



NEW YORK CITY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
CERTIFIED EMISSION CONTROL DEVICES FOR COMMERCIAL COOK STOVES
Last Updated: 08/2018

MANUFACTURER	CERTIFIED MODELS			CERTIFICATION #
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER	
Captive Aire Systems, Inc., 4641 Paragon Park, Raleigh, NC 27616	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	PCU-PF-HE-HEPA, PCU-PF-HE-HEPA-OC, PCU-PF-HE-HEPA-OC-OC followed by -1,- 2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
Grease Master 505 Cuthbertson St. Monroe, NC 28110	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	GM-PCU-PF-HE-HEPA, GM-PCU-PF-HE- HEPA-OC, GM-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
AquaMatic 4641 Paragon Park, Raleigh, NC 27616	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	AM-PCU-PF-HE-HEPA, AM-PCU-PF-HE- HEPA-OC, AM-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
Econ-Air 360 Northbrook Dr. Youngsville, NC 27596	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	EA-PCU-PF-HE-HEPA, EA-PCU-PF-HE- HEPA-OC, EA-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
Ventilation Direct, 14460 New Falls of the Neuse Road, Suite 149-293 Raleigh, NC 27614	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	VPCU-PF-HE-HEPA, VPCU-PF-HE-HEPA- OC, VPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	



NEW YORK CITY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
CERTIFIED EMISSION CONTROL DEVICES FOR COMMERCIAL COOK STOVES
Last Updated: 08/2018

MANUFACTURER	CERTIFIED MODELS			CERTIFICATION #
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER	
Stratovent 4641 Paragon Park Raleigh, NC 27616	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	SV-PCU-PF-HE-HEPA, SV-PCU-PF-HE- HEPA-OC, SV-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
Aerolater 4641 Paragon Park Raleigh, NC 27616	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	AR-PCU-PF-HE-HEPA, AR-PCU-PF-HE- HEPA-OC, AR-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
Sun Air 4641 Paragon Park Raleigh, NC 27616	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	SA-PCU-PF-HE-HEPA, SA-PCU-PF-HE- HEPA-OC, SA-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
Rupp Air Management Systems, 4641 Paragon Park Raleigh, NC 27616	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	RPCU-PF-HE-HEPA, RPCU-PF-HE-HEPA- OC, RPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
ThermoTek 4031 Tull Avenue Muskogee, OK 74403	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB- INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	TPCU-PF-HE-HEPA, TPCU-PF-HE-HEPA- OC, TPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	



NEW YORK CITY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
CERTIFIED EMISSION CONTROL DEVICES FOR COMMERCIAL COOK STOVES
Last Updated: 08/2018

MANUFACTURER	CERTIFIED MODELS			CERTIFICATION #
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER	
<p style="text-align: center;">FloAire 360 Northbrook Dr Youngsville, NC 27596</p>	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	FA-PCU-PF-HE-HEPA, FA-PCU-PF-HE-HEPA-OC, FA-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
<p style="text-align: center;">K-Tech 4641 Paragon Park Raleigh, NC 27616</p>	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	KPCU-PF-HE-HEPA, KPCU-PF-HE-HEPA-OC, KPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
<p style="text-align: center;">LDI 4641 Paragon Park, Raleigh NC 27616</p>	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	LPCU-PF-HE-HEPA, LPCU-PF-HE-HEPA-OC, LPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
<p style="text-align: center;">Global Aire, 389 Coombs Court, Milton, ON L9T 7N5, Canada</p>	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	ECO-PRE-HI-HEPA, ECO-PRE-HI-HEPA-OD, ECO-PRE-HI-HEPA-OD-OD followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	
<p style="text-align: center;">RAMAire Fresher Source Energy Solutions Inc., 343 Roselawn Avenue, Toronto, Ontario, M4R 1G2</p>	Filter- PreFilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI fan or fan by others, Optional CORE/EWC Fire System	Pollution Control Unit (PCU)	RAMEU-PF-HE-HEPA, RAMEU-PF-HE-HEPA-OC, RAMEU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)	CS2017-0001
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124	