

NYC Buildings Department 280 Broadway, New York, NY 10007

Robert D. LiMandri, Commissioner



BUILDINGS BULLETIN 2011-026 OTCR

Supersedes: None

Issuer: Alan Price, P.E.

Director, Office of Technical Certification and Research

Issuance Date: December 23, 2011

Purpose: This document establishes acceptance criteria for above-ground, nonmetallic fuel-oil storage

tanks as alternative equipment in the 2008 NYC Construction Codes.

Related Code AC 28-113.2.2 MC 1301 **Section(s):** MC 1308

Subject(s): Fuel oil, storage, above-ground; Fuel-oil, storage tank, nonmetallic; Fuel-oil storage tanks,

testing

Background: The 2008 NYC Mechanical Code does not clearly address the use of above-ground,

nonmetallic fuel-oil storage tanks. The Mechanical Code, however, recognizes NFPA 31¹ for testing of fuel-oil storage tanks. Since section 7.2.8 of NFPA 31 recognizes nonmetallic fuel-oil storage tanks constructed in accordance with UL subject 2258², this bulletin establishes the acceptance criteria for above-ground, nonmetallic fuel-oil storage tanks based on these

references.

Description: Nonmetallic fuel-oil storage tanks are constructed of a nonmetallic primary tank and metallic

secondary

Uses: Above ground nonmetallic fuel-oil storage tanks are used to store and supply fuel oil for

heating purposes.

Permissible applications:

Nonmetallic fuel-oil storage tanks shall only be used:

- 1. Above-ground, both indoor and outdoor.
- 2. In buildings used exclusively for one-family or two-family dwelling units; and
- 3. For fuel-oil heating including biodiesel blends for 100 percent (B100) and up to 20 percent (B20).

Restriction:

- Nonmetallic fuel-oil storage tanks shall not be used for the storage of waste oils and flammable liquids.
- 2. The secondary tank shall be metallic only

Evaluation Scope: 2008 NYC Construction Codes

Buildings Bulletin 2011-026 Page 1 of 2

Evaluation Criteria:

Pursuant to section AC 28-113, the Office of Technical Certification and Research (OTCR) recognizes above-ground, nonmetallic fuel-oil storage tanks fabricated, tested, and evaluated in accordance with UL subject 2258 "Outline of Investigation for Nonmetallic Tanks for Oil-Burner Fuels and Other Combustible Liquids". Acceptable nonmetallic fuel-oil tanks shall be listed and labeled and shall comply with the conditions of this bulletin.

Conditions of Acceptance:

Above-ground, nonmetallic fuel-oil storage tanks shall be manufactured and installed in accordance with the 2008 NYC Construction Codes and other applicable provisions including but not limited to the following:

A. Manufacturing

- 1. Above ground nonmetallic fuel-oil storage tanks shall be constructed as per sections 7, 8, 9, 10, 11, and 12 of UL subject 2258 and chapter 7 of NFPA 31.
- 2. Above ground nonmetallic fuel-oil storage tanks shall be marked in accordance with sections 40, 41, and 42 of UL subject 2258. The label shall also include the biodiesel percentage as identified in the scope of UL subject 2258.
- 3. Nonmetallic fuel-oil storage tanks shall only be supplied in sizes ranging from 60 gallons to 660 gallons.
- 4. All shipments and deliveries of materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and approved.

B. Installation

- Installation requirements shall be in accordance with the manufacturer's instructions, the NYC Mechanical Code, NFPA 31 and the conditions of this bulletin.
- 2. Above-ground, nonmetallic fuel-oil storage tanks installed indoor shall not be exposed to sunlight on any plastic parts.
- 3. Above-ground, nonmetallic fuel-oil storage tanks installed outdoor shall be assembled with required cover from the manufacturer.
- 4. Installation of nonmetallic fuel-oil storage tanks shall be performed by a NYC licensed oil-burning equipment installer who is certified by the manufacturer for training and experience.

Referenced Standards:

- NFPA 31-2001 "Standard for the Installation of Oil-Burning Equipment" (www.nfpa.org)
- 2. UL subject 2258-2010 "Outline of Investigation for Nonmetallic Tanks for Oil-Burner Fuels and Other Combustible Liquids" (www.ul.org)

Buildings Bulletin 2011-026 2 of 2

build safe live safe