



NEW YORK CITY DEPARTMENT OF CORRECTION
Joseph Ponte, Commissioner
Ava B. Rice, Agency Chief Contracting Officer
Central Office of Procurement

Bulova Corporate Center
75-20 Astoria Boulevard, Suite 160
East Elmhurst, NY 11370

Office: 718 546-0690
Fax: 718 278-6205

August 27, 2015

ADDENDUM # 1

Re: PIN 072201538CPD for Roof Replacement at AMKC,
Rikers Island.

Dear Prospective Bidders:

Pursuant to Section 3-02 (i) and 3-03 (f)(2) of the Procurement Policy Board (PPB) Rules, the Department of Correction (DOC) is issuing **Addendum #1** to 072201538CPD-Roof Replacement at AMKC, Rikers Island.

MODIFICATION TO SCOPE OF WORK

Section 075600 Fluid Applied Roofing (Pages C-107 through C-113) remove entirely from the Scope of Work.

QUESTIONS/CLARIFICATIONS

Question 1

Johns Manville and Siplast are the roofing manufacturers listed in the spec. The vendor GAF Building products are equal to Johns Manville in every way. We want to know if the department will accept this roofing manufacturer.

Answer 1: As per the specifications, whenever a product is specified by brand name, a substitute brand, equal to that named, may be submitted for approval subject to the requirements under Section II, B: Materials and Required Submissions.

Question 2

The liquid applied flashing at all post penetrations. However, the department will eliminate section 075600 from scope of work. Does that mean a pitch pocket will be taken its place?

Answer 2: Refer to specification section 075200 for fluid applied membrane flashing products to be used in conjunction with the SBS modified bitumen roofing system. Pitch pockets are not warrantable and will not be accepted.

Please submit this addendum with your Bids.


Agency Chief Contracting Officer

I acknowledge receipt of this addendum.

Bidder/Company Name (Print)

Authorized Representative (Print Name)

Authorized Representative (Signature)

Date