



NEW YORK CITY DEPARTMENT OF CORRECTION

Joseph Ponte, Commissioner

Ava B. Rice, Assistant Commissioner

Contracts and Procurement

Agency Chief Contracting Officer

75-20 Astoria Boulevard, Suite 160

East Elmhurst, NY 11370

Office: 718 546-0690

Fax: 718 278-6205

December 11, 2015

ADDENDUM # 2

Re: PIN 072201603CPD for Dorm "K" Elevator Replacement at Anna M. Kross Center (AMKC)

Dear Prospective Bidders:

Pursuant to Section 3-02 (i) and 3-03 (f)(2) of the Procurement Policy Board (PPB) Rules, the Department of Correction (DOC) is issuing **Addendum #2** to **072201603CPD**.

Attached to this addendum are pictures of existing shaft, elevator pit and closet.

QUESTIONS/CLARIFICATIONS

Question 1: Please issue Asbestos Containing Material Location, Quantity and Asbestos Report.

Answer 1: ACM report will be given to awarded contractor prior to demolition.

Question 2: Please issue photographs of existing shaft, elevator pit and closet.

Answer 2: Photos are attached.

Question 3: Please inform when the rest of roof waterproofing will be repaired in reference to roof waterproofing of the elevator shaft.

Answer 3: The AMKC roof project is in design phase and we expect to get the contractor by Spring of 2016.

Question 4: Please inform if the new proposed AC unit has provision for heating?

Answer 4: Yes, new heat pump has provision for heating.

Question 5: What temperature will be maintained in the Elevator Machine Room?

Answer 5: 75 Degrees Fahrenheit.

Question 6: Will tank heater be required for the hydraulic controller for the elevator?

Answer 6: No heater is needed.

Question 7: Is there any ACM in the EMR walls and building exterior walls?

Answer 7: ACM report will be given to awarded contractor prior to demolition.

BID DUE DATE

The bid opening date has been extended to **Tuesday, January 5, 2016 @ 11:00am**. Please provide all bid packages to the NYC Department of Correction, 75-20 Astoria Blvd, Suite 160, East Elmhurst, New York 11370-Attention: Jeanette Cheung

Your bid submission must contain the following:

- Section B completed (pages B-1 to B-18)
- All Addendums with signature

Please submit this addendum with your Bids.



Agency Chief Contracting Officer

I acknowledge receipt of this addendum.

Bidder/Company Name (Print)

Authorized Representative (Print Name)

Authorized Representative (Signature) **Date**











