



FIRE DEPARTMENT

9 METROTECH CENTER BROOKLYN, N.Y. 11201-3857

BUREAU OF FIRE PREVENTION

EAP Industry Notice # 8 1/21/08 EAP On-Site Test Demonstration of All Call Announcement Including the Stairs

During the Part II (demonstration) portion of the exam the candidate will be asked if the fire alarm panel enables them to make an all call announcement including the stairs . The inspector will evaluate the candidates response in comparison to the fire alarm panel to determine if the response is correct..

As a separate step, dependent upon the fire alarm panel, the candidate will be asked to make an all call announcement including the stairs. In many instances the fire alarm panel has the capability to allow an all call announcement including the stairs. However the candidate must remember to activate the stairway speakers in conjunction with the all call.

Please ensure that all candidates are completely familiar with the tools of their trade.

FDNY
Emergency Action Plan Unit

