

A. INTRODUCTION

This chapter evaluates the potential increased demand the proposed Willets Point Development Plan would place on New York City's water supply, sanitary sewage treatment, and stormwater drainage, and describes the additional infrastructure and infrastructure improvements needed to meet the projected demand in the Willets Point Development District (District). The analyses address the water supply, wastewater, and stormwater infrastructure for existing conditions, as well as the future conditions without and with the proposed Plan. In accordance with the approach outlined in Chapter 2, "Procedural and Analytical Framework," this chapter considers the cumulative impact of the proposed Willets Point Development Plan and the anticipated development on Lot B. An assessment of potential future infrastructure demand is provided for both the proposed Plan and the No Convention Center Scenario, as described in Chapter 2.

The effect of the proposed Plan on other infrastructure components, such as those associated with solid waste management, energy, and transportation, are addressed in Chapter 15, "Solid Waste and Sanitation," Chapter 16, "Energy," and Chapter 18, "Transit and Pedestrians," of this Draft Generic Environmental Impact Statement (DGEIS).

PRINCIPAL CONCLUSIONS**WATER SUPPLY**

The proposed Plan and anticipated development on Lot B would cumulatively require approximately 4.36 million gallons per day (mgd) of water supply. This additional demand would not result in a significant adverse impact on the City's water supply system. This projected flow would be supplied by the existing 72-inch water main serving the District, which may need to be relocated as a result of the proposed Plan, depending on the site plan that is ultimately selected.

Under the proposed Plan, the existing 72-inch prestressed reinforced concrete pipe (PRCP) water main within Willets Point Boulevard could be relocated to a private roadway that runs along the eastern boundary of the development District. The relocated main would consist of a new 72-inch-diameter steel pipe installed on piles from Roosevelt Avenue to the crossing of the Van Wyck Expressway and would include the replacement of one valve chamber. The construction of the new pipe would require water supply service to be transferred from the existing 72-inch PRCP, which would be taken out of service once the relocated steel pipe was installed and service transferred. Two existing booster pump stations would need to be rehabilitated to maintain proper pressure and flow. The existing booster pump stations, which were originally constructed as a redundancy to the system, are located below grade in an area directly across the Flushing River from the District. The replacement of the components of these pump stations in addition to any modifications required to bring the system into compliance with existing codes and regulations would be required as a result of the proposed Plan. In order to provide

Willets Point Development Plan

acceptable access to the new main once it is constructed, the developer would provide a 40-foot mapped permanent easement designated in accordance with New York City Department of Environmental Protection (DEP) requirements.

SANITARY SEWAGE

Under the proposed Plan, the District would be connected to the City's sanitary sewer system, replacing the current reliance on septic tanks. Sanitary wastewater from the District would be conveyed to a new sanitary pump station, which would most likely be constructed within the District. Sanitary wastewater from Lot B would be connected to the pumped discharge utilized by Citi Field. The pump station would be designed and constructed to DEP standards. A new force main would be constructed to convey sanitary flow from the District to the existing 96-inch-diameter City sewer at 108th Street (which flows to the Bowery Bay Water Pollution Control Plant [WPCP]). This new force main route would cross beneath 126th Street and the Grand Central Parkway.

The proposed Plan and the anticipated development on Lot B would result in an increase of sanitary flow to the Bowery Bay WPCP of approximately 2.8 mgd. The projected available capacity at the Bowery Bay WPCP in 2017 is 28 mgd. The Bowery Bay WPCP has adequate capacity to meet the increased demand associated with the proposed Plan.

STORMWATER

Prior to redevelopment of the site, an amended drainage plan would be prepared to comprehensively address all the surface runoff and separate handling of the sanitary dry flow that would be generated as a result of the proposed Plan, and drainage features to be included in the development of the District. This drainage plan would accommodate the City's current drainage plan for the area (Plan No. 295⁵), and easements associated with highway drainage.

The proposed Plan would maintain separate stormwater and sanitary sewer systems, in accordance with the City's goals to reduce combined sewer overflow (CSO) events. Since the existing industrial area is largely impervious (the District and Lot B are currently largely built with impervious structures including buildings, paved surfaces, and roads, which create surface runoff), its conversion to a high density mixed-use district would not significantly change the overall runoff conditions within the area. The overall stormwater runoff volume in the future with the proposed Plan would therefore remain largely unchanged from the current runoff volume of 350 cfs. Stormwater generated within the District is currently directed to the two existing outfalls on 126th Street and 127th Street. The total combined discharge capacity of these two outfalls (148 cfs) is less than the current runoff generated on-site. The current stormwater conveyance system is therefore insufficiently sized to accommodate the runoff being generated, resulting in uncontrolled and untreated runoff and street flooding during storm events. To eliminate these stormwater management issues, the proposed Plan would require the construction of a new stormwater conveyance system, including piping, sustainable design features, and an adequately sized detention tank, or other equivalent means, to accommodate the 3.79 acre-feet of stormwater that is beyond the discharge capacity assuming a 5-year storm event.

With the implementation of adequate stormwater management features, stormwater flow could be controlled to remain within the capacity of the two existing outfalls without the need to modify these outfalls. If it is determined that the stormwater management features selected for

the detailed development plan do not adequately supplement the stormwater flow capacity of the existing outfalls, a new outfall would be proposed to augment the existing system.

The proposed Plan would require coverage under the current State Pollutant Discharge Elimination System (SPDES) general permit program for discharges from construction activities. Prior to the initiation of construction activities, a Stormwater Pollution Prevention Plan (SWPPP) would be developed pursuant to the requirements of the general permit and would be enforced throughout the sequence of construction activities. Since Flushing Bay is a regulated water body, the implementation of sustainable design features would be required to ensure that applicable discharge criteria would be met after construction is completed. These actions would ensure that pollution prevention measures are in place during and after construction activity and enable adequate control of potential sources of pollution relating to stormwater management.

B. METHODOLOGY

This chapter includes the following:

- Discussions of the existing water supply network serving the proposed District area;
- Assessment of the existing water demand in the District using water demand rates from the *City Environmental Quality Review (CEQR) Technical Manual*, the New York State Department of Environmental Conservation (DEC)'s *Design Standards for Wastewater Treatment Works* (1998), and DEP's *Draft Rules and Regulations Governing the Construction of Private Sewers and Drains*;
- Description of the existing sanitary sewage management in the District and the Bowery Bay WPCP service area;
- Data on the existing flows to the Bowery Bay WPCP for the latest 12-month period, and information about the nearest existing pump station;
- Estimates on the existing sanitary and stormwater infrastructure capacity in the District area;
- Description of the future water supply demands resulting from additional planned developments within the ¾-mile study area boundary, as discussed in Chapter 2, but without the proposed Plan and anticipated development on Lot B;
- DEP's predicted wastewater demands for the Bowery Bay WPCP service area;
- Description of the future sanitary and stormwater system without the proposed Plan and Lot B;
- Estimate of the increase in water demand associated with the proposed Plan and Lot B to assess the impacts on the City's water supply and conveyance system;
- Estimate of the amount of sanitary sewage that would be generated by the proposed Plan and Lot B, and assessment of the resulting effects on the existing local wastewater management system and operations at the Bowery Bay WPCP;
- Identification of the additional wastewater infrastructure that would be required to transport and treat the sanitary sewage generated by the proposed Plan and Lot B;
- Assessment of the potential demand the proposed Plan and Lot B would place on the sanitary and stormwater collection system, and description of the sanitary and stormwater management strategies for the proposed Plan;

Willets Point Development Plan

- Results of the modeled analysis of combined sanitary and stormwater runoff flows in the Bowery Bay WPCP service area and examination of the flows generated by the proposed Plan and Lot B to determine any potential impacts on CSO events; and
- Evaluation of the effect of the No Convention Center Scenario on water supply, wastewater, and stormwater systems.

SUSTAINABLE DESIGN FEATURES RELATED TO INFRASTRUCTURE

The proposed Plan would adopt a separate and sustainable stormwater drainage plan. Additional sustainable features would be encouraged by the City and included as design guidelines for the development of the site. The sustainable design features under consideration would decrease the demand on infrastructure. These features include, but are not necessarily limited to:

- Increased quantity, density, and diversity of trees;
- Sustainable irrigation and landscaping practices;
- Graywater recycling for individual building sites;
- Integration of vegetated swales;
- Green roofs;
- Rooftop storage and filters;
- Underground storage;
- Inline pipe storage;
- Decorative wet ponds;
- Detention dry ponds;
- Proprietary pre-treatment structures (e.g., Stormceptor, Vortechinics);
- Bioengineered and structural practices to reduce and control runoff;
- Stormwater recycling facilities (reuse for toilet flushing, custodial work, landscape irrigation, and other uses to reduce demand for potable water);
- Optimized right-of-way drainage;
- Vegetated filters and buffer strips;
- Water quality inlets including oil and grit separators, media filters, and high-volume treatment proprietary devices;
- Bioretention-shallow swales;
- On-site wastewater storage and treatment facilities; and
- Other low-impact, effective measures.

C. EXISTING CONDITIONS

WATER SUPPLY

New York City's primary surface water supply, which provides approximately 1.2 billion gallons of water per day, is serviced via a network of reservoirs, aqueducts, and tunnels extending as far as 125 miles north of the City. This network comprises three systems: the Catskill system, the Delaware system, and the Croton system, which are all operated by DEP. The systems are supplied with water from watershed areas in the Catskill Mountains and Upper

Delaware River drainage basins. Water is conveyed from these systems to the local distribution grid via aqueduct tunnels that primarily operate via gravity flow; only 4 percent of the City's water must be pumped to its final destination.

The water from the Delaware and Catskill systems is distributed to the City through three tunnels: City Tunnel No. 1, which goes through the Bronx and Manhattan to Brooklyn; City Tunnel No. 2, which currently supplies the District (and goes through the Bronx, Queens, and Brooklyn (and from there through the Richmond Tunnel to Staten Island)); and City Tunnel No. 3 (Stage 1), which goes through the Bronx, Manhattan, and terminates in Queens. Tunnel 3 is being constructed in three stages and, when completed, will enhance and improve the City's water delivery system, and allow for the inspection and repair of City Tunnels No. 1 and 2 for the first time since they were put into service, in 1917 and 1936, respectively. According to the New York City 2006 Drinking Water Supply and Quality Report, construction of City Tunnel No. 3 is expected to be completed in 2025. The 13-mile Stage 1 section went into service in August 1998. It runs from Hillview Reservoir in Yonkers, through the Bronx, down Manhattan across Central Park, and into Astoria, Queens. Stage 2 consists of a 5.5-mile section in Brooklyn that connects to a 5-mile leg in Queens. These sections were completed in May 2001 and could be activated as early as 2009. This section would serve as a backup water supply for the District and the surrounding area, e.g., for instances in which Tunnel No. 2 requires maintenance.

Within the City, a grid of underground mains distributes water to consumers. Large mains, up to 96 inches in diameter, feed smaller mains, including 20-, 12- and 8-inch mains, which distribute water to individual locations. These mains also provide water to fire hydrants along many of the City's streets. Water pressure throughout the City water supply system is controlled by pressure regulators.

The proposed Willets Point Development District is within the boundary of the federally designated Brooklyn-Queens sole source aquifer. This designation was made pursuant to Section 1424 (e) of the Safe Drinking Water Act (SDWA), in recognition of the importance of the aquifer's vulnerability to contamination. The area's reliance on septic disposal inherently conflicts with SDWA goals. The aquifer is currently not used as a potable water source.

The District and adjoining streets currently have a complete, interconnected grid of water distribution mains that are served by a 72-inch water main, constructed of PRCP, located on Willets Point Boulevard. This gravity distribution system is fed by City Water Tunnel No. 2. The existing demands within the District are generally limited to the current on-site uses and the episodic supply needs of Shea Stadium, which range from 1 to 2 mgd. In addition to these demands, the existing 72-inch main also supplies water to a substantial portion of northeast Queens. This supply main currently operates under its capacity to provide water to the area. The pressures in these lines are adequate to meet the service demand.

As described in Chapter 3, existing uses in the area include automotive repair shops and other industrial-type uses. Based on water generation rates that are typical for these uses, the existing water consumption demand (i.e., potable water use) in the District is estimated to be approximately 422,242 gpd (see Table 14-1).

Table 14-1
Existing Water Consumption and Sewage Generation Rate

Current Use	Area	Domestic Rate		Air Conditioning Rate		Total
	Square Feet (sf)	gpd/sf	gpd	gpd/sf	gpd	gpd
Retail ^a	39,230	0.17	6,669	0.17	6,669	13,338
Commercial/Office ^b	59,389	0.10	5,939	0.10	5,939	11,878
Commercial/Other ^c	135,178	0.17	22,980	0.17	22,980	45,961
Industrial/Manufacturing ^d	558,011	0.46	256,203	0.17	94,862	351,065
TOTAL	791,808	N/A	291,792	N/A	130,450	422,242

Notes:

- ^a Assumes water usage and sewage generation rates for Retail/Public Use.
- ^b Assumes 0.10 gpd/sf and 25 gpd/person, which equates to 1 person per 250 sf.
- ^c Use group includes one residence, a deli and private club in addition to auto related facilities and miscellaneous businesses.
- ^d Assumes water usage and sewage generation rates for Retail/Public Use. Use group includes storage, recycling, non-retail auto uses, transportation, construction, distribution and manufacturing. Assumes 20,000 gpd/acre (10,000 gpd/acre multiplied by zoning district factor of 2.00 for M3-1).

Sources:

New York City Department of Finance Real Property Assessment Database (RPAD) 2005 and business information provided by the New York City Economic Development Corporation for the floor area by use group.
 3L-2 Table in the *CEQR Technical Manual* for Water Consumption and Sewage Generation Rates.
 Table 3 in the DEC Design Standards for Wastewater Treatment Works (1998) for Water Consumption and Sewage Generation Rates.
 DEP's Draft Rules and Regulations Governing the Construction of Private Sewers and Drains.

SANITARY SEWAGE

New York City's sewer system includes an extensive grid of sewers beneath the streets that convey wastewater to 14 WPCPs. Together, these plants, which are operated by DEP, treat approximately 1.7 billion gallons of sewage per day. Most of the sewer systems within New York City are combined sewer systems, which carry both sanitary sewage from buildings and stormwater collected in catch basins and storm drains. However, some areas of the City, primarily in Queens and Staten Island, have separate systems for sanitary sewage and stormwater. In addition, small areas of Staten Island, Brooklyn, and Queens, including the Willets Point Development District, use septic systems to dispose of sanitary sewage.

The Willets Point Development District is located within the service area of the Bowery Bay WPCP, which is located on the East River in Astoria, Queens. Currently, the Willets Point area is not connected to the New York City sanitary sewer system and relies entirely on septic systems as the means of sewage treatment. The nearest connection to the City sewer infrastructure from the District is at the existing below-grade 37th Avenue Pump Station, located approximately 4,000 feet northwest of the District. This pump station has the capacity to pump up to 5 mgd into the 20-inch force main, which discharges into a 36-inch gravity combined sewer. Based on information obtained from DEP and as-built drawings, the pump station includes two 10-inch dry pit submersible pumps, each rated for 3,450 gallons per minute (gpm) with a peak rating of 4,600 gpm. However, some reports suggest the existing pump station peak rated capacity is 3,450 gpm. Nevertheless, the existing pump station has no extra capacity.

The sewer system downstream of the 37th Avenue Pump Station consists of combined sewers, regulators, and interceptors. The 36-inch combined sewer feeds into a 96-inch combined sewer under 108th Street, which carries the sewage through a series of regulators to the Bowery Bay WPCP (see Figure 14-1 for the Bowery Bay WPCP drainage schematic and sewer map.)





Figure 14-1
Bowery Bay Existing Sewer System

BOWERY BAY WPCP SERVICE AREA

The Bowery Bay WPCP treats sanitary wastewater to secondary treatment standards prior to discharge to the East River. The existing sewer system within the Bowery Bay WPCP service area is a combined sewer system that collects both sanitary sewage and stormwater runoff. Discharges from this plant are regulated by DEC through a SPDES permit. At the plant, water is treated through a variety of physical and biological processes that remove solid contaminants so that the water discharged into the City’s waterways does not adversely affect water quality. During dry weather, combined sewers function as sanitary sewers, conveying all flows to the WPCP for treatment. During wet weather, however, stormwater entering the combined sewer/regulator system can exceed the capacity of the regulator and the treatment plant and trigger a CSO event into the City’s waterways. The purpose of a regulator is to divert sanitary flow from the existing combined sewers to the intercepting sewer during normal flow periods (dry weather), and limit the flow to the intercepting sewer to twice the dry weather flow during storm periods (wet weather). During a significant storm event, CSOs within the Bowery Bay WPCP service area discharge to the East River and Flushing Bay. Currently, the CSO outfalls that may potentially be affected by the development within the District and on Lot B discharge 5,711.68 million gallons per year to area waterways (see Table 14-6). Generally, the impact of CSO events on local water quality is short-term at most locations, due principally to the mixing caused by tidal currents of the receiving waters and the fact that sanitary flows are diluted by runoff.

The combined sewer/regulator system within the Bowery Bay WPCP service area is designed to deliver twice the mean dry weather, or sanitary, flow to the Bowery Bay WPCP for treatment. While the total hydraulic capacity of the Bowery Bay WPCP is 300 mgd, it can only provide treatment to secondary levels for 150 mgd. Flow records for the plant are maintained by DEP and are reported to DEC. Table 14-2 presents the current flow data for the Bowery Bay WPCP as reported by DEP. As shown in the table, the average daily flow rate at the plant for the period between January 2007 and December 2007 was 105 mgd. This value is significantly less than the 150 mgd permitted design capacity of the plant.

**Table 14-2
2007 Monthly Average Daily Flows at Bowery Bay WPCP**

Month	Flow (mgd)
January	88
February	85
March	104
April	119
May	106
June	114
July	117
August	115
September	101
October	105
November	97
December	104
12-Month Average	105
SPDES Permitted Capacity	150

Source: DEP

Willets Point Development Plan

As described above, the District currently has no connections to the New York City sanitary sewer system and relies on septic systems as the only means of sewage treatment. Individual property owners are responsible for maintaining these systems.

STORMWATER

Stormwater runoff is flowing surface water generated by rainfall. Runoff volume and rate of discharge vary depending upon the type of land cover and slope. The existing stormwater runoff was calculated for the District based upon these parameters using the Rational Method.¹ The Willets Point Development District comprises 14 blocks (Blocks 1820 through 1833) and segments of public streets, and is generally bounded to the east by the Van Wyck Expressway and an undeveloped lot owned by the Metropolitan Transportation Authority (MTA), to the south by Roosevelt Avenue, to the west by 126th Street, and to the north by Northern Boulevard. The area is currently developed at a moderate density for industrial uses and comprises mostly developed land, and thus is impervious in its present condition.

The estimated existing stormwater runoff generated within the limits of the proposed District and Lot B, based on DEP's Actual Stormwater Flow Criteria (Revised September 2006), is approximately 350 cubic feet per second (cfs) for a 5-year storm event. Stormwater runoff generated in the District and Lot B is currently discharged into Flushing Bay via two 60-inch outfalls on 126th Street and 127th Street. The maximum capacity for each outfall is 74 cfs. Since the runoff generated onsite is greater than the total combined discharge capacity of the two outfalls (148 cfs), the current stormwater discharge infrastructure is insufficiently sized to accommodate the runoff generated. In addition, there is only minimal stormwater conveyance infrastructure. Since the area lacks an adequate drainage system, much of the runoff flows as overland flow and ponds, causing area streets to flood during storm events. Furthermore, runoff from the many facilities in the area is neither controlled nor treated prior to entering storm drains that convey this stormwater to the outfalls.

D. THE FUTURE WITHOUT THE PROPOSED PLAN

WATER SUPPLY

In the future without the proposed Plan, no significant change in future water demand is expected within the District. The water usage within the District is expected to remain at its current level, and within the capacity of the City's water supply system. The water demand generated by the projects expected to be developed in the future without the proposed Plan would not overburden the City's water supply system, nor would it be large enough to significantly impact the City's water supply system.

In addition, in the future without the proposed Plan, Stages 1 and 2 of the City Tunnel No. 3 could be activated as early as 2009 to serve as a backup water supply for the District.

¹ The rational method is a method used by DEP to determine storm flow. Using this method, the peak rate of runoff is dependent upon rainfall intensity, infiltration, topography, type of land cover, geographic location, and the drainage basin area.

SANITARY SEWAGE

In the future without the implementation of the proposed Plan, there would be no significant change in demands within the District on infrastructure systems. The Bowery Bay WPCP Phase II upgrade, which entails replacement of several WPCP components, will be completed by 2009; these improvements will not result in a change in the 150 mgd capacity of the facility. It is not assumed that there would be an extension of City sewers into the area; therefore, the District would continue to rely on septic systems for sanitary waste disposal.

As previously noted, the new Citi Field Stadium, to the immediate west of the proposed District, is expected to be completed in 2009. However, it is not expected that the demand on local infrastructure would change appreciably with the completion of the stadium, since the size and infrastructure demands of the replacement stadium would be comparable with the existing Shea Stadium. In addition, the new Citi Field Stadium would retain the existing configuration of water supply and sewer infrastructure passing beneath the Grand Central Parkway.

Preliminary calculations by DEP indicate that the Bowery Bay WPCP would receive an average of 122 mgd sewage flow in the year 2017, 17 mgd greater than the 2007 monthly average daily flow. This 17 mgd sewage generation increase has been predicted by DEP based upon the increase in development anticipated for the entire Bowery Bay WPCP service area. Based upon these 2017 projections, the Bowery Bay WPCP would have an available capacity of approximately 28 mgd in the future without the proposed Plan.

CSO discharge volumes are primarily influenced by the amount of storm water entering the combined sewer system. Substantial increases in CSO discharges at Bowery Bay outfalls are not anticipated by the No-Action year, since the area is urbanized and projected new development in the area would not result in large increases to impervious surface draining to the combined sewers.

STORMWATER

In the future without the proposed Plan, there would be no significant change in demands within the Willets Point Development District on stormwater management infrastructure. It is assumed that there would not be an extension of City sewers into the area, and therefore stormwater runoff generated in the area would continue to be managed by an undersized separate stormwater collection system and discharged into Flushing Bay via the two 60-inch outfalls located on 126th Street and 127th Street. Since there would be no change to runoff generated or existing stormwater management infrastructure, there would be no change to the drainage plan.

It is assumed that no other improvements to the stormwater infrastructure would be made and the area would continue to rely on the existing ineffective stormwater conveyance infrastructure. Therefore, in the future without the proposed Plan, runoff in the area would continue to be neither controlled nor treated prior to entering storm drains, and streets in the area would continue to flood during storm events.

E. PROBABLE IMPACTS OF THE PROPOSED PLAN

WATER SUPPLY

With the proposed Plan the existing local water supply distribution network would be replaced with appropriately sized infrastructure within the streetbeds, as the new streets are developed. It

Willets Point Development Plan

is also expected that the area would continue to be served by City Water Tunnel No. 2, which feeds the existing 72-inch transmission main, described above in section “C. Existing Conditions.” In addition, Stages 1 and 2 of the City Tunnel No. 3 could be activated as early as 2009 and serve as a backup water supply for the District.

Under the proposed Plan, the existing 72-inch PRCP water main within Willets Point Boulevard would be relocated to a private roadway that runs along the eastern boundary of the development District. The relocated main would consist of a new 72-inch-diameter steel pipe installed on piles from Roosevelt Avenue to the crossing of the Van Wyck Expressway and would include the replacement of one valve chamber. The construction of the new pipe would require water supply service to be transferred from the existing 72-inch PRCP, which would be taken out of service once the relocated steel pipe was installed and service transferred. Two existing booster pump stations would need to be rehabilitated, tested and on-line so that proper pressure and flow would be maintained within the existing Willets Point water distribution system. The existing booster pump stations, which were originally constructed as a redundancy to the system, are located below grade in an area directly across the Flushing River from the District. The replacement of the components of these pump stations in addition to any modifications required to bring the system into compliance with existing codes and regulations would be required as a result of the proposed development. In order to provide acceptable access to the new main once it is constructed, the developer would provide a 40-foot mapped permanent easement designated in accordance with DEP requirements.

Preliminary calculations indicate that the proposed Plan and Lot B would cumulatively require 4.36 mgd water supply (see Table 14-4), which is nearly twice the increase in demand anticipated in the study area in the future without the proposed Plan. However, this is still within the capacity of the existing 72-inch transmission main. This incremental increase in demand represents approximately 0.36 percent of the City’s total current average daily water demand of 1.2 billion gpd, and would not overburden the City’s water supply system, nor be large enough to significantly impact the City’s water supply system. In addition to this calculated demand, a minimal amount of additional water demand would be required for landscaping. This demand would be seasonal, and it is expected that some portion of it could be met through recycled water that would be collected in stormwater runoff tanks, as identified in Section B, “Methodology.” A summary of the future projected demand calculations for the proposed Plan is presented in Table 14-4.

Chapter 3L, Section 211 of the *CEQR Technical Manual* indicates that actions that would have exceptionally large demand for water, such as large developments (e.g., those that use more than 1 mgd) may require an additional assessment of the effect of such action on water pressure and supply. As noted above, the existing infrastructure is adequate to supply water to the site. The proposed Plan would replace and improve the distribution system that conveys water within the District. These improvements would completely upgrade the local water supply network and the distribution system’s ability to handle the additional demand without creating an impact on local water pressure. Since the existing distribution system within the District is above the minimum acceptable pressure of 20 psi for uninterrupted service, and the developed infrastructure would be designed to a similar standard, it is concluded that the proposed Plan would not have an adverse effect on water pressure.

Table 14-4
Projected Water Usage with the Proposed Plan and Lot B

Proposed Use	Flow Rate		Sq. Ft. Redevelopment Area			Water Consumption (gpd)		
	Type	gpd/sf	Willets Point	Lot B	Total	Willets Point	Lot B	Total
Residential	Domestic	0.401	5,500,000	0	5,500,000	2,200,000	0	2,200,000
	Air Conditioning	0.17				935,000	0	935,000
Retail	Domestic	0.17	1,700,000	184,500	1,884,500	289,000	31,365	320,365
	Air Conditioning	0.17				289,000	31,365	320,365
Commercial / Office	Domestic	0.10	500,000	280,000	780,000	50,000	28,000	78,000
	Air Conditioning	0.10				50,000	28,000	78,000
Hotel	Domestic	0.1875	560,000	0	560,000	105,000	0	105,000
	Air Conditioning	0.17				95,200	0	95,200
Convention Center	Domestic	0.17	400,000	0	400,000	68,000	0	68,000
	Air Conditioning	0.17				68,000	0	68,000
School	Domestic	0.205	130,000	0	130,000	25,500	0	25,500
	Air Conditioning	0.10				13,000	0	13,000
Community Facility	Domestic	0.17	150,000	0	150,000	25,500	0	25,500
	Air Conditioning	0.17				25,500	0	25,500
Proposed Plan and Lot B (sq. ft.)			8,940,000	464,500	9,404,500			
Water Consumption Subtotals (gpd)			Domestic			2,763,000	59,365	2,822,365
			Air Conditioning			1,475,700	59,365	1,535,065
Total Water Consumption (gpd)						4,357,430		
<p>The following assumptions were made: <i>Residential: Assumes 400 gpd per unit^a and 1000 sf per unit, which equates to 0.40 gpd/sf. Assumes 112 gpd/person. Retail: Assumes 0.17 gpd/sf^a. Commercial/Office: Assumes 0.10 gpd/sf^a and 25 gpd/person^b, which equates to 1 person per 250 sf. Hotel: Assumes 150 gpd per room^b and 800 sf per room, which equates to 0.1875 gpd/sf. School: Assumes 30 gpd/seat^b and approximately 850 seats, (153 sq ft per seat for 130,000 sq ft total area) which equates to 0.20 gpd/sq. ft. (Assumes no boarding) Community Facility: Assumes water usage and sewage generation rates for Retail/Public Use.</i></p> <p>Source: a: 3L-2 Table in the CEQR Technical Manual for Water Consumption and Sewage Generation Rates b: Table 3 in the NYSDEC Design Standards for Wastewater Treatment Works (1998) for Water Consumption and Sewage Generation Rates</p>								

SANITARY SEWAGE

As discussed above, the entire Willets Point Development District currently has no connections to the New York City sanitary sewer system, and individual septic fields are used throughout the area. The proposed Plan would include the development of sanitary sewer infrastructure that would provide a new sanitary collection service to the area and eliminate the existing septic systems. The elimination of septic disposal in Willets Point is consistent with SDWA provisions for the protection of designated sole source aquifers. Sanitary wastewater from the District would be conveyed to a new private sanitary (dry flow) pump station, which would most likely be constructed within the District. The pump station would be designed and constructed to DEP and DEC standards. A new force main would transmit sanitary flow from the District to the existing 96-inch-diameter City sewer in 108th Street (which flows to the Bowery Bay WPCP). This new force main route would cross beneath 126th Street and the Grand Central Parkway. Sanitary wastewater from Lot B would be connected to the pumped discharge utilized by Citi Field.

Willets Point Development Plan

According to the *CEQR Technical Manual*, for assessment purposes, estimates of an area’s daily sanitary sewage generation are assumed to be equivalent to the domestic water usage rates. Wastewater generated from air conditioning use is minimal because of the recirculation and evaporation processes of water cooling systems, and is therefore not included in the overall wastewater volumes.

The projected sanitary sewage generation rates were evaluated based on the proposed Plan and the anticipated development on Lot B. Wastewater flow rates were estimated using DEC 1988 Design Standards for wastewater flow rate design and the *CEQR Technical Manual*. Table 14-5 presents the anticipated sewage generation under the proposed Plan and Lot B. Based on that analysis, the sanitary wastewater rate with the proposed Plan and the anticipated development on Lot B would be approximately 2.8 mgd or less than 2 percent of the Bowery Bay WPCP total treatment capacity. As described above in Section D, “The Future Without the Proposed Plan,” the projected available capacity at the Bowery Bay WPCP in 2017 is 28 mgd. The sanitary wastewater rate with the proposed Plan and the anticipated development on Lot B is approximately 10.1 percent of the Bowery Bay WPCP available capacity projected for the 2017 Build year. Thus, the additional wastewater flow expected from the proposed Plan and Lot B would not cause the Bowery Bay WPCP to exceed its capacity or SPDES permit limits of 150 mgd. Therefore, sanitary wastewater generated by the proposed Plan and Lot B would not compromise the ability of the Bowery Bay WPCP to properly treat wastewater, and the proposed Plan and Lot B would not significantly impact the City’s Bowery Bay WPCP in the 2017 analysis year.

Table 14-5

Estimated Wastewater Generation for the Proposed Plan and Lot B

Proposed Use	Domestic Sewage Generation Rate (gpd/sf)	Sq. Ft. Redevelopment Area			Sewage Generation (gpd)		
		Willets Point	Lot B	Total	Willets Point	Lot B	Total
Residential	0.40	5,500,000	0	5,500,000	2,200,000	0	2,200,000
Retail	0.17	1,700,000	184,500	1,884,500	289,000	31,365	320,365
Commercial / Office	0.10	500,000	280,000	780,000	50,000	28,000	78,000
Hotel	0.1875	560,000	0	560,000	105,000	0	105,000
Convention Center	0.17	400,000	0	400,000	68,000	0	68,000
School	0.20	130,000	0	130,000	25,500	0	25,500
Community Facility	0.17	150,000	0	150,000	25,500	0	25,500
Subtotals		8,940,000	464,500	9,404,500	2,763,000	59,365	2,822,365
Total Sewage Generation (gpd)					2,822,365		
The following assumptions were made: <i>Residential: Assumes 400 gpd per unit^a and 1000 sf per unit, which equates to 0.40 gpd/sf. Assumes 112 gpd/person.</i> <i>Retail: Assumes 0.17 gpd/sf^a.</i> <i>Commercial/Office: Assumes 0.10 gpd/sf^a and 25 gpd/person^b, which equates to 1 person per 250 sf.</i> <i>Hotel: Assumes 150 gpd per room^b and 800 sf per room, which equates to 0.1875 gpd/sf.</i> <i>School: Assumes 30 gpd/seat^b and approximately 850 seats, (153 sq ft per seat for 130,000 sq ft total area) which equates to 0.20 gpd/sq. ft. (Assumes no boarding)</i> <i>Community Facility: Assumes water usage and sewage generation rates for Retail/Public Use.</i> Source: <i>a: 3L-2 Table in the CEQR Technical Manual for Water Consumption and Sewage Generation Rates</i> <i>b: Table 3 in the NYSDEC Design Standards for Wastewater Treatment Works (1998) for Water Consumption and Sewage Generation Rates</i>							

Since the sanitary sewage generated by the proposed Plan and Lot B would bypass the existing 37th Street Pump Station and be conveyed to the Bowery Bay WPCP via a new force main connection directly to the adequately sized combined sewer in 108th Street, an evaluation of the

effect of the proposed Plan on the sewer system within the vicinity of the existing 37th Avenue Pump Station is unnecessary.

Since the development within the District would provide separate adequately sized storm sewers, stormwater runoff would not contribute to flow being directed to the Bowery Bay WPCP. The only discharges to the Bowery Bay collection system from the proposed Plan development would be from the sanitary sewers. Since the increase in sanitary flow could impact CSO discharges, the effect of an increase in sanitary flow to the combined sewer/regulator system within the Bowery Bay WPCP service area was investigated using the current Bowery Bay CSO model. The Bowery Bay collection system was modeled using Wallingford Software's InfoWorks model.

The purpose of the modeling analysis was to quantify potential changes in CSO conditions with the proposed Plan and Lot B. The CSO model simulation focused on the effect of additional sanitary discharge flows to the combined sewer/regulator system, since the sewer/regulator capacity would determine any changes in CSO volumes resulting from the proposed Plan and Lot B development to Flushing Bay. Modeling simulations were performed for the projected annual sanitary wastewater rate of 2.8 mgd from the development Plan and Lot B. Meteorological and tidal data for 2006 were used for this simulation. Modeling simulations were performed evaluating projected additional sanitary discharge from the proposed Plan and Lot B compared with the future annual volumes in the Bowery Bay system without the proposed Plan to estimate whether the additional sanitary flow associated with the proposed Plan would, when combined with the baseline wet-weather flows, increase the CSO volumes.

Based upon model simulation results of conditions with the proposed Plan and Lot B, the total annual volume of CSO discharge would increase by less than one percent (0.76 percent) in the system. The largest increase in discharge would occur at Outfall BB-008 (see Figure 14-2). The distribution of the increase in CSO discharges by outfall is summarized in Table 14-6.

The model predicts that with a projected annual sanitary wastewater rate of 2.8 mgd to the Bowery Bay collection system from the development and Lot B, the total annual CSO volume being discharged to the East River and Flushing Bay would be approximately 44 million gallons. The predicted annual increase in flow to the Bowery Bay WPCP would be 882 million gallons. The results of these simulations show that there would be no significant increase in CSO volumes. In addition, model simulations indicate that there would be no increase in the frequency of CSO events as a result of the proposed Plan, since CSOs primarily relate to stormwater inputs, which greatly exceed sanitary flow rates during storm events.

As indicated above, the flow increases associated with the proposed Plan and Lot B are within the capacity of the Bowery Bay WPCP. The proposed Plan would include a new private sanitary pump station and force main to transmit sanitary wastewater from the District to the Bowery Bay WPCP. This pump station and force main would exclusively carry sanitary flows and would not significantly affect CSO volumes or frequency. The Plan would also provide new sanitary collection sewers in the District and a separate stormwater collection and discharge system (see discussion below). Under the proposed Plan, provided these system improvements are incorporated into the amended drainage plan for the area, significant impacts on the sanitary sewer system would not occur.



Table 14-6
CSO Discharges – Existing and Proposed Conditions

Outfall	Existing (MG)	Proposed (MG)	Increase (MG)	% Increase (MG)
BB-002	575.26	583.52	8.26	1.44%
BB-003	75.95	76.02	0.07	0.09%
BB-005	1,231.5	1,245.64	14.14	1.15%
BB-005 (24th Ave)	870.78	872.54	1.76	0.20%
BB-006L	414.78	414.80	0.02	0.00%
BB-006U	1,412.02	1,414.28	2.26	0.16%
BB-007	11.94	12.02	0.08	0.67%
BB-008	535.37	552.06	16.69	3.12%
BB-041	130.47	130.87	0.4	0.31%
TI-010	453.61	453.61	0	0.00%
Total CSO	5,711.68	5,755.36	43.68	0.76%
WPCP	26,143.09	26,981.21	838.12	3.21%
Grand Total	31,854.77	32,736.57	881.8	2.77%
<p>Notes: Total CSO – Total CSO volume to Flushing Bay WPCP – Total combined sewage flow to BB WPCP Grand Total – Total volume of both CSO volumes to Flushing Bay and combined sewage to BB WPCP Source: Model simulation results of Existing Bowery Bay CSO collection system using Wallingford Software’s InfoWorks. Assumes 2006 rainfall and tide.</p>				

The proposed Plan would establish separate storm and sanitary waste water disposal systems in the District. Overall, this is expected to result in improved water quality in Flushing Bay by:

- eliminating the reliance on septic disposal;
- improving the stormwater quality by eliminating site flooding, improving the quality of the soil substrate of the site, and providing direct drainage to storm sewers;
- incorporating sustainable design features, where feasible, to reduce the discharge volume and increase the quality of storm water discharges; and
- preventing stormwater generated within the District from entering the combined sewer system, which would increase the frequency and volume of CSO discharges.

The sanitary system would discharge to the combined sewer in 108th Street. The increased volume of sanitary flow to this combined sewer system would result in an increase, by volume, in CSO discharge to Flushing Bay of less than 1 percent. No increase in the frequency of CSO events is predicted to occur. The effect of this small increase in the annual CSO volume on Flushing Bay would be mitigated by the beneficial effects of the storm and sanitary wastewater disposal systems, as indicated above.

STORMWATER

Even though the proposed Plan would transform an industrial area into a high density mixed-use district, the overall volume of stormwater runoff within the area would remain unchanged, since the District and Lot B are largely built with impervious structures, including buildings, paved

surfaces and roads that create surface runoff. The overall stormwater runoff volumes in the future with the proposed Plan would remain largely unchanged from the current estimated runoff volume of 350 cfs. Stormwater generated within the District is currently directed to the two existing outfalls at 126th Street and 127th Street. The total combined discharge capacity of these two outfalls (148 cfs) is less than the current runoff generated on-site. Furthermore, the current stormwater conveyance system is undersized, which results in uncontrolled and untreated runoff and street flooding

With the implementation of adequate stormwater management features, stormwater flow would be controlled to remain within the capacity of the two existing outfalls; modifications to these existing outfalls would therefore not be required. If the stormwater management features (i.e., a more extensive network of storm sewer and detention basins) selected for a detailed development plan exceed the stormwater flow capacity of the existing outfalls, a new outfall would be proposed to augment the discharge capacity of the existing system. Prior to development of the site, a drainage plan would be prepared to comprehensively address all the surface runoff that would be generated as a result of the proposed Plan, and drainage features to be included in the development of the District. This drainage plan would accommodate the City's current drainage plan for the area (Plan No. 295⁵), and easements associated with highway drainage. Since a separate stormwater collection system is proposed, the amended drainage plan would be consistent with City policies for reducing stormwater inputs to combined sewers as a means of preserving treatment capacity at the treatment plants. As such, stormwater collected in the District would be managed so as not to increase the occurrence of CSOs (see the discussion above).

The proposed Plan would require coverage under the current State Pollutant Discharge Elimination System (SPDES) general permit program for discharges from construction activities. Prior to the initiation of construction activities, a Stormwater Pollution Prevention Plan (SWPPP) would be developed pursuant to the requirements of the general permit and would be enforced throughout the sequence of construction activities. Since Flushing Bay is a regulated water body, the implementation of sustainable design features would be required to ensure that applicable discharge criteria would be met after construction is completed. These actions would ensure that pollution prevention measures are in place during and after construction activity and enable adequate control of potential sources of pollution relating to stormwater management. Provided these improvements are incorporated in the proposed Plan, no significant impacts (e.g., street flooding) would occur, and conditions would greatly improve. The proposed Plan would include raising the overall grade to meet the 100-year floodplain elevation and would allow for a completely new stormwater system to be designed and connected to the existing outfalls. Elements of that system would be such that outflow would meet both flow and quality criteria of the existing outfalls.

F. THE NO CONVENTION CENTER SCENARIO

WATER SUPPLY

In the No Convention Center Scenario, the additional residential and retail use would increase the water supply demand by 0.08 mgd above the demand required by the proposed Plan and would require a total water supply increase of 4.44 mgd for the Plan and the anticipated development on Lot B. This demand level is 2.25 times the anticipated demand from the District without the proposed Plan; however, it is within the available capacity limits of the existing 72-inch

Willets Point Development Plan

transmission main and can be provided without upgrade. This incremental demand increase—approximately 0.37 percent of the City’s total current average daily water demand of 1.2 billion gpd—would not overburden the City’s water supply system, nor would it be large enough to significantly impact it. A minimal water demand above these calculated values would be required on a seasonal basis for landscaping; however, it is anticipated that some portion of the landscaping demand may be met through recycled water that would be collected in stormwater runoff tanks. A summary of the future projected demand calculations for the No Convention Center Scenario is presented in Table 14-7.

**Table 14-7
Projected Water Usage for No Convention Center Scenario**

Proposed Use	Flow Rate		Sq. Ft. Redevelopment Area			Water Consumption (gpd)		
	Type	gpd/sf	Willets Point	Lot B	Total	Willets Point	Lot B	Total
Residential	Domestic	0.40	5,500,000	0	5,500,000	2,340,000	0	234,0000
	Air Conditioning	0.17				994,500	0	994,500
Retail	Domestic	0.17	1,700,000	184,500	1,884,500	297,500	31,365	328,865
	Air Conditioning	0.17				297,500	31,365	328,865
Commercial/Office	Domestic	0.10	500,000	280,000	780,000	50,000	28,000	78,000
	Air Conditioning	0.10				50,000	28,000	78,000
Hotel	Domestic	0.1875	560,000	0	560,000	105,000	0	105,000
	Air Conditioning	0.17				95,200	0	95,200
Convention Center	Domestic	0.17	400,000	0	400,000	0	0	0
	Air Conditioning	0.17				0	0	0
School	Domestic	0.20	130,000	0	130,000	25,500	0	25,500
	Air Conditioning	0.10				13,000	0	13,000
Community Facility	Domestic	0.17	150,000	0	150,000	25,500	0	25,500
	Air Conditioning	0.17				25,500	0	25,500
Proposed Plan and Lot B (sq. ft.)			8,910,000	464,500	9,374,500			
Water Consumption Subtotals (gpd)						Domestic	59,365	2,902,865
						Air Conditioning	59,365	1,535,065
Total Water Consumption (gpd)						4,437,930		
<p>The following assumptions were made: <i>Residential: Assumes 400 gpd per unit^a and 1000 sf per unit, which equates to 0.40 gpd/sf. Assumes 112 gpd/person.</i> <i>Retail: Assumes 0.17 gpd/sf^a.</i> <i>Commercial/Office: Assumes 0.10 gpd/sf^a and 25 gpd/person^b, which equates to 1 person per 250 sf.</i> <i>Hotel: Assumes 150 gpd per room^b and 800 sf per room, which equates to 0.1875 gpd/sf.</i> <i>School: Assumes 30 gpd/seat^b and approximately 850 seats, (153 sq ft per seat for 130,000 sq ft total area) which equates to 0.20 gpd/sq. ft. (Assumes no boarding)</i> <i>Community Facility: Assumes water usage and sewage generation rates for Retail/Public Use.</i></p> <p>Source: <i>a: 3L-2 Table in the CEQR Technical Manual for Water Consumption and Sewage Generation Rates</i> <i>b: Table 3 in the NYSDEC Design Standards for Wastewater Treatment Works (1998) for Water Consumption and Sewage Generation Rates</i></p>								

SANITARY SEWAGE

In the No Convention Center Scenario with the anticipated development on Lot B, the sanitary wastewater rate would be approximately 2.9 mgd or less than 2 percent of the Bowery Bay WPCP total capacity, 0.1 mgd greater than with the proposed Plan and Lot B. The projected sanitary sewage generation rates are summarized in Table 14-8. As described above in Section D, “The Future Without the Proposed Plan,” the projected available capacity at the Bowery Bay WPCP in 2017 is 28 mgd. The sanitary wastewater generated by the No Convention Center Scenario is 2.9 gpd, or 10.4 percent of the Bowery Bay WPCP capacity that is projected as being available at Bowery Bay in the 2017 Build year. Therefore, there would be no significant impact on the Bowery Bay WPCP.

Table 14-8
Conceptual Wastewater Flow Rate Generation Based on the
No Convention Center Scenario

Proposed Use	Domestic Sewage Generation Rate (gpd/sf)	Sq. Ft. Redevelopment Area			Sewage Generation (gpd)		
		Willetts Point	Lot B	Total	Willetts Point	Lot B	Total
Residential	0.40	5,850,000	0	5,850,000	2,340,000	0	2340000
Retail	0.17	1,750,000	184,500	1,934,500	297,500	31,365	328865
Commercial/Office	0.10	500,000	280,000	780,000	50,000	28,000	78000
Hotel	0.1875	560,000	0	560,000	105,000	0	105000
Convention Center	0.17	0	0	0	0	0	0
School	6	130,000	0	130,000	25,500	0	25500
Community Facility	0.17	150,000	0	150,000	25,500	0	25500
Subtotals		8,910,000	464,500	9,374,500	2,843,500	59,365	2,902,865
Total Sewage Generation (gpd)					2,902,865		
<p>The following assumptions were made: <i>Residential: Assumes 400 gpd per unit^a and 1000 sf per unit, which equates to 0.40 gpd/sf. Assumes 112 gpd/person.</i> <i>Retail: Assumes 0.17 gpd/sf^a.</i> <i>Commercial/Office: Assumes 0.10 gpd/sf^a and 25 gpd/person^b, which equates to 1 person per 250 sf.</i> <i>Hotel: Assumes 150 gpd per room^b and 800 sf per room, which equates to 0.1875 gpd/sf.</i> <i>School: Assumes 30 gpd/seat^b and approximately 850 seats, (153 sq ft per seat for 130,000 sq ft total area) which equates to 0.20 gpd/sq. ft. (Assumes no boarding)</i> <i>Community Facility: Assumes water usage and sewage generation rates for Retail/Public Use.</i></p> <p>Source: <i>a: 3L-2 Table in the CEQR Technical Manual for Water Consumption and Sewage Generation Rates</i> <i>b: Table 3 in the NYSDEC Design Standards for Wastewater Treatment Works (1998) for Water Consumption and Sewage Generation Rates</i></p>							

Since the increase in sanitary flow could impact CSO discharges, the effect of an increase in sanitary flow to the combined sewer on 108th Street was investigated using the current Bowery Bay WPCP CSO model. The Bowery Bay collection system was modeled using Wallingford Software’s InfoWorks model. The purpose of the modeling analysis was to quantify potential changes in CSO conditions with the proposed Plan. Modeling simulations were performed for the projected annual sanitary wastewater rate of 2.9 mgd, using 2006 rainfall and tide data. Based upon model simulation results of conditions with the proposed Plan, the total CSO discharge would increase by less than 1 percent (0.79 percent) in the system. The largest increase in discharge would occur at Outfall BB-008 (see Figure 14-2).

The effect of average flow was investigated by simulating average dry weather flow for existing conditions. The results of these simulations showed that there would be no significant increase in sanitary sewage overflows.

As shown in Table 14-8, the flow increases associated with the No Convention Center scenario are within the capacity of the Bowery Bay WPCP; however, the existing 37th Avenue Pump Station has no extra capacity to accommodate these increases. Therefore, a new private sanitary (dry flow) pump station and force main would be required in the District to transmit sanitary wastewater from the District to the Bowery Bay WPCP. The incorporation of these features into the drainage plan for the District would prevent significant adverse impacts.

Table 14-9
**2006 CSO Discharges - Existing Conditions and Proposed Conditions for
the No Convention Center Scenario**

Outfall	Existing (MG)	Proposed (MG)	Increase (MG)	% Increase (MG)
BB-002	575.26	583.79	8.53	1.48%
BB-003	75.95	76.02	0.07	0.09%
BB-005	1,231.5	1,246.12	14.62	1.19%
BB-005 (24th Ave)	870.78	872.58	1.8	0.21%
BB-006L	414.78	414.80	0.02	0.00%
BB-006U	1,412.02	1,414.35	2.33	0.17%
BB-007	11.94	12.02	0.08	0.67%
BB-008	535.37	552.64	17.27	3.23%
BB-041	130.47	130.88	0.41	0.31%
TI-010	453.61	453.61	0	0.00%
Total CSO	5,711.68	5,756.81	45.13	0.79%
WPCP	26,143.09	27,008.38	865.29	3.31%
Grand Total	31,854.77	32,765.19	910.42	2.86%

STORMWATER

In the No Convention Center Scenario, stormwater runoff generation rates would be essentially equivalent to the proposed Plan. Stormwater drainage from the District would be conveyed to Flushing Bay through storm drains, with the ultimate discharge point at the 126th Street and 127th Street outfalls or a proposed outfall.

As with the proposed Plan, it is anticipated that detention would be required to manage stormwater runoff being discharged to these existing two outfalls. Provided these improvements are incorporated into the detailed design, no significant impacts would occur. *