

1 RCNY §3616-02

CHAPTER 3600

Appendices

§3616-02 National Fire Protection Association (“NFPA”) 13 amendment relating to closets and pantries.

Pursuant to Section 28-103.19 of the New York City Administrative Code, Section 8.14.8.2 of reference standard NFPA 13 is hereby deleted and a new section 8.14.8.2 is added, to read as follows:

8.14.8.2* Closets and Pantries. Sprinklers are not required in clothes closets, linen closets, and pantries within:

- (1) Dwelling units in hotels and motels where the area of the closet or pantry does not exceed 24 ft² (2.2 m²), the least dimension does not exceed 3 ft (0.9 m), and the walls and ceilings are surfaced with noncombustible or limited-combustible materials: and
- (2) Dwelling units in Group R occupancies other than hotels and motels where the area of the closet or pantry does not exceed 12 ft² (1.1 m²), the room or space upon which the closet or pantry opens is equipped with sprinklers designed to afford protection to the opening of the closet or pantry, and the walls and ceilings of the closet or pantry are surfaced with noncombustible or limited-combustible materials.