

1 RCNY §3616-05

CHAPTER 3600

Appendices

§3616-05 National Fire Protection Association (“NFPA”) 13R amendment relating to exemption from Fire Department connection requirements in one- and two-family residential buildings.

Pursuant to Section 28-103.19 of the New York City Administrative Code, paragraph 6.6.4 of NFPA 13R-02, as modified by Section Q104.1 of the New York City Building Code, is amended by adding language at the end of the paragraph to read as follows:

Exception: Fire department connection is not required for installations in one and two-family dwellings.