

NYC Buildings Department 280 Broadway, New York, NY 10007

Robert D. LiMandri, Commissioner

SUPERSEDED BY: BUILDINGS BULLETIN 2013-004, DATED MARCH 25, 2013



BUILDINGS BULLETIN 2012-005

Supersedes: Buildings Bulletin 2010-026 dated October 28, 2010

Issuer: Alan Price, P.E.

Director, Office of Technical Certification and Research

Issuance Date: April 6, 2012

Purpose: This document establishes acceptance criteria for gas-fired direct vent space-heating

appliances used for providing heat in rooms for sleeping purposes in accordance with the 2008

804.1

NYC Construction Codes.

Related Code AC 28
Section(s): FGC 30

AC 28-113.2.3

FGC 503.8

FGC 303.3 FGC 503.4.2 FGC 691,8 FGG 503.2.2

Subject(s): Space-heating appliance, gas-fired, direct went; Space-heating appliance, sleeping room; Gas-

fired heater, direct vent, sealed combustion; Carbon)monoxide detectors, sleeping rooms.

Background: Section FGC 303.3, exception (1) prohibits the location of gas-fired direct vent appliances in

rooms for sleeping purposes. However, such appliances installed in accordance with this

bylletin shall be deemed to be located outside of the sleeping room.

Description: Gas-fired direct vent space-heating appliances for use in rooms for sleeping purposes consist

of automatic gas burner, gas pressure regulator and different controls with or without cooling

section, and shall be constructed as a sealed combustion chamber.

Evaluation Scope: 2008 NXC Construction Codes

Evaluation Pursuant to section AC 28-113, the Office of Technical Certification and Research recognizes gas-**Criteria:** fired direct vent space-heating appliances tested, designed and evaluated in accordance with ANSI

Z21.86 "Gas-Fired Vented Space Heating Appliances." when used to provide heat in sleeping rooms. Acceptable gas-fired direct vent space-heating appliance shall be listed and labeled by an

approved agency in accordance with section AC 28-113.2.3.

Uses: Gas-fired direct vent space-heating appliances are used for providing heat in an interior

environment. This bulletin addresses the use of such appliances in rooms for sleeping purposes.

Conditions of Gas-fired direct vent space-heating appliances used for providing heat in sleeping rooms shall be **Acceptance**: designed and installed in accordance with the 2008 NYC Construction Codes and other applicable

provisions including but not limited to the following:

Buildings Bulletin 2012-005

build safe live safe

A. Design

- 1. The unit shall be specified in accordance with manufacturer's recommendations, the applicable listing, and the conditions of this bulletin.
- 2. The unit shall be factory assembled.
- 3. The unit shall be of direct vent type, that all air for combustion is derived from the outside atmosphere and that all flue gases are discharged directly to the outside atmosphere.
- 4. No retrofitting or on-site duct work is permitted in association with the unit.
- 5. All gas piping shall be hard-piped with no flexible connectors.
- 6. The unit shall be installed through a sleeve located in an exterior wall.

All gas-fired direct vent space heating appliances used for providing heat in sleeping rooms and installed or replaced pursuant to a work permit issued on or after September 30, 2013 shall be manufactured with an integral factory assembled carbon monoxide detector interlook with automatic main gas shut-off valve.

Exceptions for installation or replacement pursuant to a work permit issued prior to September 30, 2013:

- a. In buildings constructed pursuant to the 2008 Code, gas fired direct vent space-heating appliances installed or replaced shall, in lieu of an integral factory assembled carbon monoxide detector interlock be monitored by carbon monoxide detectors installed in sleeping rooms as required by section BC 908.7. Such appliances shall be deemed to be located outside of the sleeping room notwithstanding section EGC 303.3, Exception 1.
- b. In buildings constructed pursuant to the 1968 code or prior codes, gas-fired direct vent space heating appliances installed or replaced shall be in accordance with the conditions of this builtetin, except that a carbon monoxide alarm complying with 1 RCNY \$28-02 may be installed within the sleeping room in lieu of an integral factory assembled carbon monoxide detector interlock. Such appliances shall be deemed to be located outside of the sleeping room notwithstanding 1 RCNY §40-11 (b).

B. Installation Requirements

- 1. Installation requirements shall be in accordance with the manufacturer's instructions, the applicable listing and the conditions of this bulletin.
- 2. Gas-fixed direct verit space-heating appliances, including those for use in rooms for sleeping purposes, shall only be installed by a master licensed plumber.
- A licensed master plumber shall file for a permit with an "LAA 1" or a "PW1" application.
- . The unit shall be installed with natural gas only.
- 5. Clearances from adjacent combustible surfaces shall meet the minimum clearances indicated by the manufacturer's instruction and the listing agency.
- Clearances from adjacent openings shall meet the minimum clearances indicated by the manufacturer's instructions and the listing agency.
- 7. Gas fired direct vent space-heating appliances for use in rooms for sleeping purposes shall be labeled as per section AC 28-113.4. All shipment and deliveries of materials shall be accompanied by a label certifying the material shipped or delivered are equivalent to those tested and approved.

C. Maintenance

Gas-fired direct vent space-heating appliances, carbon monoxide detectors installed in sleeping rooms pursuant to 1 RCNY §28-02 or section BC 908.7, and integral factory assembled carbon monoxide detectors shall be maintained in accordance with the manufactures instructions and the conditions of their listing.

Referenced 1. ANSI Z21.86-1998 "Gas-Fired Vented Space Heating Appliances" **Standards:**

Buildings Bulletin 2012-005 2 of 2