



CONSTRUCTION CODES UPDATE PAGES

Attached are Construction Codes Update Pages. These pages reflect local laws enacted and ministerial administrative corrections made after July 1, 2008. Please note that the source of a particular update, the local law number, and year is indicated on each page. Please visit our [webpage](#) to ensure that your codes are complete and up to date as the City Council may periodically pass Local Laws that affect the Construction Codes.

Instructions:

Please place each page, according to its page number found on the bottom right hand corner, into your Construction Codes books. The pages contain letters after the page number and should be placed in alphabetical order following the number, i.e. 5, 6, 6a, 6b, etc.

- Place Title Pages in the front of your Code books for easy reference.
- Note: If you have all four Construction Codes (Building, Mechanical, Plumbing & Fuel Gas), please make sure to insert updates made to the Administrative Provisions into each of the four Code books.

CONSTRUCTION CODES UPDATE PAGES

UPDATE # 25

Source: Local Law 59 of 2009, effective September 3, 2009.

This update includes the following pages:

BUILDING CODE	
<u>Section</u>	<u>Page Number</u>
3310.8.1.1	616b

CONSTRUCTION CODES UPDATE PAGE

Matter in plain text is unchanged. Matter underlined is new. Matter ~~stricken through~~ is deleted.
Source: Local Law 59 of 2009, effective September 3, 2009.

BUILDING CODE

Insert between pages 616a and 617 of your bound volumes.

Add the following new section 3310.8.1.1:

3310.8.1.1 Site safety manager or coordinator standpipe inspection responsibilities.

The site safety manager or coordinator shall, at a minimum, in accordance with rules promulgated by the department, conduct daily checks to ensure that a standpipe system is available and in a state of readiness at all times for use by fire fighting personnel, by verifying:

1. That valves are in place at each story below the construction floor;
2. That standpipes are connected to a water source or siamese connection; and
3. That siamese hose connections are free from obstruction and are marked by a red light and sign that reads, "Standpipe Siamese Connection."

The site safety manager or coordinator shall also, in accordance with such rules, conduct weekly checks to verify that no breach exists by visually tracing the standpipe, including risers, cross connections and siamese connections. A record of all such inspections shall be maintained by such site safety manager or coordinator in a log book.