



CONSTRUCTION CODES UPDATE PAGES

Attached are Construction Codes Update Pages. These pages reflect local laws enacted and ministerial administrative corrections made after July 1, 2008. Please note that the source of a particular update, the local law number, and year is indicated on each page. Please visit our [webpage](#) to ensure that your codes are complete and up to date as the City Council may periodically pass Local Laws that affect the Construction Codes.

Instructions:

Please place each page, according to its page number found on the bottom right hand corner, into your Construction Codes books. The pages contain letters after the page number and should be placed in alphabetical order following the number, i.e. 5, 6, 6a, 6b, etc.

- Place Title Pages in the front of your Code books for easy reference.
- Note: If you have all four Construction Codes (Building, Mechanical, Plumbing & Fuel Gas), please make sure to insert updates made to the Administrative Provisions into each of the four Code books.

CONSTRUCTION CODES UPDATE PAGES

UPDATE # 47

Source: Local Law 55 of 2010, effective July 1, 2012.

This update includes the following pages:

PLUMBING CODE	
<u>Section</u>	<u>Page Number</u>
410.1-410.3	26a

CONSTRUCTION CODES UPDATE PAGE

Matter in plain text is unchanged. Matter underlined is new. Matter ~~stricken through~~ is deleted.

Source: Local Law 55 of 2010, effective July 1, 2012.

PLUMBING CODE

Insert between pages 26 and 27 of your bound volume.

Amend sections 410.1 and 410.2 and add a new section 410.3, to read as follows:

410.1 Approval. Drinking fountains shall conform to ASME A112.19.1M, ASME A112.19.2M or ASME A112.19.9M, and water coolers shall conform to ARI 1010. Drinking fountains and water coolers shall conform to NSF 61, Section 9. ~~Where water is served in restaurants, drinking fountains shall not be required. In other occupancies, where drinking fountains are required, bottled water dispensers shall be permitted to be substituted for not more than 50 percent of the required drinking fountains.~~ Drinking fountains required by Table 403.1 shall be equipped with both a bubbler faucet for drinking and a separate faucet designed for filling a container at least 10 inches (254 mm) in height.

~~**410.2 Prohibited location.** Drinking fountains shall not be installed in public restrooms.~~ **Required drinking fountains.** Where water is served in restaurants, drinking fountains shall not be required. In other occupancies, where drinking fountains are required, up to 50 percent of required drinking fountains conforming to Section 410.1 may be substituted by dedicated plumbing fixtures with faucets designed for filling a container at least 10 inches (254 mm) in height. Bottled water dispensers shall not be substituted for required drinking fountains.

410.3 Prohibited location. Drinking fountains and plumbing fixtures with faucets permitted to be substituted for required drinking fountains shall not be installed in public restrooms.