

# ADVISORY BOARD CALENDAR

**January 7, 2009**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Jaros Baum & Bolles Consulting Engs 80 Pine Street New York NY 10005	Requesting permission to install 120 type "FF" led 24 volt high power submersible fixtures that will be powered by ground fault protected 277 volt circuits that will feed step-down transformers to light up 2 fountains.	National 9/11 Memorial World Trade Center New York NY	Approved	\$0.00
		Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requesting permission to install a 30 amp 220 volt branch circuit and 220 volt receptacle in lieu of the required 20 amp 110 volt branch circuit due to a single unit combination washer/dryer being installed in a 36" x 36" closet.	339 East 91st Street New York NY	Approved	\$0.00
With the stipulation that receptacle outlet required in Section 210.52(H) is installed in close proximity of the washer/dryer closet.						
		Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requesting permission to install a 30 amp 220 volt branch circuit and 220 volt receptacle in lieu of the required 20 amp 110 volt branch circuit due to a single unit combination washer/dryer being installed in a 36" x 36" closet.	Courtlandt Corners #1 and 2 356 and 361 East 161st Street Bronx NY	Approved	\$0.00
With the stipulation that receptacle outlet required in Section 210.52(H) is installed in close proximity of the washer/dryer closet.						
		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission the re-route an existing 5KV feeder and install a new chiller controller without filing Advisory Board drawings.	New York Presbyterian Hospital Millstein Chiller Room New York NY	Approved	\$0.00
		RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requesting permission to leave as installed due to lack of space inside of the service room, a new service switch installed in the adjacent room where signage will be provided indicating where the other service is located.	600 Gates Avenue Brooklyn NY	Approved	\$350.00

# ADVISORY BOARD CALENDAR

**January 7, 2009**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Paul Verardi, Licensed Electrician 176 Canal Street Staten Island NY 10304	Requesting permission due to lack of space inside of the service room to leave as installed a new 600 amp service switch with a front clearance of 34 3/4 inches to the end box.	23 East 67th Street New York NY	Approved	\$0.00
		Sal Electric Service 71-21 Roosevelt Avenue Jackson Heights NY 11372	Requesting permission due to a hardship to replace to leave as installed AC cable that does not contain an insulated grounding conductor as a wiring method in a place of assembly	2316 Bruckner Boulevard Bronx NY	Approved	\$350.00
With the stipulation that all non metallic sheathed cable is removed.						
		Atkinson Koven Feinberg Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission on an existing 1000 KVA service switchboard where the switches are independently fed with multiple sets of conductors to remove a 1200 amp fire pump service switch fused at 3000 amps located in a single section and replace it with a new remote 3000 amp service switch and to allow the feed to be taken from the line bus of the old 1200 switch due to the bus on the load side of the CT having no available lug space to tap.	235 West 48th Street New York NY	Approved	\$0.00
		Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requesting permission to leave as installed approximately 235 fluorescent fixtures wired without ballast devices	1250 Waters Place Bronx NY	Approved	\$0.00
Carry over from December 10, 2008 meeting.						
		Z & Z Electric Inc. 2380-82 Hughes Avenue Bronx NY 10458	Requesting permission to install underground service lateral conductors in non-metallic conduit.	141-33 78th Avenue Queens NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**January 7, 2009**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	08A0603CO	C.M.S. Electrical Services Co., Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Equity Office Properties 717 5th Avenue New York NY	Denied	\$0.00
Carry over from December 10, 2008 meeting. 1) Fire pump service switch must be upgraded to the correct size and must be located remote from the service switchboard. 2) The branch circuit to the fire pump controller must be fire rated on the line and load sides of the automatic transfer switch.						
	08A0609CO	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Gotham Center-Building B2 42-09 28th Street Long Island City NY	Approved	\$0.00
Carry over from December 10, 2008 meeting.						
	08A0625CO	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tallman Island, WPCP 127-01 Powells Cove Boulevard College Point NY	Hold	\$0.00
Carry over from December 10, 2008 meeting. 1) submittal not complete provide generator information. 2) Provide ATS switches, generator layout drawings. 3) Special permission needed for not providing full selectivity and state that there is not life safety equipment.						
	09A0001	School Construction Authority 30-30 Thomson Avenue Long Island City NY 11101	Requested concept approval of electrical room layout for a 1000 KVA service.	PS264 88-18 4th Avenue Brooklyn NY	Approved	\$0.00
With the stipulation that the sketch of proposal #2 is used for the room layout and the double doors shall comply with the sketch proposal #1.						
	09A0002	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Jones Lang LaSalle 1285 6th Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 7, 2009**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	09A0003	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Barclays 27-01 Queens Plaza North Queens NY	Approved	\$650.00
1) Equipment grounding conductors do not comply with Table 250.122 . 2) Tap conductors feeding 30 amp cut outs are undersized. 3) Are cut outs for fire alarm? Job finalized 2/18/09.						
	09A0004	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	9 East 36th Street New York NY	Denied	\$650.00
Service room layout does not comply with requirements of Article 110.26, extremely hazardous condition.						
	09A0005	Blue Ribbon Electrical Contractors Inc. 500 Smith Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Nederlander Theatre 208 West 41st Street New York NY	Rejected	\$650.00
1) Equipment grounding conductors for service entrance and feeder conductors do not comply with tables 250.66 and 250.122. 2) Verify rating of existing service switch #2. 3) Provide signage at each service location indicating where the other service is located. 4) Size SS#6 at 600% FLA (400A switch ok) fire pump below grade. Job finalized 7/9/09. 3/1/17 - 1) Comply section 110.26 (A)(3) & (E) for ss#6. Identify the front side. 2) Comply section 230.64 (B) for ss#5. 5 ft clear working space required. 3) Provide couple room layout with all wall & doors. 4) ss#6 is overfused for 70a rectifier						
	09A0006	Jolt Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	524 West 19th Street New York NY	Approved	\$650.00
Explain why a 2nd door can't be installed for the service room. Job finalized 6/2/09.						
	09A0007	Campisano Electric, Inc. 355 Food Center Drive Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	Baldor Specialty Foods 155 Food Center Drive Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 7, 2009**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	09A0008	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	New Utrecht High School 1601 80th Street Brooklyn NY	Denied	\$650.00
1) Verify if feeders are copper or aluminum conductors. 2) Feeders are undersized to panels "EMDB", "ADB", MDB-B and MDB-C-D. 3) Show neutral link in existing switchgear. 4) Show ground connections in existing switchgear. 5) Provide size of bus bar jumpers in panel ADB. 6) Show coordination between 1200 A4BY to 400 TR. 2/29/12- 1) Explain how existing aluminum conductors changed to copper. 2) Fire pump circuit tap taken from switchboard section that contains overcurrent protective devices. 3) Feeder to panel MDB-A overfused. 4) Tap to panelboard section undersized. 5) Location of sprinkler booster pump not shown.						
	09A0009	Jeminis Electrical Contractors, Inc. 18-01 120th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	130 Green Street Brooklyn NY	Approved	\$650.00
1) Verify if feeder conductors are copper or aluminum. 2) 400 amp fuses to be A2D. Job finalized 2/18/09.						
	09A0010	Cogen Electrical Services, Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	14 Penn Plaza New York NY	Hold	\$650.00
1) Show clearance measurements in the service room. 2) Add second means of egress to service room. 3) Switchboard "C", block off side of switchgear. 4) 3 sets of 500 MCM fused at 2000 amps. 5) Show bonding and grounding of existing service switch and CT. 6) Room "A" 5' clearance needed in front of service switch. 7) How do you get from service A to A3 ?						
	09A0011	Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	NY Public Library 31-11 Thomson Avenue Long Island City NY	Approved	\$650.00
	09A0012	Major Electric Inc. 41-30 37th Street Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	Essex Berry Street, LLC 70 Berry Street Brooklyn NY	Approved	\$650.00
Coordinate fuses in distribution "H" switch #4. Job finalized February 18, 2009.						

# ADVISORY BOARD CALENDAR

**January 7, 2009**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	09A0013	C.M. Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Joachim & Anne Nursing Home 2720 Surf Avenue Brooklyn NY	Approved	\$650.00
1) Provide FACO on emergency side. 2) CGSB-verify bus size between CT and 800 amp switch. 3) Confirm that fuel cell neutral is grounded. Job finalized 2/20/09.						
	09A0014	Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	NY Public Library-Astor Center 476 Fifth Avenue New York NY	Approval	\$650.00
	09A0015	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Lexington House Hotel 517 Lexington Avenue New York NY	Approved	\$650.00
1) Provide rating of ATS. 2) Adjust circuit current settings from 720 to 1200. Job finalized 2/18/09.						
	09A0016	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	West 44th Street Hotel 306 West 44th Street New York NY	Approved	\$650.00
1) Verify the number of service entrance conductors. 2) 1600 amp switch to be ground fault protected. 3) Provide drawing of the end box location and clearances. 4) Show diagram of the encased service entrance conductors. 5) Verify transfer in rush current does not exceed closing rating of primary switch 1250 KVA and 750 KVA( service A & B). 6) Emergency feed to fire pump must be fire rated. 7) Provide minimum 24" clearance behind MS-B to column. Job finalized 2/18/09.						
	09A0017	Department of Environmental Protection 96-05 Horace Harding Expressway Corona NY 11368	Requested concept approval	Oakwood Beach WPCP 751 Mill Road Staten Island NY	Denied	\$0.00
Status changed April 22, 2010. The drawings submitted are not complete, a detailed site plan was not provided showing the service busway lengths which are limited to ten foot lengths each. Documentation and drawings were not provided indicating compliance with Section 240.21(c)(4). Service busway, and transition details and manufacturer's cut sheet were not provided.						

# ADVISORY BOARD CALENDAR

**January 7, 2009**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	09A0018	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	10 Monroe Street New York NY	Denied	\$650.00
1) The Transtector equipment is not a listed product. 2) Tap conductor to 30 amp disconnect switch is undersized. 3) The tap conductor does not show where it originates from.						
	09A0019	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	500 19th Street Brooklyn NY	Denied	\$650.00
1) The Transtector equipment is not a listed product. 2) Conductors are over fused 3) AIC not provided. 4) Documentation was not provided why the frame of the 200 amp disconnect switch is being bonded.						
	09A0020	Aventura Electrical Services 235-07 Braddock Avenue Queens Village NY 11428	Requested approval for the electric service equipment proposed to be installed	Ritz Plaza 235 West 48th Street New York NY	Approved	\$650.00