

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
54980	16A0601CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55572	18A0001	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination between "2000A" main and "800A" downstream cb in "DSB-3" switchboard and ss#2 2500A fuse and downstream breakers in 'DSB' sign and seal by P.E. 2) Get "NRTL" listing for existing "Gallagher swbd" with modification in ss#1 section and keep on site for inspection review. 3) Provide GFCI to new 2000A Br in 'DSB-3'. 4) Verify DLO cable ampacity use 75 degree "c" rating. 9/6/18 1) Provide DLO cable cut sheet showing ampacity. 2) Item #2 not addressed-verify NRTL listing to existing SWBD with new modification. 9/18/18 1) Provide ground fault protection and not indication to transformer secondary OCPD. 2) DLO cables should be used at 75 degree C ampacity rating or provide documents for listing of equipment based on 90 degree C.. 11/19/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55060	18A0002	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply with Section 695.4(B)(3)(4)-Provide 12" separation. 2) Fix typo of main switchboard in floor plan. 3) Physical doesn't match one line. 2/8/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/18/19 Swap Dwg # ME97-OLRL 1 of 2 Rev 2 and ME97-EQ 2 of 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55061	18A0003	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Rating of Eaton PRLC swbd is undersized. 2/8/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54990	18A0006	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0007	Special Permission	Denied	\$350.00
55125	18A0010	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide Jockey Pump Tap Length. 3/5/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54981	18A0011	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/4/19 Swap Dwg # FP20 1 of 1 Rev-1 and AB20 1 of 1 Rev-1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55057	18A0012	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide Asbestos Abatement Compliance document 2/8/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55044	18A0017	Special Permission	Approved	\$0.00
1) Provide signage that the maximum fuse to be used inside the 4000 amp service switch is 2000 amp including the type. 2) Provide Time Current Curves demonstration coordination between the 2000 amp service fuses and all downstream distribution fuses. 2/5/18 - With stipulation of signage that the max fuse to be used inside the 4000A S.SW is 2000A including the type. Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0018	Special Permission	On Hold	\$350.00
Provide photographs and dimensions for the whole mechanical room/space outside the electrical service space.				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55468	18A0019	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Emergency conductor for SB-SW-E undersized. 2) Verify compliance with JP tap rule (length). 3) Verify # of sets of incoming service 4 sets or 10 sets. 4) Show neutral continuation in ss#2. 5) Provide coordination study signed and sealed by P.E. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/2/18 1) Remove bonding from "SB-SW-E" &amp; "FA-SW-E" with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Item #1 is not addressed. 9/4/18 1) The provided coordination study is not complete. Please provide coordination between ss# 2 &amp; 3 and all downstream breakers. 9/17/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/20/19 Swap dwg #1 of 4 and 3 of 4-Revision 3 and dwg 2 of 4 and 4 of 4-Revision 1.</p>				
55133	18A0020	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify &amp; show that all fuses are "inkind" (one-to-one) replacement. Verify that no addition of load. 2/28/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54975	18A0025	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54985	18A0026	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55340	18A0027	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Existing conductor for "DP-B" switchboard is undersize 3/30/18 - 1) Provide coordination between "1200A KMH-C" fuse (SS# 2) with downstream existing fuses in "DP-B" panel & new "400A FRN" fuse sign & seal by P.E. 5/10/18 Verify 1200A fuse is KMH or KRPC. 6/22/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55048	18A0029	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Room layout does not match physical for fuse size in DC #2. 2/1/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/8/2021 Amended dwgs# A & B Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55049	18A0030	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify control no. on ACP.5 form & note on drawing doesn't match. 2) Provide bus size feeding new sw. s in swb-w-4 and swb-w-3. Location of 500KVA transformer block accessibility of existing swbd-5. 4) Doors to swing outwards. 2/1/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/29/18 - swap dwg 1,2,3,4 of 4 Rev 2 8/2/18 - swap dwg AB-A.3 & D.3. 11/1/18 1) Tap cond feeds 'HDP-WIA' is undersized. 2) Verify that new 800A switch, "HDP-P4" , "HDP-W3A" and "DP-W4A" in floor plans are 3rd level of OCPD-Dwg 1 of 4 of 2 of 4. 2/1/19 1) Provide coordination between new 600A breaker & upstream fuse in "W-1" switchboard and between New KRPC fuses in "SWB-E-2" & upstream fuse. 3/29/19 Swap dwg 1 of 4 rev 5 and dwg 3 of 4 rev 4.				
54986	18A0032	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/28/2020 Swap dwg #A & B-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55155	18A0033	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify location of swdb-2 (show in electrical room). 2) Clarify number of sets verses wires. 3) Provide jockey pump tap length. 4) Verify that Jockey Pump tap not from f.p. controller. 3/8/18 - Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/23/2020 Amended Plans D1 & D2 Rev-2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55052	18A0034	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination between 1200A A4BY and upstream fuse KRPC 2500A. 2) FACP fire alarm tap should be ahead of ssw(verify tap location) 3) Verify FACP double grounded 2/7/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements..				
55051	18A0035	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Asbestos abatement compliance document required. 2/7/18 Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/6/18 Swap dwg #1-Revision 1.				
54997	18A0036	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Provide asbestos abatement compliance documents. 2) Provide coordination bet "2000A ss#1" & "400A" downstream breaker sign & sealed by P.E. 1/23/18 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/2/18 Provide updated TCC for 2000A ss#1 and 400A downstream breaker signed and sealed by P.E. 6/5/18 - swap dwg # 1 Rev 1				
55043	18A0037	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Tap conductors are undersized 2) Equipment grounding conds are undersized 2/2/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
54977	18A0038	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/19/18-Swap Dwg #1 of 1				
55136	18A0039	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance required documents. 2) Provide coordination between new 400A FRN fuse and upstream fuse. 2/27/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/30/18 - swap dwg # P1 Rev 2				
55138	18A0040	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance required document. 2) Drawings is not legible. 2/27/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55021	18A0041	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide asbestos abatement compliance required documents 1/26/18 Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55127	18A0042	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Comply 110.26 and provide 3' (ft) working clearance in front of SEB. 3/5/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/6/18 - 1) Provide 'store - 1' panel cut sheet & service rating doc. 9/19/18 Swap dwg #A.3.. 10/31/18 Swap dwg #A.4				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
54973	18A0043	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/19/18 Swap dwg 2-Revision 1. 6/3/2021 Amended Dwgs# 1 & 2 Rev 2 .Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
54979	18A0044	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55137	18A0045	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance required documents. 2/27/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55209	18A0046	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify fire pump horsepower 25 or 40 on one line. 2) Sectional bus in main switchboard A, Section B is undersized. 3) Comply with 230.64(B)(4) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4) Verify if generator is a SDS (separately derived system). 5) Confirm that MI directly termination doesn't void the NRTL listing to the lugs. 2/26/18 - Item # 5 not addressed 4/3/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/20/19 Swap Dwg # D-1708-29309-C Rev 11. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55360	18A0052	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify number of set for normal conductors for "ATS-E3-12A". ATS cutsheet doesn't have enough lugs for cable termination. 2) Verify medium voltage conductors from all unit substation transformer and provide cutsheet with temp rating. 3) Provide fuse coordination between "1200A KRP.C" fuse sign and seal by P.E. 4) Show bus sizes in 8 generator paralleling switchboard "DP-GEN." 5) Remove bonding from generator paralleling switchboard. Multiple bonding on generator and paralleling switchboard or provide GF sensing relay system. 6) Verify number of set for normal conductor for "ATS-E1-12A", "ATS-E2-12A", "ATS-E2-12B" and "ATS-E3-12B". 7) Verify "ATS-E2-C1" rating. Cutsheet rating doesn't match with one line. 8) Change door swing for 29th floor electrical room to open out in the direction of egress. 9) Show load bank conductor size from generator paralleling switchgear with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10) Any pipe above the switchboard required drip pan to protect switchboard. 4/25/18 - 1) Item # 7 not addressed dwg # Y. 7/3/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/9/2023 Amended Plan # A3 Rev- 4, B Rev- 8, C Rev- 7, D Rev- 6, E Rev- 4, F Rev- 4, G Rev- 4, M Rev- 6, X Rev- 6, and Y Rev- 8, Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55134	18A0053	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify supplemental ground connection for ss#4D and ss#5D. 2) Update typo for ss#5D on one-line diagram. 3) Ground conductor undersize betw transformer secondary and secondary OCPD. 4) Comply Section 230.64(B) (1) and provide 5'(ft) working clearances. 2/28/18 - job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/22/18 Swap dwgs B and C-Revision 2. 1/26/2023 Amended Plan # B Rev-3 and # C Rev-4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54978	18A0058	Special Permission	Approved	\$0.00
<p>Approved with stipulation that electrical installation &amp; inspection shall be in accordance with 2014 NEC Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54982	18A0059	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				



# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55344	18A0060	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show existing ss#3 size, rating, type, designation on one-line. 2) Existing FA ss# & new ss# has same ss#5 designation. 3) Supplemental ground conductor from new ss#5 to building steel is undersize. 4/27/18 - 1) Provide coordination between 400A TR fuse & upstream 800A breaker (SSW # 3) & to be signed & sealed by P.E.. 6/26/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54976	18A0061	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54974	18A0062	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/21/18 Swap dwg A & B, Revision 1.				
55313	18A0064	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination bet 4000A ss#1B and downstream 3000A KRPC fuse sign and seal by P.E. 2) Provide fence for authorized personal access only. 3) Provide barrier at left side (rear) of "New temp switchboard" to prevent the access for rear side. 4) Verify that temp switchboard is in 2 hr. fr room. 5/1/18 -- Item # 2 & 4 not addressed - You may apply for special permission 5/30/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/5/18 Swap dwg D-Revision 2.				
55292	18A0065	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify existing cond. connected to f.p. s.sw is 2 hr fire rated-695.6(B)(1). 2) Provide 5' clearance in front of ss. #5-Section 230.64(B)(1) and 7' in front of ss#1 swbd 'A' 3) Provide coordination between 4000A s.sw.#1 and downstream KRPC 3000A and 7000A KRPC s.s #5 and downstream fuses. 5/17/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/1/19 Swap Dwg # A & C Rev- 5 and # B Rev-3. 7/25/19 Swap Dwg # D-1712-29751-A Rev 6 and Dwg # D-1712-29751-B Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
54998	18A0066	Special Permission	Approved	\$0.00
With stipulation that both electric meters are installed on the outside of 9 Jade Court, and identify the loads they are serving. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55045	18A0067	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination 3000A fuse or 1200A fuse and downstream breakers. 2) Provide transformer cutter showing NRTL listing. 3) Verify if using PV system and provide cut sheets. If PV is being used verify complying with Con-ED requirements. 2/5/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/3/19 Swap Dwg #ACS-D-13062-Revision 1				
55020	18A0068	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide asbestos abatement compliance required document(Not correct address). 1/26/18 - Address corrected Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/13/2020 Amended dwgs # 1 & 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
54984	18A0069	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/18/2021 Amended Plan# 1 Rev 1 & 2 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
54992	18A0071	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55047	18A0072	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply with 34-05.c(1) EM for mechanical ventilation for electrical service room. 2) Provide asbestos abatement compliance documents. 1/31/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55036	18A0073	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance documents. 2) Provide signage on ss#1 stating "maximum fuse permitted by code is 1600A." 1/31/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/30/18 - swap dwg# ACS-D-13094 Rev 2 8/1/18 - swap dwg # ACS-D-13094 Rev 3. 11/16/18 Swap Dwg Revision 4.				
54991	18A0074	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55164	18A0075	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) F.P. fuse size is undersized see 695.4(B)(1)(1). 2 Conds feed MB #5 & 4 are undersized-310.15(B)(2)(a). 3) Service bus feeds ssw #1, F.A. and F.P. is undersized. 4) Verify fuse size that feed 600A MLO panel BP-1- emergency side. (3rd device) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5) Cover letter is missing license #. 6) Verify MB #4 & 5 size & provide cutsheet. 7) 400A FRN fuse feeds distribution panel 'DP-FSE' is overfused. 3/22/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/7/19 Swap dwg # 1,2, & 3 Rev-4. 8/9/19 1) The tap conductor is undersized from 'BP1-ATS' to 200A disconnect switch. 2) Show connection to ground collector bus at service switches. 11/13/19 Swap Dwg # 1, 2 & 3 Rev-6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/24/2020 Swap dwg 1,2 & 3-Revision 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0076	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Provide asbestos abatement compliance documents 8/22/18. 1) Provide ACP-5 form or control No. Asbestos Abatement compliance document.				
55054	18A0077	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) F.A. taps to be ahead of N.D.L 2/7/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55041	18A0078	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply with 34-05.c(1) EM for mechanical ventilation for electrical service room . 2) Provide asbestos abatement compliance required document. 3) Verify ground of secondary winding. 1/31/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55169	18A0079	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Request special permission for additional service room and service switches are not grouped at one location. 2) Provide supplemental and water main connection for ss#5. 3/22/18- Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54999	18A0080	Special Permission	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0081	Special Permission	Denied	\$0.00

# ADVISORY BOARD CALENDAR

**January 17, 2018**

Approval #	Submission #	Type of Request	Status	Fee
56203	18A0082	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify physical protection (concrete encased) of incoming service conds and provide floor plan and elevation view. 2) Add the Asbestos note to the drawing. 2/16/2021 Job finalized. Approved dwgs# 1,2,3 & 4 Rev 2 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
55122	18A0083	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Update asbestos note on the drawings to match with standard asbestos compliance note from EAB. 2) Grounding from ss#2 (south service) to ground bus undersize comply Section 250.66. 3) Comply Section 700.9(B) and verify that EM & standby load has barrier on "DP-GEN" switchboard. 3/2/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/29/2020 Swap drawings # 1 & 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/6/2020 Amended Plans # 2 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55139	18A0084	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Verify supplemental grounding to F.A. S.SW 2) Asbestos abatement compliance document required 2/28/18 - Item # 1 not addressed 3/7/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/2/18 Swap Dwg # ATL-D-1801052-Revision 2. 3/20/19 Swap dwg #ATL-D-1801052 Rev-3 7/29/2019 1) Correct thecalendar # for existing equipment for 55139 was only approval to few fuses change in the original dwg & not the whole existing job. 2) Keep new equipment was approved under C# 55139 bubbled as it was in original submission. 3) Fire pump conductor is undersized. 9/11/2019 Swap Dwg # ATL-D-1801052 Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/13/19 Swap ATL-D-1801052 Rev 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/21/2020 Swap dwg # ATL-D-1801052-Revision 9. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. No more swaps.				
55135	18A0085	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance documents. 2) Verify & Show N.D.L. for SS # 2 (4000A SS#) 2/28/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				