

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requesting permission to install switchgear behind a steel beam that hangs down 6" and 18" in front of the switchgear	20 Henry Street Brooklyn NY	Approved	\$0.00
		New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission to install replacement elevator feeder conductors inside of the elevator shaftway where the feeder will not contain any splices.	NYCHA St., 154-156 Broome St. and 201 West New York NY	Approved	\$0.00
		B. McCann & Son 40-33 215th Street Bayside NY 11361	Requesting permission to install 450 feet of direct burial cable from the Con Ed property line box to the building	135-02 Springfield Blvd. Queens NY	Denied	\$0.00
		Innovative Electric of New York, Inc. 4351 White Plains Road Bronx NY 10466	Requesting permission to leave as installed AC cable that does not contain an insulated equipment grounding conductor as a wiring method in a place of assembly.	1040 Havemeyer Avenue Bronx NY	Approved	\$350.00
		Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requesting permission to tap power for the fire pump emergency branch circuit on the load side of the generator disconnecting means.	227 East 30th Street New York NY	Denied	\$0.00

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		L.E.A. Electric Corp. 1001 Sixth Avenue, 11th Floor New York NY 10018	Requesting permission to replace one for one defective CT cabinet, service entrance conductors and 1200 amp service switch on a 1000 KVA service without filing a full Advisory Board submission .	136 Madison Avenue New York NY	Denied	\$0.00
		Altman Electric 283 West 11th Street New York NY 10014	Requesting permission to replace 1 for 1 one 400 amp service switch on a 1000 KVA service	300 East 46th Street New York NY	Approved	\$0.00
With the stipulation that the fuses must match.						
		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to utilize UL heat rise testing for the network switchgear	Mt. Sinai 101st Street and Madison Avenue New York NY	Denied	\$0.00
		Market Electric Inc. 2526 50th Street, Suite 201A Woodside NY 1177	Requesting permission to use overcurrent protective devices that would provide selective coordination in the time range at and above 0.1 seconds.	The Hampshire Building 2329 Norstrand Avenue Brooklyn NY	Denied	\$0.00
		A.T.J. Electrical Inc. 33-61 55th Street Woodside NY 11377	Requesting permission to have 3-1200 amp fused switches feed 3-1200 amp fused switches, and 1-400 amp fused switch feed 1-400 amp fused switch without coordination where all 3rd fusions will coordinate, where it will provide additional protection for conductors that will run over 300 feet between buildings.	NYC City Hall 1 City Hall New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
		Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to install approximately 25' of service busways in a fire rated service room	80 Centre Street New York NY	Approved	\$0.00
	10A0263CO2	Hugh O Kane Electric Company, Inc. 90 White Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1221 Sixth Avenue New York NY	Approved	\$0.00
Carry over from October 13, 2010 meeting. Verify if 3 or 4 pole ATS' are being used. Job finalized 5/18/11.						
	10A0324CO	NYMEC 269 37th Street, Suite 200 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Industry City Building 10 882 Third Avenue Brooklyn NY	Approved	\$0.00
Carry over from September 15, 2010 meeting.						
	10A0335CO2	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sky View 40-28 College Point Boulevard Flushing NY	Approved	\$0.00
Carry over from September 15, 2010 meeting. 1) Show 3' clearance around switchboard SB-A. 2) Conductors looped through switches do not show gutter sizes, termination of conductors not shown. Job finalized 2/17/11.						
	10A0365CO	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tallman Island WPCP 127-01 Powells Cove Boulevard College Point NY	Hold	\$0.00
Carry over from October 13, 2010 meeting. 1) 2-1/4"x7" bus undersized on main-tie-main of 480V switchboards at 800 amp Sq". 2) Clarify section on secondary side of transformers. 3) Clarify 480V neutral bonding and grounding. 4) Clarify 480V neutral size construction and location. 5) Clarify 4160V bus duct one line. 6) Verify if 3 line are for 3 phases on 3 feeders. 7) Concrete encase generator feeders. 8) Secondary disconnect switches needs for transformers 300 KVA. 9) Provide grounding grid drawing. 10) Provide 4' clearance around generator switchboard. 11) Are rooms mechanically ventilated 12) 26 KV boards need 6' clearance. 13) Provide cut sheets of transformers.						

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	10A0372CO	Mac Electrical Contractors 8023 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	238 Atlantic Avenue Brooklyn NY	Approved	\$0.00
Carry over from October 13, 2010 meeting.						
50376CO	10A0394CO	A.T.J. Electrical Inc. 122-13 15th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	NYC City Hall 1 City Hall Park New York NY	Approved	\$0.00
Carry over from December 22, 2010 meeting. 5/6/14 Swapped AB-1 of 5, 3 of 5, 5 of 5 SB-1 of 3.						
	10A0400CO	Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Sprint 60 Hudson Street New York NY	Hold	\$0.00
Carry over from December 22, 2010 meeting. 1) Key interlocking scheme not clear. Identify key numbers. 2) Show grounding electrode conductor and neutral disconnect link.						
	10A0403CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Madison Square Garden 4 Penn Plaza New York NY	Hold	\$0.00
Carry over from December 22, 2010 meeting. Provide coordination curves for new generator distribution.						
	10A0433CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt Sinai Center for Science 1470 Madison Avenue New York NY	Hold	\$0.00
Carry over from December 22, 2010 meeting. 1) Remove service grounding in 'MS' switchboards. 2) Show ground fault protection. 3) Resubmit special permission on current density.						

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	10A0456CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Octagon 888 Main Street Roosevelt Island NY	Approved	\$0.00
Carry over from December 22, 2010 meeting. 1) 150 KVA transformer misidentified (1500). 2) Verify whether ATS' are 3 or 4 pole. 3) If ATS' are 3 pole the emergency side neutral cannot be bonded and grounded. Job finalized 3/28/11.						
	11A0001	Quenzer Electric Systems, Inc. 11 West 25th Street, 9th Floor New York NY 10010	Requested approval for the electric service equipment proposed to be installed	30 Flatbush Avenue Brooklyn NY	Approved	\$650.00
	11A0002	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Ventura 240 East 86th Street New York NY	Denied	\$650.00
Advisory submission required for 2nd fusing. Drawings void as per Cal. #50617.						
	11A0003	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	CBS Broadcasting 524 West 57th Street New York NY	Approved	\$650.00
	11A0004	Kramer Electric, LLC 336 West 37th Street, Suite 510 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	The Puck Building 295 Lafayette Street New York NY	Approved	\$650.00
Provide lengths of tapped conductors. Job finalized 9/22/11.						

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	11A0005	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NYU 32 Washington Place New York NY	Approved	\$650.00
50479	11A0006	Shorr Electrical Contracting, Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's Herald Square 151 West 34th Street New York NY	Approved	\$650.00
1) Verify that service room is mechanically ventilated. 2) Grounding electrode conductor and supplemental ground to terminate to new 4000 amp service switch. 3/17/17 - 1) Verify new ss# 6 & distribution switchboard have tamper resistance screw on the rear side of the switchboard. 3/20/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	11A0007	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	St. Patrick's Cathedral Rectory 460 Madison Avenue New York NY	Ok, but	\$650.00
1) Fire pump branch circuit not fire rated. 2) Equipment grounding conductors undersized. 3) Fire pump tap cannot be in switch section. Tap in S.E.B. w/new meter.						
	11A0008	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	315 West 70th Street New York NY	Ok, but	\$650.00
1) Verify if 2/0 copper conductor is a EGC. 2) EGC undersized on load side of transformer.						
	11A0009	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Trinity Real Estate 100 Avenue of the Americas New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	11A0010	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	727 5th Avenue New York NY	Approved	\$650.00
50484	11A0011	FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	490 Fulton Street Brooklyn NY	Approved	\$650.00
11/25/13 Swapped Rev 3.						
	11A0012	GB Legend Electrical Contrs Corp. 496 Greenwich Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	40 West 57th Street New York NY	Approved	\$650.00
	11A0013	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Trader Joe's 2385 Richmond Avenue Staten Island NY	Approved	\$650.00
	11A0014	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	650 Madison Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	11A0015	Crana Electric Inc. 600A East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Pier A 22 Battery Place New York NY	Approved	\$650.00
<p>1) Grounding electrode conductor to terminate in 800 amp service switch. 2) Install grounding electrode conductor in new 800A service switch. Job finalized 2/23/11.</p>						
	11A0016	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	440 West 15th Street New York NY	Approved	\$650.00
<p>1) 4000 amp fuse requires 800 MCM AL EGC's. 2) Provide GF indication at generator board. 3) How are 5 sets of 750 MCM terminated to ATS #3? 4) Provide tap lengths to EHSW-C-L2-1 and -2. Job finalized 5/2/11.</p>						
	11A0017	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Barclays Center Arena 620 Atlantic Avenue Brooklyn NY	Approved	\$650.00
<p>Requested Concept Approval:</p>						
	11A0018	Senon Associates, Inc. 255 Old New Brunswick Road Piscataway NJ 08854	Requested Concept Approval:	S. Bklyn Marine Terminal 30th Street Pier Brooklyn NY	Approved	\$0.00
<p>With the stipulation that the following items must be corrected and resubmitted for final approval: 1) Provide primary disconnect on MDS-I and MDS-II transformers w/key Intlk with secondary breaker. 2) Confirm NRTL certification on 6000A main breakers in MDS-I and II. 3) No neutral continuity on single-ended operation. No neutral conductor in tie. 4) Comply with 250.32 for grounding. 5) Full Advisory Board drawings must be submitted for approval. 6) Advisory Board submittals to be folded in 8"x11" sizes.</p>						
	11A0019	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	201 East 21st Street New York NY	Approved	\$650.00
<p>1) Is transformer room mechanically ventilated? 2) 44 conductors not allowed in service trough. 3) Verify service entrance conductors to 800 amp service switch. Job finalized 6/16/12.</p>						

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	11A0020	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 227 East 30th Street New York NY	Denied	\$650.00
1) The tapped conductors are undersized. 2) The fire pump tap on the normal side is made in the same switchboard section containing a switch. 3) Does the automatic switch feed life safety? 4) The emergency taps to the fire alarm and fire pump are not fed from the line side of the disconnect switch.						
50494	11A0021	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	Lower East Side Girls Club 101 Avenue D New York NY	Approved	\$650.00
1) Show lengths of tapped conductor to panel "PPF1". 2) Equipment grounding conductor undersized to FP service switch. 3) FP feed cannot be tapped from cubicle that contains fused switch. 4) Bus in panel undersized ( PPF1 and MGCP, SSW-3). 5) Explain note for trough and tap details. Job finalized 2/12/13.						
	11A0022	Scott Electrical Service, LLC 40 Macon Street Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	41-18 Crescent Street Queens NY	Approved	\$650.00
Verify conductor bending radius of conductors terminated to 1200 amp switches. Job finalized 2/28/11.						
	11A0023	Twins Electric Corporation 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	The Nomad Hotel 1170 Broadway New York NY	Approved	\$650.00
1) Generator neutral to be bonded and grounded, generator frame not grounded. 2) Feeder to switchboard MDB-EM-1 undersized. 3) 2000 amp switch is backwards. 4) Emergency circuit to FP not fire rated. Job finalized 2/23/11.						
	11A0024	T & R Alarm & Electric Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	636 Broadway New York NY	Ok, but	\$650.00
1) Tapped conductor undersized. 2) Short circuit calculations not provided. 3) AIC not provided						

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	11A0025	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU 333 East 38th Street New York NY	Approved	\$650.00
	11A0026	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Hospital for Special Surgery 176-60 Union Turnpike Fresh Meadows NY	Approved	\$650.00
Clarify voltage of panel. Job finalized 3/1/11.						
	11A0027	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Skyview Park 40-28 College Point Blvd. Flushing NY	Hold	\$650.00
1) What is the length of the transformers secondary conductors to the 800 amp panel? 2) Where is the new panel located?						
	11A0028	Total Power Distribution Electl Contg Inc. 1107 43rd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	3339 Park Avenue Bronx NY	Denied	\$650.00
1) The fire alarm switch on the emergency side is not in Advisory Board format. 2) The fire alarm conductors are not shown. 3) The service entrance conductors to 4000 amp switch not shown. 4) The bus size of 4000 amp switch not shown. 5) The bus feeding the distribution panel is undersized. 6) Conductor to ATS not shown. 7) Verify size of generator 1 line does not match cut sheet.						
	11A0029	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	8 West 40th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	11A0030	Broadway Electric, LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	27 North 6th Street Brooklyn NY	Approved	\$650.00
	11A0031	Positive Electrical Associates Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYC School Construction Auth. 44-24 Vernon Blvd. Long Island City NY	Approved	\$650.00
	11A0032	GB Legend Electrical Contrs Corp. 496 Greenwich Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	40 West 57th Street New York NY	Approved	\$650.00
	11A0033	Guiding Light Electric 5015 Avenue D Brooklyn NY 11203	Requested approval for the electric service equipment proposed to be installed	810 Humbolt Street Brooklyn NY	Approved	\$650.00
Show trough tap detail. Job finalized 2/4/11.						
	11A0034	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weil Cornell Med Research Bldg 413 East 69th Street New York NY	Approved	\$650.00
1) Verify that switchboard has now removable rear covers or is hinged.. 2) 1600A service switch has to have GF(not GFI). Job finalized 2/23/11.						

# ADVISORY BOARD CALENDAR

**January 19, 2011**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	11A0035	Control Spec Electrical Systems, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	500 East 77th Street New York NY	Approved	\$650.00
	11A0036	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	NYU-Langone Med Ctr, 550 First Avenue New York NY	Denied	\$650.00
The new switches must have ground fault protection						
	11A0037	Radionic Hi Tech, Inc. 6625 W. Diversey Chicago IL 60707	Requested approval for use in New York City of your LED Exit Sign Retrofit Kit. Model Series Numbers: ZXE5000		Approved	\$200.00