

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55748	18A0699CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1/17/19 - Add stipulation that the listing documentation of the 5KV distribution switch gear "co gen switch gear" is to be kept on site for inspector's review. 1/23/19 - 1. Confirm sensing and protection on IGARD NGR. 2. Clarify that the 90 degree C rating of the gear is not being compromised with the 105 degree C cable rating. 3/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55693	18A0732CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1) Item #3 from last revision is partially addressed. Please confirm GFP not GFI. 2/4/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/14/2023 Amended plans # 1 &amp; 2 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/11/2023 Amended plans # 1 &amp; 2 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55883	18A0737CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from November 14, 2018 meeting. 1) Explain access to horizontal busbars for switchboards maintenance/thermoscaring-Item #1 last revision. 2) Explain what is covering existing Con-ED transfer-if metallic covering confirm bonding and grounding as well as the metallic fence. 3) Confirm generator location-provide site plan. 4) Item #4-not addressed provide cut sheet of generator I.e. technical data. 5) Item #6 not addressed. 6) Confirm NRTL listing to next gen switchgear. 2/19/2019 1) Site plan was not attached as mentioned in last revision. 2) Provide coordination &amp; short circuit study. 3) Nex gear bus bar are undersized - 700 A/in<sup>2</sup> density shall be used - 40B.60E (exception). 4) Show grounding neutral for SDS Generators. 5) Show metal graded &amp; show properly grounded &amp; bounded. 6) Show how will you maintain the ATS. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/3/19 This drawing is approved</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/1/2021 Amended plans# 1 Rev 4, 2 Rev 0, 3 Rev 4, 4 Rev 4, 5 Rev 5 and 6 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0787CO2	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>) Explain access to horizontal busbars for switchboard maintenance/thermoscaring-Item #1 last revision. 2) Explain what is covering existing Con-ED transfer If Metallic covering confirm bonding &amp; grounding as well as the metallic fence. 3) Confirm generator location-provide site plan. 4) Item #4-Not addressed provide- Cut sheet of generator I.e. technical data. 5) Item #6 not addressed. 6) Confirm NRTL listing to next gen swgr.</p>				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
	19A0001	Requesting SP to replace 92 panel boards with compromised/ blocked equipment work clearance	Denied	\$0.00
No legal egress has been provided.				
55672	19A0002	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55879	19A0003	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1/28/19 - 1. Provide coordination between new 400A FRS-R and upstream fuse signed and sealed by P.E. 2. Provide asbestos abatement compliance doc. 5/1/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55663	19A0004	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55861	19A0005	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Submit coordination study with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Remove double bonding at transformer and secondary switch 3) Verify number of conductors at fire alarm disconnect and ATS. Is FACP 3 phase or single phase? 4/25/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/7/2021 1 of 3 Rev 2, 2 of 3 Rev 2, 3 of 3 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/26/2023 Amended plans # 1 Rev 3, 2 &amp; 3 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/6/2023 Amended plans # 1 Rev 4, 2 Rev 2, 3 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55783	19A0006	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1/28/19 - 1. Provided asbestos abatement compliance doc. Doesn't include EAB project address.. 3/6/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	19A0008	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>) Address on ACP form doesn't match project address-lot is different. 6/7/19 - 1. Show generator in one line dwg, if new 2. Provide available SC current at FP controller 3. Confirm that new area of work is included in provided asbestos document</p>				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
	19A0011	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1. Confirm that the MV90 rating of the MV cables is being used when entering and exiting MV switchgear. 2. Connect busbar in "SS-PH2-SC1A1" feeds "SS-PH2-SC1B1" to main busbar. 3. XFmrs secondary neutral to be bonded and grounded in "SS-6B-SC1A1" and "SS-6B-SC1B1". 4. Provide scheme to prevent access to live conductors in rear compartment of main 13.8KV breakers for safe grounding of cables. 5. Confirm if location of RC snubber is correct. Should be on primary of transformer. 6. Short circuit study is preliminary and needs to be updated in accordance with the engineer's comments. 7. Confirm all key interlocks meet all OSHA and Con Edison safety requirements. 8. Confirm that busbars in LV swgr are in accordance with 408.60. 9. Provide second egress door for rooms SC300-MR3 and MR4. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
55890	19A0014	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Verify that incoming 10 sets of 500MCM are Con-Ed cables and provide the AIC rating of service switchboard. 4/23/19 1) Incoming service conductor from P.O.E to be concrete encased. 5/7/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/21/19 Swap Dwg # 16362 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55699	19A0015	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR-1. Provide available S.C current &amp; AIC rating of the new equipment. 2. Fix typo of existing switchboard designation-one line doesn't match floor plan. 2/6/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/21/2020 Amended Dwg# 1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55715	19A0017	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Provide coordination between 400A FLSR and upstream 1200A A413 Y fuses signed and sealed by P.E. 2/5/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/16/2023 Amended Plan # 1 of 1 Rev- 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55749	19A0020	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Fix typo for 750KVA transformer. 2. Verify bonding and grounding to existing fp transformer. 3. One line dwg doesn't match floor plan or physical. 4. Verify if new distr. Swbd 'M' and 'A & B' on 3rd level of OCPDs. 5. Verify supplemental grounding in new service switch "SW13". 3/1/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/17/2021 Amended Plan# B Rev 4 & C Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
	19A0021	Requesting SP to replace 92 panel boards with compromised/ blocked equipment work clearance	Denied	\$0.00
	19A0022	Requesting SP to replace 92 panel boards with compromised/ blocked equipment work clearance	Denied	\$0.00

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55803	19A0023	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Sectional bus in "RDB" switchboard section #2 is undersized. 2. Provide cond. Size feeding distribution from generator. 3. Comply with 230.64(B)(3). With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 3/26/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/12/2020 Amended Plan #A Rev-3, &amp; A1 Rev- 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/22/2021 Amended Plan # A Rev- 5 and # A1 Rev- 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55659	19A0024	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55972	19A0025	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with 700.10(D)(1). 2) Provide Asbestos compliance document. 3/7/19 1) Item #2 is not addressed. 2) Confirm that limited service fire pump is located above street level.. 6/6/19 Job finalized .Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55669	19A0026	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/10/19 Swap Dwgs D, C -rev 1.				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55674	19A0027	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/30/31 Amended dwgs # 1 & 2 Rev 1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55681	19A0028	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55949	19A0029	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide ground fault protection to 2000A switch-230.95. 2) Confirm that incoming 4 sets of 500KCMIL are Con ED cables. 3) Correct note regards service voltage in general notes. 4) Comply with 408.36 for "GRD" panel. 5) Provide bonding and grounding to all service switches and fence. 6) Verify filing for battery storage system equipment approval within the building department. 4/12/19 1) Provide ground fault protection (GFP) and not sensing. 2) Bring neutral to service switches and provide bonding and grounding -system shall be grounded. 5/24/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/19/2020 1) Confirm conductor size to lithium - ion battery. 690.8(A)(4) and (B)(1). 2/26/2020. 1) Confirm compliance with 110.14.14C for using DC cables with 90 degree Celsius rating ampacity. 2) Confirm using the conductors in free air. 3) Comply with 690.8(B)(1) - D.C. conductor is undersized. 4/15/2020 Amended Plan # B.5 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs..				
55947	19A0030	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply with 230.95- provide GFP to new 2000A switch. 2) Confirm that incoming 4 sets of 500 MDM conductors are Con-ED. 3) Correct note regards service voltage in general notes. 4) Comply with 408.36 for "GRD" panel 5) Provide bonding and grounding to all service switches and fencing. 6) Verify approval filing for battery storage system equipment. 4/12/19 1) Provide ground fault protection (GFP) and not sensing. 2) Bring neutral to service switches and provide bonding and grounding -system shall be grounded. 5/24/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/19/19 Swap dwgs 1 and 2-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55716	19A0031	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1. Provided asbestos compliance document doesn't include the project address 2/12/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/17/2021 Amended dwg# 1 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
	19A0032	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/31/19 1) The conductor feeding 600A fuse is undersized and the conductor feeding two 400A is undersized. 2) Clearly state and mark all changes from the originally approved Dwg # AB-19358-A.0 3) Comply with 110.2(B)				
55755	19A0034	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
With stipulation to use 2014 NEC for solar installation. 1. Provide available SC current at new equipment.. 2/27/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/23/19 Swap Dwgs 16 of 16 rev 5 and AB-A&B rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55754	19A0035	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
With stipulation to use 2014 NEC for solar installation. 1. Provide available SC current at new equipment.. 2/15/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/23/19 Swap Dwgs 16 of 16 rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/10/2020 Amended dwgs # 1 & 2 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55660	19A0037	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/20/2021 Amended Plan# A & B Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 4/7/2022 Amended plans # A & B Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55901	19A0039	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
O.R. - 1. Verify that new incoming 10 sets 500 MCM are Con-Ed Conductors. 2. Confirm complying with 250.53 (D)(2) 5/13/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/26/2021 Amended Plan # D Rev-1 & E Rev-2.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55781	19A0040	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1- Provide asbestos abatement compliance required documents. 2- Slide DP- cellar eq south to clear the column. 3/6/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/30/19 Swap dwgs B-Revision 3; dwg C-Revision 2; dwg D-Revision 2 and Dwg E-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/31/2020 Amended Dwgs# C , D, & E Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/29/2021 Amended Plan # D & E Rev- 4.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55767	19A0041	ReAmended Dwgs # B Rev 3 requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Service busbar feeding ss#1 and fire pump is undersized. 2) Physical doesn't match one line-Sections #6 & 7. 3/7/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/13/20 Amended Dwgs # B Rev 3; C Rev 1 and D Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/2/2022 Amended Approved Plan# B Rev-6, # C Rev-2 and # D Rev- 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55769	19A0042	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provided Asbestos Compliance document doesn't include the project address. 3/1/19 1) Conductor off 1200A sw and feeds 400 KVA XFmr is undersized.. 3/11/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55664	19A0044	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/1/2021 Amended plans# A Rev 2, A1 Rev 1, B Rev 5, C Rev 9 and D Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 11/02/2021 Amended Plans# A Re 2, A1 Rev 1, B Rev 5, C Rev 9 and D Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55762	19A0047	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR-1)3 sets of 600MCM between sections in NEWTA-DPH-6A(OD) board 2)Existing ground fault is ground fault protection not just sensing as per 230.95 3)Verify the supplemental grounding to existing service. 3/7/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/18/2020 Amended dwg # C Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55766	19A0049	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Provide signage to indicate existing 3000A switch to be closed before the new 300 A sw. 3/7/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55661	19A0065	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.                      Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/2/19 Swap dwg #ACS-D-13388-1 and 2-Revision 1. 5/5/2022 Amended Plan # 1 Rev_1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55662	19A0066	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55776	19A0067	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination between 600A FRN and upstream 1600A KRPC fuses. 2/27/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/12/2020 Swap drawings # 1 &amp; 2 Rev # 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 11/16/2020 Amended Plan # 1&amp;2 Rev-3.                      Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55665	19A0068	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/12/2020 Amended Dwgs # 1 &amp; 2 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/13/2020 Amended dwgs # 1 &amp; 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/27/2021 Amended dwgs # 1 &amp; 2 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55666	19A0069	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/22/2021 Amended Plan # 1 Rev- 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/22/2022 Amended Plan# Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55765	19A0070	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1. Confirm that locatoins of the new work within the bldg are included under provided control no. 3/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/20/19 - Swap dwg #1 Rev-1. 6/17/2022 Amended Plan # 1 Rev-2. Contractor name change. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55759	19A0071	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1. Provide coordination between new 800A A4BQ SS#5 and downstream fuse 400A TR signed and sealed by P.E. 3/6/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/11/19 Swap Dwg no. ACS-D-13465-1 Rev.2 12/11/19 Swap Dwg # ACS-D-13465-1 rev.3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55810	19A0072	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1. Tap conductor feeds 30A disc. SW is undersized 4/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55809	19A0073	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1. Tap conductor feeds 30A disc SW is undersized. 2. Provide asbestos abatement compliance doc. 4/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55752	19A0074	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Verify metering to FA. 2. Verify if service switchboards are rear accessible -- if yes, provide tamper proof -- sec 408.60(F). 3. Provide cover letter includes license #. 3/5/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/15/19 Swap dwg #E.1A & 2B-Revision-2. E.2A, 2B-Revision 1 and E.3-Revision-1. 5/1/19 - Swap dwg # E.1A & E.1B rev-3.				
55751	19A0076	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1/28/19 - 1. Provide coordination between new 2000A KRPC fuse and upstream fuse signed and sealed by P.E. 3/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
	19A0077	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Provide GFP to secondary OCPD of new 750KVA transformer-215.10. 2) Provide coordination between 600A TR fuse and upstream 2500A breaker in gen switchboard, signed and sealed by P.E. 3) Confirm that MDB-A is 3rd level of OCPD. 4) Provide new reduced neutral calculation for PP-8A. 5) Platform to be modified and additional rizers are required required-provide railing for fall protection. 3/8/19 1) Comply with 408.36 for new "gen.dist. Pnl" panel and provide main OCPD. 2) Cond feeds new "Gen dist pnl" is undersized. 3) Confirm that ground fault protection is provided to secondary OCPD of 750KVA transformer and not ground fault indication. 4) Item #5 is partially addressed. 5) Provide coordination between new 1200A A4BQ and upstream 2500A breaker.				
55682	19A0078	Requesting a SP for ungrouped Service Switches	Approved	\$350.00
with stipulation that signage shall be provided at both electric service rooms.				
55675	19A0079	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
	19A0080	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1. Provide coordination between HDB-1, HDB-A-2, PP-7B, PP-5B, HDB-B-1 with their upstream devices. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 2/5/19 1) Tap Conductors feed "PP-5B", &amp;"PP-7B"-sec 240.21(B)(2) 2) Provide coordination between A4BQ 2000A &amp; downstream 600 TRs &amp; provide short circuit study to all equipment. 6/1/2023 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
56066	19A0081	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Provide asbestos abatement compliace doc. 7/30/19 1) New Conds feed existing dist. Panel #1 are undersized. 8/21/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55870	19A0082	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Asbestos Abatement Compliance document. 2) Confirm a NRTL field evaluation will be provided on new installation within existing switchboard. 4/25/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55667	19A0083	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/15/2020 Amendedn Dwg Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**January 23, 2019**

Approval #	Submission #	Type of Request	Status	Fee
55668	19A0086	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/6/19 Swap Dwgs 1&2 rev 2. 11/21/19 Swaps dwgs 1 and 2-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55780	19A0088	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1. Provide available sc current at the new panel. 3/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55892	19A0089	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide bonding and grounding to new 800A service switch 2) GEC & EGC to conductors connected to 400A switch are undersized. 3) Provide cut sheets to equipment showing NRTL listing. 4) Provide signage indicating location of transformer secondary disconnect (solar application). 3/6/19 1) Item #2 is not addressed and item #3 is partially addressed. 5/7/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0091	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1. New work needs to be bubbled. 2. Provide physical and EQ cut sheets for board, ats, and gen. Sets. 3. Provide floor plans. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/1/19 1) Verify trip size of OCPD in new paralleling switchgear. 2) Confirm compliance with 517.17 in new outdoor substation "KCC-EM-dist." 3) Provide coordination study signed and sealed by P.E. 4) Item #3 from last revision is partially addressed-provide floor plan for "KCC-EM-dist" switchgear.				