

# ADVISORY BOARD CALENDAR

**January 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
BK00108A3	BK00108	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/27/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 5/17/2022 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 6/17/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/25/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
BK00589A3	BK00589	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/13/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/2/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/3/2023 New cover sheet provided indicating new P.E. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
	BK00655	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>2/26.2021 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 <a href="https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf">https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf</a>:                      The §4000-01 Rule includes but not limited to the following:                      a. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing.                      2. Provide The asbestos abatement compliance document (new building).                      3. Provide the required plans only:                      · The one-line plan,                      · Floor plans for the service room and generator room, the floor plans should be zoomed in, clearly show the equipment clearances and the compliance with article 110. The rest of rooms in the whole site plan should be deleted.                      4. All excess and not necessarily plans and should be removed</p>				

# ADVISORY BOARD CALENDAR

**January 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
BK00665A	BK00665	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/29/2021 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01  <a href="https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf">https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf</a>                      The §4000-01 Rule includes but not limited to the following:                      a. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing.                      2. Provide a clear floor plan for the service room &amp; 1000KVA generator showing the equipment clearance.                      3. Add the coordination statement on the plan.                      4. Provide The asbestos abatement compliance document.. 3/15/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK00780A2	BK00780	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/20/2021 Job finalized Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/13/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
BK00802A1	BK00802	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>8/24/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 5/25/2023 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.                      8/23/2023 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/30/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BX00774A1	BX00774	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/8/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/27/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

# ADVISORY BOARD CALENDAR

**January 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
MN00044A2	MN00044	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
5/20/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 11/29/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/8/2024 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
MN00450A1	MN00450	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/12/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/12/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/7/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00483A	MN00483	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/29/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00640A	MN00640	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/4/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00679A1	MN00679	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/29/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 6/29/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**January 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
MN00710A1	MN00710	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/20/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/2/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00715A1	MN00715	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/6/2021 Job finalized Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00725A3	MN00725	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/1/2021 Job finalized Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/23/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/23/2023 New cover sheet submitted showing new P.E. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
MN00739A	MN00739	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/19/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/11/2022 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00751A1	MN00751	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/16/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**January 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
MN00772A2	MN00772	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/5/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/27/21 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 2/15/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
MN00793A2	MN00793	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/1/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 2/10/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/23/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
MN00800A	MN00800	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/22/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00429A1	QN00429	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/8/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/2/2022 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00635A1	QN00635	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/5/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00702A1	QN00702	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/20/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**January 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
QN00759A2	QN00759	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/20/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/28/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/5/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
QN00806A	QN00806	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/2/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
SI00810A2	SI00810	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/12/2021 Job finalized Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/24/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
SI00811A1	SI00811	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1/29/2021 1. Provide Clear sequence of operation. 2. Provide coordination statement as per NYC 4000-01 rule. 3. Provide size of all new OCPD and conductors. 4. Label all new equipment in the floor plan and clearly show the Clearance for all new equipment. 5. Asbestos note should be signed and sealed by P.E. or added to stamped plans. 6. Clarify the OCPD intersected curves within the coordination study and clarify the compliance with NEC code- provide a coordination summary within the study. 2/25/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
	SI00811	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
2/12/2021 1. Clearly show an equipment lay out (zoomed in) showing and clarifying that clearances are in compliance with 110.26(A)(1) & 110.34 (A) for all new electrical equipment				

# ADVISORY BOARD CALENDAR

**January 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
SI00812A1	SI00812	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/29/2021</p> <ol style="list-style-type: none"> <li>1. Provide Clear sequence of operation.</li> <li>2. Provide coordination statement as per NYC 4000-01 rule.</li> <li>3. Provide size of all new OCPD and conductors.</li> <li>4. Label all new equipment in the floor plan and clearly show the Clearance for all new equipment.</li> <li>5. Asbestos note should be signed and sealed by P.E. or added to stamped plans.</li> <li>6. Clarify the OCPD intersected curves within the coordination study and clarify the compliance with NEC code- provide a coordination summary within the study.</li> </ol> <p>2/12/2021 1. Clearly show an equipment lay out (zoomed in) showing and clarifying that clearances are in compliance with 110.26(A)(1) &amp; 110.34 (A) for all new electrical equipment. 2/25/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				