

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47556CO	06A0561CO	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Pier 88 635 12th Avenue New York NY	Approved	\$0.00
Carry over from December 13, 2006 meeting. Neutral bond for transformer either in disconnect switch or transformer not both. Job finalized 3/22/07.						
47666	07A0049	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Queens Hospital 56-45 Main Street Flushing NY	Approved	\$650.00
47667	07A0050	L.E.A. Electric Corp. 1001 Sixth Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	H.W. Wilson 950 University Avenue Bronx NY	Ok, but	\$650.00
1) Service 'A' & 'B' -tap to be sized for 1200A.. 2) Provide Con-ED S.C. current . 3) Service 'B' -verify adequate bus sizing in existing switchboard.						
47668	07A0051	Megaris Electrical Contracting Corp. 126-12 18th Avenue College NY 11356	Requested approval for the electric service equipment proposed to be installed	190 Allen Street New York NY	Approved	\$650.00
47669	07A0052	Megaris Electrical Contracting Corp. 126-12 18th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	785 Eighth Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47670	07A0053	Megarix Electrical Contracting Corp. 126-12 18th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	120 West 72nd Street New York NY	Approved	\$650.00
47671	07A0054	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	PS/IS 44R 280 Regis Drive Staten Island NY	Approved	\$650.00
47672	07A0055	T & T Electrical Corp. 24-30 47th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	2-30 51st Avenue Long Island City NY	Approved	\$650.00
47673	07A0056	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	PS 829R 98 Grant Street Staten Island NY	Approved	\$650.00
Verify fuse size on primary of 225 KVA XFMR. Job was finalized 3/8/07.						
47674	07A0057	Up Town Electric, Inc. 128-20 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Sephardic Community Center 1901 Ocean Parkway Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47675	07A0058	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	One York Street New York NY	Approved	\$650.00
47676	07A0059	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	215 West 94th Street New York NY	Approved	\$650.00
47677	07A0060	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	1265 Broadway New York NY	Approved	\$650.00
47678	07A0061	G & F.A.ST Electric, Inc. 36-12 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	433 East 100th Street New York NY	Approved	\$650.00
47679	07A0062	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	1510 2nd Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47680	07A0063	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Brooklyn College-West Quad 2900 Bedford Avenue Brooklyn NY	Hold	\$650.00
1) Service room doors to open out w/panic hardware. 2) Fire alarm cutout, change to switch. 3) Bond secondary of transformer for fire alarm system. 4) Water main ground and supplemental ground omitted. 5) Conductor wire size line and load of transformers omitted. 6) Show bus sizing in 'DPM-BA'. 7) Provide hinged DBL doors in rear of rear-access equipment.						
47681	07A0064	Scientific Electric Company, Inc. 1475 East 22nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	San Remo 145-146 Central Park West New York NY	Approved	\$650.00
47682	07A0065	Judd Electric, Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	301 East 69th Street New York NY	Approved	\$650.00
47683	07A0066	Flack + Kurtz Inc. 475 Fifth Avenue New York NY 10017	Request concept approval	The New York Times College Point Facility New York NY	Approved	\$650.00
47684	07A0067	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Barclays Capital (Thor Project) 200 Park Avenue New York NY	Hold	\$650.00
1) 1600/3 switch tapped from swbd "10LB" shown backwards. 2) Provide Advisory format drawings for Asco equipment..						

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47685	07A0068	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	79-14 Rockaway Beach Blvd. Far Rockaway NY	Approved	\$650.00
1) Underground service lateral to 1200 amp service switch is undersized. 2) Show coordination between 800 amp service switches to meter bank circuit breakers. ground not provided. Job finalized 3/26/07.					3) Supplemental	
47686	07A0069	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Nina Footwear 200 Park Avenue South New York NY	Approved	\$650.00
1) Remove neutral bond in new and existing 400 amp service switch. Job finalized 3/22/0.						
47687	07A0070	New York University 10 Astor Place, 6th Floor New York NY 10003	Requested concept approval to install an expanded 13 MW cogeneration electrical distribution system.	NYU Cogeneration Plant New York NY	Approved	\$0.00
47688	06A0508	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	City University of New York Convent Avenue @ 138th Street New York NY	Hold	\$650.00
1) Provide supplemental grounds on both service switches. 2) Provide overlay coordination curves between 2500 Siemens breaker and 3000 Siemens breaker switchboard "A". 3) MSE 2 & 3 overcurrent device to coordinate with 1st fuse.						
47689	07A0071	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	270 Nostrand Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47690	07A0072	Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	One Centre Street New York NY	Hold	\$650.00
1) Provide GF indication on feeder over 1000 amps. 2) Show grounding of transformer. 3) Ground frame of the generator. 4) Drawing submitted, not by Advisory Board rules.						
47691	07A0073	Fas Electrical Contractors, Inc. 90-61 Pitkin Avenue Ozone park NY 11417	Requested approval for the electric service equipment proposed to be installed	Ultra Flex Packaging 975 Essex Street Brooklyn NY	Hold	\$650.00
1) Secondary of new transformer not grounded. 2) Conductor sizes not provided. 3) 1200 amp 480 volt disconnect switch not ground fault protected. 4) Show load side of 1200 amp switch.						
47692	07A0074	Hi-Rite Electric Corp. 1335 61st Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	199 Lafayette Street New York NY	Approved	\$650.00
1) Parallel conductors to 800 amp disconnect switch not the same. 2) Bond neutrals to enclosures in 400 and 200 amp service switches. 3) Show tap details in trough. Job finalized 9/23/08.						
47693	07A0075	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	440 Park Avenue South New York NY	Ok, but	\$650.00
1) Provide supplemental ground. 2) Show coordination between 1200 amp service switch and 1200 amp breaker.						
47694	07A0076	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	The Standard Hotel 844 Washington Street New York NY	Approved	\$650.00
1) Ground frame of generator and show bond's of neutral. 2) Are 3 or 4 pole ATS being used and rating. Job finalized 2/27/06.						

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47695	07A0077	Jay Helfgott Electric Corp. 2970 Fulton Street Brooklyn NY 11208	Requested approval for the electric service equipment proposed to be installed	205 Rockaway Parkway Brooklyn NY	Approved	\$650.00
1) Provide clearer details of tap of fire alarm feeder. 2) Provide tap details in trough's. 3) Clarify 800 amp TR800R fuse. Job finalized 8/25/08.						
47696	07A0078	Fas Electric, Inc. 10 Jefferson Blvd. Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	1479 Beach Channel Drive Far Rockaway NY	Hold	\$650.00
1) Increase conductor sizes feeding 1200 amp service switches. 2) Provided overlay fuse and circuit breaker curves. 3) Show 2nd fusing off of 800 amp service switches. 4) Bond neutrals to enclosures service switches. 5) Remove bond and ground in Con-Ed box. 6) Provide wire size to 800 amp service switches.						
47697	07A0079	z R. Electl Contracting and Repair Service 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	310 Lexington Avenue New York NY	Approved	\$650.00
47698	07A0080	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	675 Morris Avenue Bronx NY	Approved	\$650.00
Verify the number of conductors inside the trough. Job finalized 2/27/07.						
47699	07A0081	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	The Dwyer 258-264 St. Nicholas Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47700	07A0082	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	720 Fifth Avenue New York NY	Approved	\$650.00
47701	07A0083	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Alice Tully Hall/ Juilliard 155 West 65th Street New York NY	Approved	\$650.00
1) Coordinate fuses on bus duct with 2500 and service switch service D. 2) Provide series ratings of circuit breakers DP EM4 and DP EM3 show overlay coordination curves. Job finalized 2/27/07.						
47702	07A0084	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Riverside South Bldg. I 80 Riverside Blvd. New York NY	Approved	\$650.00
Manual fire pump raceway to be fire rated. Job finalized 2/27/07.						
47703	07A0085	Shorr Electrical Contracting Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's 422 Fulton Street Brooklyn NY	Hold	\$650.00
1) Transformer bonds to building steel. 2) Clarify that taps to disc #2 and 3 are within 10'. 3) Remove 200 amp disconnect switch between ATS AWD transformer that feeds the fire alarm system. 4) Special permission is needed to install switch instead of fuse cutout for fire alarm riser. 5) Install step-down transformer on emergency side feeding fire alarm instead of having several transformers or 208 volt side.						
47704	07A0086	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	108 Owners Corp. 300 West 109th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47705	07A0087	B & H Electrical Power & Maint. Co. Inc. 500 Bergen Street Brooklyn NY 11217	Requested approval for the electric service equipment proposed to be installed	NYU Weissman Building 421 First Avenue New York NY	Approved	\$650.00
47706	07A0088	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	CBS 530 West 57th Street New York NY	Approved	\$650.00
47707	07A0089	United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	63-14 Queens Boulevard Rego Park NY	Approved	\$650.00
47708	07A0090	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	47 Flatbush Ave., aka 306 Gold Street Brooklyn NY	Approved	\$650.00
47709	07A0091	Salvatore Campisi & Sons Electl Contrs, Inc 453 Onderdonk Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	460 West 34th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47710	07A0092	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1271 6th Avenue New York NY	Approved	\$650.00
47711	@	KNC Electric Inc. 187-27 Linden Blvd. St. Albans NY 11412	Requesting permission due to a corrosive area, Far Rockaway, Queens to install non metallic Schedule 80 conduit standpipes on four two family buildings	7, 329, 331 and 333 Beach 101st Str Queens NY	Approved	\$0.00
47712	@@	Ambrosino, DePinto & Schmieder Engs. 275 Seventh Avenue, 21st Floor New York NY 10001	Requesting permission to install concrete encased Schedule 80 non metallic conduits from the property line box to the C.T. cabinet	Monroe High School 1301 Monroe Avenue Bronx NY	Approved	\$0.00
With the stipulation that all stub ups and elbows are galvanized.						
47713	@@@	Megariz Electrical Contracting Corp. 126-12 18th Avenue College Point NY 11356	Requesting permission to install service entrance conductors in Schedule 80 non metallic conduit that will be encased in concrete and all stub ups will be galvanized.	785 Eighth Avenue New York NY	Approved	\$0.00
47714	@@@@	Amboy Electric Inc. 6523 Amboy Road Staten Island NY 10216	Requesting permission to install underground service lateral conductors in Schedule 80 non metallic conduit.	2000 Hylan Blvd. Staten Island NY	Approved	\$0.00
With the stipulation that all elbows and stup-ups are galvanized.						

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47715	@@@@@	Police Department 620 Circle Drive, Suite B Fort Totten NY 11359	Requesting permission due to unsatisfactory experience with automatic tap changing transformers to install a standard voltage adjustment transformer where the voltage drop to the most remote outlet is less than 5%.	Central Park Police@86th Trans New York NY	Approved	\$0.00
47716	@@@@@@	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requesting permission to tap power for a 24 hour battery back up fire alarm system from a fused common bus within an emergency switchboard that is fed from redundant generators.	Verizon 221 East 37th Street New York NY	Approved	\$0.00
With the stipulation that the generator is standby and not emergency and the installation is subject to approval by other jurisdictions.						
47717	@@@@@@@	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requesting permission on a project where the kitchen back splash is considered art to install multi-outlet assemblies under them bottom of the kitchen cabinets approximately 24 inches off of the countertops in lieu of wall counter spaces.	Penthouse 4 231 10th Avenue New York NY	Denied	\$0.00
47718	@@@@@@@ @	Fusion Electric Inc. 148-27 Hillside Avenue Jamaica NY 11435	Requesting permission to install a second service outdoors on a one family building that has an existing service switch indoors the new service will provide power for private street lighting.	1-15 Samos Lane Whitestone NY	Approved	\$0.00
47719	@@@@@@@ @@	Hirschel Electrical, Inc. 411 Beach 30th Street Far Rockaway NY 11691	Requesting permission due to the commercial buildings having no common areas to install the service equipment on the outside of 2 buildings.	05 Bch 205th St. & 2002 Cornaga A Queens NY	Approved	\$0.00
With the stipulation that outdoor equipment be installed and protection is installed in front of the equipment from vehicles.						

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47720	@@@@@@@ @@@@	Smith Electrical Contracting Inc. 120 Dobbin Street Brooklyn NY 11222	Requesting permission due to hardship to replace to leave type non metallic cable as a wiring method inside of a 3 family 4 story building.	416 Hancock Street Brooklyn NY	Approved	\$350.00
With the stipulation that the buildings certificate of occupancy reflects that the attic can be used as bedrooms.						
47721	@@@@@@@ @@@@	Smith Electrical Contracting Inc. 120 Dobbin Street Brooklyn NY 11222	Requesting permission to install non metallic sheathed cable inside of a two family 3 story building	2300 Pitkin Avenue Brooklyn NY	Approved	\$0.00
47722	@@@@@@@ @@@@	Smith Electrical Contracting Inc. 120 Dobbin Street Brooklyn NY 11222	Requesting permission to install non metallic sheathed cable inside of a two family 3 story building.	10-32 B 20th Street Far Rockaway NY	Approved	\$0.00
47723	@@@@@@@ @@@@	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requesting permission to leave as installed a outdoor service switch that provides power to a cell site in a building where the existing service is located indoors.	Sprint 1101 Woodrow Rd. Staten Island NY	Approved	\$350.00
With the stipulation that signage is provided as per Article 230.2E.						
47724	>	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requesting permission to install a seventh service switch to power a new sprinkler booster pump.	720 Fifth Avenue New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47725	>>	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval to install a photovoltaic utility grid connected system.	Eric Moynier 54 Garfield Place Brooklyn NY	Approved	\$0.00
47726	>>>	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval to install a photovoltaic utility grid connected system.	Roger Bittenbender 489 Henry Street Brooklyn NY	Approved	\$0.00
47727	>>>>	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval to install a photovoltaic utility grid connected system.	Brian Nelson 196 Clermont Avenue Brooklyn NY	Approved	\$0.00
47728	07A0093	Conservation Technology, Ltd. 2783 Shermer Road Northbrook IL 60002	Requested approval for use in New York City of your Recessed Low Voltage Lighting Fixtures. Model Numbers on separate.		Hold	\$200.00
47729	07A0094	67 Toll Road Holland Landing ON L9N1H	Requested approval for use in New York City of your Storwal Office Furnishings with modular electrical system.		Denied	\$200.00

ADVISORY BOARD CALENDAR

February 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47730	07A0095	Air King 820 Lincoln Avenue West Chester PA 19380	Requested approval for use in New York City of your Exhaust Fan. Model Numbers(s): BFQ50.		Approved	\$200.00
Job finalized 3/14/07.						
47731	07A0096	Air King 820 Lincoln Avenue West Chester PA 19380	Requested approval for use in New York City of your Exhaust Fan. Model Number: FRAS50.		Approved	\$200.00
Job finalized 3/14/07.						
47732	07A0097	Modular International 3941 California Avenue Pittsburgh PA 15212	Requested approval for use in New York City of your Recessed Low Voltage Lighting Fixtures. Model Numbers: MM121-JBX-TL, MM221-JBX-TL, MM321-JBX-TL, MM421-JBX-TL and MM521-JBX-TL.		Approved	\$200.00
47733	07A0098	Smith Environmental Products 9330 Corporate Dr. #510 Selma TX 78154	Requested approval for use of New York City of your Power Quality Improvement/Energy Saving Devices. Model Numbers: CM 201-202-203-204-205-301-302-303-303A-304-305-306-307-308.		Approved	\$200.00