

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
	16A0648CO2	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from November 16, 2016 meeting. Comment #2 on the short circuit study shows 27.8.8K at the 22K AK rated panel. See 110.9 and 240.86. See notes on original short circuit study. Equipment installed prior to EAB approval 110.2(B) not acceptable.				
54377	16A0827CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over of from November 16, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.3/21/2017 - swap "1 of 5" & "5 of 5" dwg with Rev 2 11/20/19 Swap Dwg # 22927AB20-01 of 5 Rev 4, -02 of 5 Rev 3, -03 of 5 Rev 3, -04 of 5 Rev 3, -05 of 5 Rev 3 and Dwg # 22927FP20-01 of 3 Rev 2, -02 of 3 Rev 2, -03 of 3 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
54460	17A0013	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. FP fuse is undersized (over current protection is less than 300% of F LA) 2. Physical & room layout don't match one line. 3. Confirm ss # 5 fuse size. 4. 1200a S.S. and TDP-1 does not coordinate. 2/24/2017- Vertical bus of 1200A SS # 1 is undersized 3/20/17 - 1. Comment not addressed. (Vertical BUS of ssw#1 undersized.3/24/2017 - job finalized . Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/19/18 - Swap dwg # 1 of 2, & 2 of 2 Rev 3				
54367	17A0053	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/25/19 Swap Dwgs 1&2 Rev 1				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54464	17A0054	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>5' clearance required in front of S.S. 3 & 4 east electric service room. 2. Verify location of TVSS & its fusing east switchboard. 3. Line & Load fire pump conductors undersized. 4. Provide not if Generator is existing or new. 5. East & west service boards, are barriers provided on bottom of boards supporting line and load for TVSS and meters 3/23/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/13/18 - Provide coordination between 800A C.B. & downstream fuses. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/29/18 Swap dwg #1,2 and 3-Revision 6</p>				
54745	17A0068	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1.Show length of transformer secondary taps. 2. Equipment grounding conductors undersized. 3. Verify Coordination between 1600 amp ss # 2 to PNC Hvac - 3. 4. Fire pump feeder to be fire rated 695.6 (B) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. This drawing voids out Sub # 12A0257. 6/15/17 1) Comment 3 not addressed coordination between service switch #2 and its downstream fuses is missing in coordination study. 2) F.P. emergency feeder to be fire rated. 3) Conductor off 1200A F.P. service switch feeding 112.5 KVA transformer is undersized. 9/14/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/27/18 - swap dwg 1 of 3 Rev 2. 6/21/18 Swap dwg 1 of 3, Revision 4. 8/14/18 Swap dwg # 1 of 3-Revision 5.</p>				
54597	17A0075	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Tap conductors to 400 amp switch undersized. 2. Length of taps not shown. 3. Show fuse size & types for ARCS & F.A. SS. 4. Show wiring method, conductors, and fire rating to fire pump. 4/11/2017 - 1) Conductor feeding service switch # 4 is undersized. 6/20/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 12/20/17 - 1) Provided TCCs to be signed & sealed by P.E. 2) 800A A4BQ doesn't coordinate with down stream 400A IXD2 C.B. 1/29/18 - Swap dwg with Rev 6</p>				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54608	17A0077	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Tap conductor to 400 amp switch undersized. 2. Length of taps now shown. 3. Show fuse size & type for arcs & F.A. ss. 4. Show size of fire pump feeder, conduit, and fire rating. 4/11/2017 - 1) Comply section 230.42 (A) (2) for ss # 4, FA & ARCS. 2) Comply section 110.26 (c) (3) and provide panic bar hardware for service room egress exit. 6/19/17 1-400A TR does not coordinate with 1200A s.sw #2. 6/28/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/18/17 - 1) Time current curves and coordination needs to be performed, signed & sealed by P.E. 2) Revise coordination between fuse 800A A4BQ & 400A circuit breaker 1/30/18 - 1) Verify SS# 4 fuse is A4BQ or A4BY & revise TCCs 5/15/18 - swap dwg # 1/1 Rev 7</p>				
54453	17A0086	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Show Con ED supply coming in. 3/20/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/25/18 - Swap dwg FP 20-01 of 1 Rev 1</p>				
	17A0094	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1. What switchgear company performed Bus work in the switchgear, removed & installed conductors. 2. Relocated Bus size not shown. 3. Coordination study performed, signed, sealed by a PE not submitted. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/5/18 1) Provided coordination study doesn't include coordination between 2500A KRPC fuse (normal side) and 1600A KRPC fuse [emergency side] with the down stream breakers.</p>				
54368	17A0096	Requesting permission due to lack of space inside of the service room to allow a new 100 amp service switch to be installed on the outside of the building wall where the service switches will not be grouped together, signage will be provided as per Section 230.2(E) of the NYC Electrical Code	Approved	\$0.00
<p>OR With the stipulation that signage is provided at each service indication where the other service is located as per Section 230.2(E) of the NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54356	17A0097	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.3/24/17 - Swap dwg A rev-1				
54363	17A0108	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/12/2023 Amended plans # 1 & 2 of 3 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
54525	17A0110	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Show the ampacity of vertical bus in distribution sections. 2. Provide signage on 4000 amp ss. Room doors to be open when working on this switch. 3. Doors to have panic hardware, with key locks not pad locks. 4. Verify job address on drawing. 5. Show how feeders will run from 28-07 Jackson ave to 42-09 28th Street 4/19/2017 - comment 3 is partially addressed. Second duo is required panic hardware with key lock. 2) verify section bus connection in 1st distribution section. 5/4/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54471	17A0111	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Disk link required for ss # 4. 2. Clearly identify the cable size bet 800 CT fire pump disconnect switch. 3. 2500 amp service = switch reversed 2/24/17 - 1) Disc link to be located downstream of main bonding jumper- 408.60(A) 2) provide base for FP disconnect sw. & FP electrical data. 3) Provide ratings & type of over current devices in existing 400A dist. Panel 3/28/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/21/17 - Provide signage for service switch location on both electrical service room. 2) Comply sec 230.6 for service entrance conductor. 12/21/17 - 1) Comply sec 408.60(A) and provide N.D.L downstream of the main bonding jumper & grounding elevate conductor terminal for SS# 4 12/22/17 - swap dwg with Rev 5				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54913	17A0112	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Neutral in switch Board bonded & grounded on load side of neutral link. 2. Service bus feeding middle section undersized. 3. MI cable feeding fire pump undersized. 4. Show length of taps to elevator disconnect switches. 5. Short Circuit study performed, signed, sealed by a PE not submitted. 6.. Correct typo at fire pump SS. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/16/2017 - 1) Provide large scale of the oe line diagram of the coordination study-readable copy. 2) 004 TCC doesn't match one line page 35 9/27/17 - Item 2 not addressed. 10/25/17 - Verify supplemental grounding to F.A., F.P. & Time Warner S.SW 11/22/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/17/2021 Amended dwg# 2 of 2 Rev 6 . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/21/2021 Amended Plans #1 of 2 Rev-4 and # 2 of 2 Rev-8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/25/2022 Amended Plans #2 of 2 Rev-10. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54357	17A0113	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/29/17 - swap dwg A rev 1				
54353	17A0114	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54354	17A0119	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR-2/6/2017 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54384	17A0120	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/24/18 Swap dwgs 1,2,3, and 4-Revision 1.				
54510	17A0121	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify size of Tran S for FA 4/20/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/3/18 Swap Drawing #FP20-01 of 1. 8/2/18 - swap dwg# AB20-02 Rev 2; SB20-04 Rev 5; FP20-01 Rev 4				
54509	17A0122	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. 4000 AMP service switches to be ground fault protected. 2. Provide the available short circuit at the inverter during charging. 4/20/17 - job finalized. - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54418	17A0123	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Room layout doesn't match one line. 2) Provide fuel cells cut sheet showing listing. 2/28/17 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54358	17A0125	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/20/17 - Swap dwg # 1701192-0 Rev 2				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54458	17A0129	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Cond off ssw # 2 is undersized, 2, coordination study not followed on 1 line drawing items 2,3,&4 page 2 3/24/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/4/17 Swapped drawing with Revision 2. 4/9/19 1) Provide 5' clearance in front of F.A. service switch ss#6 and ss#2. 2) ATS #3 and 5 amperage rating is undersized. 5/6/19 1) Item #1 is not addressed - Provide 7' clearance between SS #2 and SS #6 & 5. 7/1/19 1) Provide neutral disconnect for the 2000A SW#2. 7/8/2019 Swap Dwg No: AB-17189-A.1 Rev-5.				
54360	17A0132	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.6/22/2017 - ok, swap # 2/2 rev 1				
54369	17A0134	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	17A0135	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1. Tapped conductors on load side of SS # 2 undersized 240.2 (B). 2. Clarify all work on load side of top box on load side of SS # 3. 3. Second fusing not shown on load size of SS # 1, & # 4. 4. Conduit sizes from generator to fire pump, fire alarm & Em ATS not shown. 5. Cable undersize from dist. Sec. 1. Boro A. fuse to EMDP ATS. 6. Verify 2 hr fire rating for fire pump feeders. 7. Comply section 215.10. GF protection for 1200 a disc. Switch on secondary side of 1000 kva x'mer. 8. Comply Section 230.71 for max number of service disconnect switch. (Time Warner service switch.) 9. Provide mechanical ventilation in service room. 10. 1000 kva transformer neutral to be bonded and grounded in one location not 2. 1. There are more than 6 service switches not counting FA & FP Sw's. 12. Verify neutral conductors feeding 1000 kva transformer.				
54383	17A0136	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 4/11/2017 - swap dwg 1 & 2 rev 1				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54544	17A0139	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Identify EQ Behind SS # 3 2/24/2017 - Verify that ss #2 is bonded 5/11/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	17A0140	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1. Voltage regulator not listed, or field evaluated by a OSHA recognized testing laboratory. (NRTL)				
54416	17A0141	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Provide cut sheets of fuel cells showing its listing. 2/28/17 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54447	17A0142	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) EMT can't be installed in concrete in contact with the Earth Article 100, and Article 358.10(B) and 358.10(C), 358.12. 2) Conductor type installed in underground EMT not shown on drawing. 3) Does installation comply with Sections 358.10(A), 358.10(B), and 358.10(c)? 3/20/2017- see special permission letter to leave as installed 17a0169 voided,, installation to follow approved drawing. - 3/20/2017-Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54350	17A0143	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54440	17A0144	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply Section 760.41(A) for FACP tap ahead of service switches. 2) Show tap lengths to 1200 and 800 amp disconnect switches. 2/24/17 - 1. Verify that service switch #2 and fire alarm ss is bonded. 2. FACP should feed from dedicated single fuse disconnect switch only 3/14/2017 - job finalized-Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54362	17A0147	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	17A0149	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR 1) Provide 36" clearance in front of transformer. 2) Clarify where is the new 400A switch located in the service room?				
54364	17A0150	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
54439	17A0151	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that service entrance conductors from service end box to new main service switch is concrete encased. 2) Clearly identify the ground conductors and supplemental ground conductor terminals with new 4000A service switches. 3/14/2017 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/28/17 - swap dwg B Rev 2, C Rev 2				
54461	17A0152	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Short circuit curves not provided. 3/27/2017 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/4/19 Swap Dwgs-B & C-Revision #1				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54560	17A0154	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify type of medium voltage cable being installed cut sheet doesn't match 1 Line.1 2/22/17 - Clearly mention the trip setting in "MV-SWG-KP-20-1" & "MV-SWG-KP-20-2" switchgear. 5/23/2017 - 1) Comment 1 not addressed (dwg 1 of 5) 2) F2A feeder in "DESS-PES-KP-20N1" switchboard undersize. Equipment ground conductor undersize for the same feeder (DWG 1 of 5) 3) DWG 1 of 4. Ground conductor doesn't match with dwg 1 of 5 main. Provide trip rating of main CB. 5/26/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/1/18 Swap drawing 1, Revision 4. 5/1/19 1) Provide 2nd copy of as built drawings. 2) Show new changes in the dwg with a new triangle with revision # - list all changes. 6/28/19 Swap dwg #1 of 5 Rev-4 and 2 of 5 Rev-0. 1/28/2021 Amended dwg# 1 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
54382	17A0155	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 10/24/17 - swap dwg with Rev 2 1/3/18 - Swap Dwg Rev 3				
54366	17A0156	Requesting permission due to lack of space inside of the existing service room to locate new electrical service equipment outside of the building not grouped together with the existing service equipment	Approved	\$350.00
OR With the stipulation that signage is provided at each service area as per Article 230 Section 230.2(E). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54415	17A0157	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply the Section 230.64 for s.s. #4. Section 110.26 apply for working space for 750 KVA transformer. (Drawing 2 of 6). Relocate new distribution switchboard from blocking the door. Service room #2. 2/24/17 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/19/18 Swap 6 of 6 dwgs . This job supercedes & replaces previous job for 30-30 47th Avenue, Submission #17A00061 due to major changes. Job needed to be resubmitted. 11/1/18 Swap Dwg #4. 5 and 6 of 6-Revision 3.. 2/1/19 Swap dwg # 4 of 6 and 6 of 6-Revision 4.				
54381	17A0158	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 5/16/2017 -swap dwg 1 & 2 rev 1				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54370	17A0159	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54380	17A0160	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 11/27/17 - swap dwg 1 rev 1				
54454	17A0161	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide panic bars on doors. 3/23/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/20/17 - swap D1 rev 2 1/29/18 - Swao dwg with Rev 3 3/22/18- Swap dwg with Rev 4 No More Swaps				
54456	17A0162	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Doors to have panic bars 110.26(c)(3) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/23/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/18/17 - swap dwg 1,2,3 rev 2				
54476	17A0163	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Special service FP is misidentified. 2. Feeders feeding 75HP F.P. is undersized. 3. Equipment GND Cond's for F.P.S. are undersized. 4. Indicate panic hardware. 3/24/17 - Verify that FP cables in fire pump service panel is separated. 3/31/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.4/10/2020 Swap Dwgs 1,2 and 3-Revision 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/30/2020 Swap Dwgs# 1,2,& 3 rev 5 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

February 15, 2017

Approval #	Submission #	Type of Request	Status	Fee
54374	17A0164	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54375	17A0165	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54359	17A0166	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				