

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55827	18A0735CO2	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1) The exception referenced applies to de energized equipment in order to de energized the MV cables, proper OSHA grounding procedures require applying grounding cables to bleed own the standing voltage on the cables. Consequently, these are energized conductors and require proper clearance for applying the grounding cables.. 4/11/19 Job finalized With the stipulation to provide signage "The foldabel platform shall be unfolded and used when working on the rear of medium voltage switch gears" and platform shall be properly grounded .Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
56176	19A0013	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>5/8/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 5/24/2021 Amended Plan # 1 of 1 Rev-2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55718	19A0018	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/6/2020 Swap dwg #A.1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/28/2022 Amended plan # 1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55811	19A0033	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide adequate AIC rating of 'EPB' panel-the available s.c. current at "EPB" panel is more than the AIC rating of the equipment. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/15/2020 Amended Plan # A Rev -2 & B Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 10/28/2021 Amended Plan# B Rev 4</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55817	19A0036	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Physical doesn't match one line per DP-R 2) Verify location of DR-DP. 3/27/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/13/2020 Amended Dwg # B Rev 1, C Rev 2, D Rev 2 and E Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 11/9/2020 Amended Dwgs # B Rev 1 C Rev 2, D Rev 4 and, E Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56139	19A0043	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>2/11/19 - 1. Provide bonding and grounding to FA S.S.W. 2. Provide coordination and short circuit study signed and sealed by PE. 3. Comply with G95.4(B)(3)(4) - Provide 12" separation. 4. "ATS-OP-65" shall be 4 pole ATS and confirm number of wires feeding "DP-RSB" panel. 5. 800A SW cannot be installed in 600A panel - confirm current rating of fire pump switchboard. 6. Confirm that SKV switch doesn't need rear access and provide cut shet for SKV switch. 2/20/19 - With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. 5/3/2023 Amended plans # A Rev 8, B Rev 8, C Rev 2 E Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 10/21/2019 1) Item # 1 & 6 from last revision are not addressed. 2) Confirm that # of wire of F.A emergency & normal side. 12/18/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/20/2023 Amended plans # A Rev9, B Rev 10, C Rev 3, D Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55900	19A0050	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) ATS not permitted in electric service room. 2) Verify typo to sets of 500MCM feeding DS-BOH.B with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/10/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
55727	19A0052	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55728	19A0053	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/11/2019 Swap Dwg # D-1901-30878-A Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55808	19A0063	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance doc. 4/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56055	19A0075	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance document. 8/12/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 11/27/19 Swap Dwg # 24100AB90-01 of 1 rev.2 and # 24100SB05-01 THRU-01 rev.4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55825	19A0084	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>2/19/19 - 1. Show bonding and grounding to existing service switchboard. 2. Confirm modification to 4(1/4" x 4") extention will not violate listing of existing switchboard - dwg (2 of 2). 4/9/19 This drawing is approved with the stipulation for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/2/19 Provided UL field evaluation, stipulation deleted. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55820	19A0087	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Include license # within the cover letter. 2) Remove bonding from new service switchboard and new distribution switchboard "DB-C1". 3) Provide the AIC rating of the new equipment. 4) Confirm that new elec. Work location are included with in provided control number for Asbestos Assessment report. 4/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/21/2019 Swap Dwg #A Rev-5. 10/17/19 Swap dwgs A-Revision 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55736	19A0090	Requesting special permission Manual Transfer Switch installed in Main Service Room to remain	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55737	19A0094	Requesting special permission for ungrouped Service Switches	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55974	19A0095	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Remove bonding from FP and FA switches - emergency side. 2. Fire pump OCPD - normal side - is overfused. 3. Verify 4 wires feed fire pump ATS. 6/7/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/12/19 Swap Dwg #16366-1 Rev.2 and #16366-2 Rev.1 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/11/19 Swap dwg #16366-1-Revision 2 and dwg #16366-2-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/9/2021 Amended Plan # 1 Rev- 4 & plan # 2 Rev-3.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/20/2021 Amended Dwgs# 1 Rev 5 and 2 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	19A0098	Requesting SP to keep shared small circuit appliance	Denied	\$350.00
Failed to provide a hardship and safe alternative.				
	19A0099	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
OR - 1) Provide asbestos abatement compliance doc. 4/2/19 1) Provided Asbestos document doesn't include area of new electoral work. 6/17/19 Contractor sent letter requesting withdrawal this submission.				
55722	19A0100	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/15/2019 1) Confirm that 24" clearance to CT cabinet in new service swbd is acceptable by Con Ed specs. 10/1/19 Swap dwg #A-Revision 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
	19A0101	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR - 1) Provide asbestos abatement compliance doc. 5/20/19 1) Provide ACP5 control #				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55738	19A0104	Requesting a special permission to keep sleeves at 11" A.F.F.	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56136	19A0107	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with Section 230.71-verify if existing 400A service switch was in use previously or it was spare-add the note in the one line drawing. 2) Provide Asbestos Abatement compliance document. 5/7/19 - 1. Verify project address drawing & asbestos doc has different address than submitted cover sheet. 8/14/19 1) Provide all coordination study values for each C.B. and fuses on one line diagram (Clearly match fuses/C.B. label in both plans and coordination study). 10/9/19 1) Label "MDP" and overcurrent protection devices to match coordination study.(Type and size and name) or edit lable on the coordination study to match dwg. 12/11/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55719	19A0108	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/15/19 Swap Dwg 1 rev 1.</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
56144	19A0109	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with 760.41(A)-F.A. tap to be ahead of N.D.L (Dwg 7 of 9) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>. 2) Provide coordination and short circuit study signed and sealed by P.E. 3) Show 150 KVA transformer secondary OCPD on dwg 5 of 9 and 4 of 9. 4) Comply with 450.3(B)-Primary OCPDs of 45KVA transformer that feeds "PP-E-D" and "PP-E-A"-emergency side-are overfused. 5) Physical doesn't match one line-"MS-C" and "DP-LL-C". 10/30/19 1) Bus bar feed SS # 2A, 6A in "MS-A" 2) Primary conductors of 500 KVA xfms and off s.sw # 5B & 6A are undersized - Dwg # 3 of 8 & 4 of 8. 3) Bus bar feeds s.sw # 5B in "MS-B" is undersized - Dwg # 4 of 8. 4) Bus bar feeds vertical bus bar in section # 3 in "DP-LL-C" swbd. 5) Provide main bus bar size in "MS-D" swbd - Dwg 6 of 8. 6) Conductor feeds "DP-LL-A" off SS # 4D is undersized - (SS # 4D is overfused). 7) Vertical bus in "DP-GEN-C" section #2 is undersized. 8) Confirm ATS in service rooms is only feeding optional standby loads only. 9) Coordination study doesn't match one line. 1/2/2020 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. 6/12/2023 Amended plans # B Rev 5, E Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/14/2022 Amended plans # 1, 2, 3, 4, & 5 Rev 0. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/15/2023 Amended plans # A Rev 3, B Rev 3, E Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/27/2023 Amended plans # B Rev 4 E Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55730	19A0111	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/4/19 Swap Dwg 1 rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55963	19A0112	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Comply with 695.5(A)(2) - remove xfmr secondary OCPD. 2. Provide asbestos control number (ACP-S control #). 3. "FBP-SW-1" OCPD is over fused - 695.4(B)(2). 4. Show NDL in existing switchboard "MSB". 5. Provide available short circuit current at fire pump controller. 4/15/19 1) Fire booster pump OCPD is undersized -comply 695.2 & 695.4(B)(1)(2). 2) Confirm that electrical work locations are included within the provided ACP 5 control number. 6/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/18/19 Swap Dwg # SNY000-S2-FP (2 of 2) Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55723	19A0113	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/26/19 Swap dwg AB-19365-A.1 and dwg AB-19365-B.1. 7/13/2021 Amended plan# A & B Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/4/2023 Amended Plans # 1 & 2 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/24/2023 Amended plans # 1 & 2 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55729	19A0114	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55887	19A0115	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply with 230.71 2) Confirm that service room doors leads to a legal egress. 4/4/19 - 1. Sectional bus feeds service switches #1,2, & 6 is undersized. 5/6/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55843	19A0118	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Vertical bus (upper portion) section #1 in MDP is undersized. 2) Provide asbestos abatement compliance doc. 4/23/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/26/19 Dwg A.2 rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/28/2020 Amended Dwg # A Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
56161	19A0120	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide bonding & grounding to service switch feeding ss AP and ARCS and lable this switch in floor plan. 2) Comply with 695.4(B)(3)(4). 3) Provide short circuit study. 4) Provide Asbestos Abatement compliance documents. 11/18/19 1) Comply with 110.26(A)(2)-for service switch feeding arcs-provide 30" working space width. 2/14/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 2/14/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work 10/19/2020 Amended Dwg # 1 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/23/2021 Amended Dwg # 1 Rev 5 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
	19A0121	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Drawings not in EAB format. 4/24/19 1) Show all information in the one line Dwg. -clearances around new transformer. - type of 2500A fuse - Is secondary GFI provided? Encosure types don't match letter and transformer cut..				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55841	19A0122	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump EGC is undersized-T250.122. 2) Cond. Feeds 60A disconnect F.A. switch is undersized. 3) EGC of 800A sw(2nd fuse) in (MS-A) feeds "ATS-SB" is undersized. 4) Provide coordination between 1600A A4BQ & upstream fuse in (MS-A) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55725	19A0123	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55842	19A0124	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service switch #2 GEC is undersized-250.66. 2) Comply with 230.95-Provide GFP to service switch #1 3) Comply with 695.6(B)(1)-Provide 2 hr fire rated cond to fire pump with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55871	19A0125	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide asbestos abatement compliance required documents. 2) Provide 4 pole ATs to loads - using SDS transformer in the emergency side with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/25/19 - This drawing is approved</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/15/2023 Amended plans # 1 Rev 2, 3 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 6/26/2023 Amended plans # 1 Rev 2, 3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56069	19A0126	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Asbestos Abatement compliance document. 2) Provide available s.c. current and AIC rating of new distribution panel(5th floor). Also, confirm NRTL listing on DWG #2 sheet 1. 3) Provide 5' clearance to ss#4-Dwg #3 sheet 1 6/6/2019 1) Confirm the project address. 7/16/2019 1) Confirm legal egress in the basement service room. 8/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55844	19A0127	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Provide asbestos abatement compliance doc. 2. Provide 5' clearance to S.SW#4. 3. Verify cond. Size feeding SS#5. 4/23/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0128	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Service busbar feeds ss#1 and ss#2 is undersized. 2) Provide series rating documents. 3) Provide Asbestos Abatement compliance document. 4) Coordination required for 800A ss#3 and branch cb's. Also for SS#1 & ss#2 (Above 600A selective coordination is required) 5). Spa panel missing s.g.				
	19A0129	Requesting a special permission for Fire Wrapping of Emergency Circuits thru Main Electric Room.	On Hold	\$350.00
Provide the following A special Inspection documentation that the installation was installed in accordance with the manufacturer's installation or a letter by the Engineer of Record that they have witness the installation and it is satisfactory to them.				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55866	19A0130	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Confirm generator is SDS or NSDS and show number of wires (3 or 4 wires) used. 4/25/19 - This drawing is approved</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. 12/27/2022 Amended Plans # A Rev 5, B Rev 7 and C Rev 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/24/2023 Amended Plan # C Rev- 9. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 				
	19A0131	Requesting special permission to keep an elevator feeder as installed in the elevator shaft.	On Hold	\$350.00
<p>Provide the following:</p> <ol style="list-style-type: none"> 1.Is the elevator new or existing. 2.How many floors is this building 3.Provide a hardship for installing the feeder within the shaft (see 620.37(C)(1)). 4.Provide a letter, signed and sealed by the elevator installer/ maintenance indicating that the location of the feeder does not interfere with the elevator operation or controls. 				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55739	19A0132	Requesting a SP to utilize RTRC conduit within building	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55726	19A0133	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/15/19 Swap dwg A-Revision 1. 5/30/19 Swap dwgs A & B-Revision 2				
	19A0134	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1. Provide asbestos abatement compliance doc. 2. Physical doesn't match one line. 3. Provide panic bars to door. 4. Confirm that new service end pull box does not interfere with clearance of main swbd.				
55828	19A0135	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Remove bonding from FA switch emergency side. 2. Provide 5' clearance to fire alarm S.S.W. 3. Doors to open outward. 4. Confirm that fire alarm neutral tap is before ND. 5. Verify neutral conductor from fire pump S.S.W to fire pump controller. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 4/12/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0136	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Provide barriers between ct breakers on genset with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) 2hrs fire rating for fire pump conductor not provided. 3) Verify type in conduit fill between Sub-2 and fire pump transformer. 4) Provide selective coordination study. 5) Cancel one of grounding on transformer secondary or FA service switch. 6) Verify location of circuit breaker B on one line. 7) Identify sequence on one line (identify all breakers). 8) Show roll up generators if it-is generator source 3?</p>				
55909	19A0138	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify cond size feeds ATS "S1" normal side-from "SSA" switchboard doesn't match at the ATS with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Confirm the bus bar size is correction the one line dwg for "GSB"-Square D cuts doesn't match . 3) Provide ampacity calculations for bus bars . 4) Verify project address-Asbestos document doesn't match the project address. 3/29/19 - 1. The main bus in "GSB" is undersized. 2. - Item #4 is not addressed. 4/5/19 1) Item #4 from revision date 2/12/19 is not addressed. 5/14/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/24/2024 Amended plans # 1 & 2 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55801	19A0139	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump GEC undersized-250.66. 2) Confirm that limited service F.P. is above street level.. *Stipulation: Undersized service conductors to be re-evaluated when load on 1600A service switch #4 is filed with the Advisory Board. 3/26/19 With the stipulation of Undersized service conductors to be re-evaluated when load on 1600A service switch #4 is filed with the Advisory Board. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55814	19A0140	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Provide generator & ATS size and type. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/25/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/16/2021 Amended Plans# 1 Rev 3 ,2 Rev 3 and 3 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/12/2021 Amended Plan# 1, 2&3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55731	19A0141	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55732	19A0142	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/22/20 Amended Plan # 1 & 2 Rev-1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55720	19A0143	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55952	19A0144	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - 1) Provide asbestos abatement compliance doc.. 5/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/4/19 Swap Dwg # ACS-D-11482 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
56110	19A0145	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Conductor feeds new 1200A MB is undersized. 2) Provide Available s.c. current at new 1200A at meterbank. 9/20/19 1) Provide 5' clearance to s.sw #1. 11/13/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/10/20 Swap dwg #ACS-D-13482-1-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55875	19A0146	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Confirm that new electrical work location is included within the provided Asbestos Abatement compliance document with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

February 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55733	19A0147	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55721	19A0149	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/8/19 1) Vertical buses in "East Coast swbd" section #1 are undersized. 2) Provide appropriate clearance to rear of "New East Coast swbd" section #1. 5/6/19 - Swap dwg #A021901 Rev-1. Please check special permission #55856.				
55740	19A0151	Requesting special permission to provide an elevated dedicated workspace platform for medium voltage equip.	Approved	\$350.00
with stipulation Platform shall be provided with risers and railing in accordance with NYC Building Code Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55741	19A0160	Requesting SP to keep shared small circuit appliance with dishwasher.	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				