

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53577	15A0518CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from August 12, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 12/18/17 - Swap dwg # P1 Rev 2. 7/6/18 Swap dwg # P1-Revision 3 and P2-Revision 2.				
	15A0588CO2	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from January 13, 2016 meeting. 1) Show paralleling bus sizes.. 2) Provide coordination study addressing items discussed at meeting.				
53586	15A0651CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from October 21, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/14/2020 Amended Dwgs Sheets 1,2, 3, 4 and 5-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
	15A0774CO	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
Carry over from November 18, 2015 meeting. 1) 1000 KVA installation to comply with Section 230.64(B)(1) through (5). 2) show clearances in service room to comply with 230.64(B) and 110.26(A)(3). 3) Service room door to open outwards.				
53601	15A0842CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from December 16, 2015 meeting. 1)Load bank breaker bay to be listed. 2) Load bank breaker bay to be provided with main 25' tap. 3/17/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/17/16 Job finalized Ok, with the stipulation that the bus supplying the 4000 amp circuit breaker in the breaker bay switchboard is removed and the breaker bay switchboard is field evaluated by a NRTL and the NRTL approval and testing report is available at inspection .Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0020	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1. ATS & feeders not protected, normal & emergency sides. 2. Service switches over fused. 3. Put bus duct manufacture's bud density notes on 1 line for 200k series rating. 4. Show short circuit current at switchboards and all other equipment up to 3rd level. 5. Designer to appear at meeting when revised drawings are submitted. *If 1000 KVA temporary switch boards will be used a submittal is required</p>				
	16A0025CO	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
<p>Carry over from January 13, 2016 meeting. 1) Provide physical for substations 1 and 2. 2) Secondaries of transformers not bonded and grounded. 2) Coordination study not provided. 3) Is fire pump #4, explain GFS (typo) in service switch. 4) Fire pump service entrance conductors and feeders to fire pump transformers are undersized. 5) Provide barriers behind 120/208 switchboards. 6) Clearance behind medium voltage switchgears to comply with Table 110.34. 7) Verify that 750 KVA transformer connections are on the left side of the transformer on room layout. 8) Explain what 2" EPR is.</p>				
53575	16A0043	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/1/19 Swap dwg A-Revision 3. 1/15/20 Swap Dwgs A rev 3 and B & C rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/10/2020 Dwg A-Rev 4 and Dwg C Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
53558	16A0056	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/22/16 Swapped Drawing A-Revision. No more as built.</p>				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53557	16A0057	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0066CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Full detailed reduced neutral and voltage calculations not provided from Con Ed box to last panelboard, 4% to last distribution board and 1% to last branch circuit panel.				
53819	16A0075	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide manufacturer's cut sheet of new 800 amp panel. 2) show wiring method from 800 amp service switch to new panel. 3) Show fuse type in 800 amp switch. 5/16/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/1/16 Swapped drawing1-Revision 2.				
53579	16A0116	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/22/17 - swap Dwg A rev 3 2/28/18 - swap dwg A Rev 4, B Rev 3				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53823	16A0125	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Rear of switchboard to comply with 230.64(B)(4). 2) Where is the service entrance box located in relation with the service room? 3) Only first and second fusing to be shown on drawing, put a note under the generator indicating whether 3 or 4 pole ATS' will be installed. 4) Feeders undersized to and from 800 amp emergency with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/18/19 1) Provide coordination study for 800A fuse & 200 downstream TR fuses. 2) Conductor feeding FCO 100A switch undersized. 3) Verify ATS in electrical room. 2/28/2020. Swap dwg 1 of 3 and 2 of 3-Revision 4; dwg 3 of 3-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/26/2020 Dwg 1 of 3-Revision 5, Dwg 2 of 3-Revision 4 and Dwg 3 of 3-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
	16A0130	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>OR Drawing not complete, length of tapped conductor not shown and undersized. With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer.</p>				
53576	16A0144	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53939	16A0157	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify oversized bus bars in switchboards. 2) Emergency side equipment grounding conductor to 100 amp disconnect switch is undersized. 3) Verify that neutral conductor in generator is bonded to the enclosure. 4) Provide short circuit curves generator circuit breaker to distribution panel with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/27/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/8/17 Swapped drawings 1 of 3-Revision 2, 2 of 3-Revision 1 and 3 of 3-Revision 1. 4/21/2021 Amended Dwgs# 1 Rev 1, 2 Rev 1, 3 Rev 0 and 4 Rev 0. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 6/4/2021 Amended Plan# 1 ,2 ,3 Rev 2 & 4 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/21/2021 Amended Plan #1 of 4 Rev-2, # 2 of 4 Rev- 2, #3 of 4 Rev-3 and 4 of 4 Rev- 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
53582	16A0168	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53591	16A0173	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53580	16A0175	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/15/2022 Amended Plan # 1 Rev-2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
53581	16A0177	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0181	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Short circuit study not provided, signed, sealed, by a PE. 2) Section #12 section bus undersized. 3) Equipment grounding conductors undersized.				
53583	16A0183	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0184	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Coordination study indicates that OCPD not coordinated with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53584	16A0188	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53585	16A0189	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53828	16A0190	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Length of taps not shown. 2) Equipment grounding conductors undersized. 3) Verify that the Bollards don't interfere with transformer access. 5/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53571	16A0191	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 6/6/2019 1) Provide coordination between 600A FRSR fuse & upstream fuse signed & sealed by P.E 7/10/19 Swap Dwg #A.4				
	16A0192	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) Drawing not in Advisory Board format. 2) Drawings too small to read. 3) 1 Line does not match room layout 600 amp service switch not shown in service room. 4) 600 amp fuses to coordinate with 300 amp fuses fuse types not shown. 5) Bonding and grounding of existing service equipment not shown on 1 Line.				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53919	16A0193	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Emergency "EMSWB" section bus undersized middle section. 2) Address ATS-LS#5 in short circuit study. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer.. Note: Look ate the generator damage curve. 6/20/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/3/16 Swapped drawing 3-Revision . This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 8/31/17 - swap dwg 1,2,3, rev 2 				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53587	16A0194	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53560	16A0195	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
53559	16A0197	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR With the stipulation tha new 600 amp disconnect switch comp;ies with 110.26 (A)(3). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53825	16A0199	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1., TAP conductor #2. 500 KCM. 5/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53818	16A0200	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Provide barrier behind switchboard. 5/16/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/28/16 Swapped drawings 1 and 2-Revision 2.				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0201	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Scope of new work not clear on drawings, new 3000 amp service switch #2 and distribution board not shown on 1 line. 2) All new work to be bubbled. 3) Notes cut off of drawing.				
53562	16A0202	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53588	16A0203	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/2/16 Swapped drawing A and B-Revision 1.				
53589	16A0205	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/25/18 - swap dwg A & B Rev 1. 9/24/18 - Swap dwg A - rev 2. 9/26/19 Swap Dwg # D-1602-27580-A Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/5/19 Swap Dwg # D-1602-27580-A Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
53578	16A0206	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53608	16A0207	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show short circuit current at circuit breaker panel PP-6, PP-CR, NB-1 and NB-2. 2) Provide cut sheets for circuit breakers or provide coordination study.. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53826	16A0208	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Manufacturer's cut sheet of serve equipment does not match bus on 1 Line. 5/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/14/18 1) Comply with 760.41(A)(1)-F,A, tap to be before N.D.L. 2) Provide coordination between 1200A A4BQ & downstream fuses. 10/15/18 Swap dwg 2-Revision 2				
	16A0209	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Grounded conductor to be brought to fire pump service switch. 2) fire pump verify Vita Link cable installed in conduit. 3) Verify that ATS' EDP "C-EM-1" and C-STS-1 normal sides are 3rd fused. 4) Fire pump switch provide physical with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.				
	16A0211	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1 Line does not match physical and room layout of service equipment (1 Line is in reverse).				
53592	16A0214	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.2/1/18 - swap dwg Rev 1				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53593	16A0215	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/21/19 1) Clearly mark and note all the changes on the plan from previously approved plan. 9/17/19 Swap Dwg # ACS-D-12342-1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/11/19 Swap Dwg # ACS-D-12342-1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
53573	16A0218	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53568	16A0219	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53565	16A0220	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/8/19 Swap Dwg Rev 1.				
53566	16A0221	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53567	16A0222	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/11/18 Swap dwg 1-Revision 4. 12-16-2020 Amended plan Plan #1 Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
53922	16A0223	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
I. Will a new generator be installed? If so, indicate on drawing. Fire Alarm, indicate if it will be a separately derived system and show types of ATS. 6/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53594	16A0224	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/28/16 Swapped drawing 1-Revision 1.				
53572	16A0225	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR With the stipulation that the rear of the switchboard is blocked off. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 6/15/16 Swapped drawings 1,2,3-Revision 1.				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53610	16A0226	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/26/18 - swap dwg # 1 & 2 Rev 1</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. <p>The fire proofing must be performed by a certified fire proofing installer.</p> <p>* Note: UL 2200 is for the engine only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
53570	16A0227	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53569	16A0228	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 3/12/18 - swap dwg 1 Rev 1. Swap dwg 1-Revision 2. 7/3/18- swap dwg 1 Rev 2				
53564	16A0229	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53595	16A0230	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/1/18 - Provide 5' clearance to in front of SS# 2 and F.A. service switch. 11/14/18 "R" 1) Fire pump OCPD-Normal side-is undersized. 1/3/19 Swap dwg #SSL-11961-Revision 3.</p>				
53561	16A0231	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53920	16A0233	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Bond neutral to enclosure in 1600 amp service switch and install neutral link. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.3/7/18 - 1) Comply sec 695.6 (B) for FP emergency conductor & provide 2HR FR. 2) Show generator chasis grounded 3) Provide tamper proof screws on the rear of SS# section MLO, 1600A retail SW and 4000A CT to prevent the rear access. 4) One 200A disconnect switch tap from 1600A SS# in MSS-A is missing on floor plan. Verify number of tap disconnect switch on floor plan & single line. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/2/18 - swap dwg with Rev 3</p>				
	16A0234	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Where is the service end box located in relation to service room, what floor is the service room located on 16 sets of SEC's. 2) Emergency side fire alarm disconnect switch bonded and grounded on non separately derived system. 3) Transformer secondary's not bonded and grounded. 4) Equipment grounding conductor undersized load side of 1600 amp switch. 5) "MDP" explain feeders in twin panel "by others". 6) Fire pump emergency feeder not fire rated. 7) Where is the fire pump transformer located? 8 Manufacturer's cut sheet of equipment not provided. 9) Fire alarm ATS to be 4-poles. 10) SS 3000A and 1600A to have 5' clearance. 11) 1 Line does not match room layout or physical. 12) Verify 12" separation for fire pump service switch.</p>				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0235	Requested approval for the electric service equipment proposed to be installed		\$650.00
Not Reviewed				
53596	16A0236	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/13/17 - swap dwg 1 rev 2				
53590	16A0237	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53563	16A0238	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/30/16 Swapped drawing 1-Revision 2.				
	16A0239	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) 1-Line drawing not in Advisory board format. 2) Provide cut sheets of 1000 volt PV equipment showing their listing. 3) Service room layout does not show clearances.				
53820	16A0240	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
I. BUS feeding service switch #2 undersized..5/16/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.5/16/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/31/18 - swap dwg 1 & 2 Rev 2. 8/16/18 Swap dwg #1 of 2-Revision 3				

ADVISORY BOARD CALENDAR

March 9, 2016

Approval #	Submission #	Type of Request	Status	Fee
53650	16A0241	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Drawings not in Advisory Board format. 2) Scope of work not clear. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
	16A0242	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1. 1 line does not match room layout, 1 line shows 3 service switches and room layout shows 5 services switches. 2. Clarify scope of work. 3. Add note to drawing on what will be installed. Drawings are very confusing to follow.				
	16A0243	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) Water damaged electrical equipment to be replaced or 2) Water damaged electrical equipment to be recommissioned by the original manufacturer of the electrical equipment, or 3) Water damaged electrical equipment to be tested and evaluated by a NETA certified testing agency witnessed by a PE and the NETA report to be signed and sealed by the PE along with a letter from the PE that the PE witnessed all testing.				
53574	16A0251	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				