

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50573CO		Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	284 Livingston Street Brooklyn NY	Denied	\$0.00
Carry over March 10, 2011 meeting. Tap detail or length of taps not shown.						
50816CO2		Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	1717 Broadway New York NY	Hold	\$0.00
Carry over from December 14, 2011 meeting.. 1) Fire pump emergency branch circuit not fire rated. 2) Verify whether 3 or 4 pole ATS' are being used. 3) Bond and ground transformer secondaries. 4) Feeder to panel "SBDH-66" overfused. 5) Does emergency switchboard feed life safety loads. 6) Provide generator room layout, generator cut sheets. 7) Verify that emergency conductors are not ran through the service room.						
51037CO2		RCM Technologies 3020 Westchester Avenue, Suite 401 Purchase NY 10577	Requested approval for the electric service equipment proposed to be installed	150-14 Jamaica Avenue Queens NY	Approved	\$0.00
Carry over from February 14, 2012 meeting.						
51091CO		Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	19 East 34th Street New York NY	Approved	\$0.00
Carry over from February 15, 2012 meeting.						
51099CO		Gallagher Electric 111 John Street, Suite 2605 New York NY	Requested approval for the electric service equipment proposed to be installed	120 Park Avenue New York NY	Approved	\$0.00
Carry over from February 15, 2012 meeting.						

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51124		Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Hioward Beach Senior Housing 155-55 Crossbay Blvd. Queens NY	Approved	\$650.00
1) Both doors must open out. 2) Fire pump tap to be moved ahead of neutral link. Job finalized 5/7/12.						
51125		N.J.D. Wiring & Electric, Inc. 213-08 99th Avenue Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	P.S. 71R-Staten Island 1050 Targee Street Staten Island NY	Hold	\$650.00
1) Fire pump branch circuit undersized. 2) Remove neutral bond in emergency fire alarm switch. 3) F.A. Disc.is backward. 4) Confirm generator not separately derived system and neutral is not bonded. 5) Gen not indicating grounding. 6) Use 2 pole ATS for F.A. switch. 7) Fire pump service feeder missing neutral. 8) Define RPC/ provide work space as per 110.26.						
51126		Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	200 Lafayette Street New York NY	Rejected	\$650.00
1) Equipment grounding conductors undersized. 2) Show size of vertical bus in 4000 amp board. 3) Fire pump emergency circuit overfused. 4) 3 sets 300 MCM terminated to 600 amp switch. 5) Confirm neutral is not bonded at gen. 12/20/12 - 1) Dedicate overcurrent disconnect means not provide at generator for fire alarm. 2) Fire alarm emergency feeder tap under size. 3) According drawing neutral shown bonded to generator enclosure. 4) Tap conductors at both 400A trans-s undersize. 5) Submit cut-sheet for Polaris connector used to tap into 5 sets 500 MCM. 12/19/13 Revision 4 rejected. 1) Size of F.A. switch on emergency side to be increased. 2) Tap conductors 500MCM undersized should be 600 MCM normal and emergency sides. 3) Check the elevator feeder 200 amp feeding 500 amp switch? Lighting load center? Is this correct?						
51127		Hampton Electrical Corporation 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	366 Madison Avenue New York NY	Ok, but	\$650.00
Verify new Con-Ed meter has 3' clearance.						
51128		Joseph Weinstein Electric Corp. 94-24 88th Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	1021-1029 Avenue of the Americas New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51129		K & M Electric Inc. 200 Varick Street, Suite 608 New York NY 10014	Requested approval for the electric service equipment proposed to be installed	551 5th Avenue New York NY	Approved	\$650.00
51130		First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	525 Clinton Avenue Brooklyn NY	Approved	\$650.00
51131		FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	148 East 48th Street New York NY	Ok, but	\$650.00
Verify fire pump on elevation indicated 1200A, single line 800. Job finalized 6/21/12.						
51132		Eric & NG Electrical Inc. 153 Suffolk Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	10 Union Square New York NY	Approved	\$650.00
51133		Broadway Electric, LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	620 West 42nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51134		US Electric Corp. 13-07 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	60 Madison Avenue New York NY	Approved	\$650.00
51135		GRX Euro Electric Corp. 18-02 26th Road Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	23-25 31st Street Astoria NY	Approved	\$650.00
51136		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Depository Trust 55 Water Street New York NY	Hold	\$650.00
<p>1) Show rear clearance of new paralleling switchgear. 2) DG-3 generator feeders are undersized. 3) Sequence of operation for UPS board. 4) Provide generators room layout, 5) Indicate bonding at generators. 6) Missing short circuit and coordination study-submitted curves are not adequate.</p>						
51137		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	85 St. Nicholas Terrace New York NY	Hold	\$650.00
<p>1) Verify that switchgear rooms are mechanically ventilated. 2) ASCO drawing, provide cut sheet for ILSCO bug tap. 3) ASCO drawing, provide Eaton drawing numbers that feed normal side of ATS'. 4) Provide procedure to safe off both line side of 13KV switch to allow safe work in 13KV compartment. 5) Confirm fire pump neutral tap is connected on load side of neutral link. 6) Provide wiring method type for under metal grating in electrical room sheet 7 of 14. 7) Doors to open out on sheet 8 of 14.</p>						
51138		Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Silverstein 570 7th Avenue New York NY	Hold	\$650.00
<p>1) Where is limited service fire pump located? 2) Where is tap for jockey pump located? 3) Verify what type pump is being installed.</p>						

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51139		Samco Electric Corp. 39-08 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Public Library 476 5th Avenue New York NY	Hold	\$650.00
1) General notes not shown on drawing. 2) Is switchboard rear accessible? 3) Identify feeders to 1200 amp disconnect switch. 4) Verify size of conduits 5) Verify if all conductors are copper. 6) Show length of tap.						
51140		Dunrite Electrical Corp. 107 Sanford Street Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	475 Kent Avenue Brooklyn NY	Approved	\$650.00
12/24/15 Swapped Drawing 1-Revision 1. 8/2/16 Swapped Drawing 1-Revision 2.						
51141		Allstate Electric Corp. 555 Eighth Avenue, Suite 809 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	25 Broad Street New York NY	Approved	\$650.00
51142		Jusler Electrical Corporation 45-43 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sage Realty Sprinkler Work 437 Madison Avenue New York NY	Approved	\$650.00
51143		Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	CBS Broadcast Center 513 West 57th Street New York NY	Approved	\$650.00
Service bus to 3000 amp service switches undersized. Job finalized 4/20/12.						

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51144		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NYU Langone Medical Center 550 First Avenue New York NY	Hold	\$650.00
1) Verify if paralleling gear is rear accessible, verify if the rear doors can open 90 degrees. 2) Generator cut sheets not provided. 3) Equipment grounding conductor undersized. 4) Verify if generators disconnect switches are in generator room. 5) Does emergency system feed life safety loads? 6) Designer to appear at meeting to explain job. 7) Drawing submittal incomplete provide all drawings, cut sheets, paralleling gear, coordination study as per Advisory Board rules.						
51145		Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	33 Thomas Street, 5th Floor New York NY	Approved	\$650.00
51146		Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	201 East 144th Street Bronx NY	Approved	\$650.00
1) Verify if emergency conductors are ran through the service room if so, are they fire rate?. 2) Verify bus sizing in "MDB-BB". 3) Provide emergency board cut sheet, and room layout. 4) Verify that load bank circuit breaker is not located in emergency board. Job finalized 4/24/12.						
51147		Nead Electric Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	330 Hudson Street New York NY	Approved	\$650.00
1) Verify that free standing switchboards have rear doors. 2) Bond neutrals to enclosures in unit substations disconnect switches. 12/20/13 Job finalized. 2/18/14 Swapped D-Rev 3, D1 Rev 5.						
51148		A.M.C. Electrical Services, Inc. 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	44 Court Street Brooklyn ny	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51149		Kopp Electric Corporation 59-27 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Bronx Lebanon Hospital Center 1650 Grand Concourse Bronx NY	Approved	\$650.00
4/15/ 14 Swapped A-Rev 2 and B-Rev 3.						
51150		Delta Phase Electric Corporation 137 29th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	60 East 56th Street New York NY	Approved	\$650.00
51151		Amber Lite Electric Corp. 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	250 Bowery New York NY	Approved	\$650.00
51152		Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	241 Fifth Avenue New York NY	Approved	\$650.00
Show transition box for MI cables. Job finalized 6/21/12. 11/18/14 Swapped A-Revision 1, B-Revision 2.						
51153		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	John Jay College 860 11th Avenue New York NY	Approved	\$650.00
1) Verify if emergency feeders are ran through the service room. 2) Verify number of feeders to lab emergency riser. 3) Emergency disc switches for lab emergency riser and panel EMCC-1 not identified in emergency panel "ESS-A". 4) Verify that emergency and optional standby loads are mixed in switchboard and provide breaker sizes.. Job finalized 3/28/12.						

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51154		Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requesting permission to leave as installed wall mounted over that do not comply with Section 422.31(B) and junction boxes for the wall mounted ovens that don't comply with Section 314.23 in 131 apartments	The Laurel 400 East 67th Street New York NY	Denied	\$350.00
51155		Martin Dorkin, Licensed Electrician 547 Coney Island Avenue Brooklyn NY 11218	Requesting permission to replace damaged feeders from the load side of existing 3000 amp service switch to an existing 3000 amp switchboard	920 East 132nd Street Bronx NY	Approved	\$0.00
With the stipulation that the equipment grounding conductors comply with Table 250.122.						
51156		Kenneth Fisk Electric Corporation 72-02 Cooper Avenue Glendale NY 11385	Requesting permission to use approximately 100 existing 20 watt single bulb fluorescent luminaires as a splice box to supply power to 100 new exit emergency luminaires throughout a building.	865 West End Avenue New York NY	Denied	\$0.00
Code: 410.64.						
51157		Arup 155 Avenue of the Americas New York NY 10013	Requesting permission to omit the installation of outlet receptacles on 4 twenty square foot balconies in a building under renovation.	117-119 East 69th Street New York NY	Denied	\$0.00
Code: 210.52(E)(3).						
51158		Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requesting permission on 2 semi attached buildings with 4 separate blocks and lots without common walk through means inside of the buildings to leave as installed service equipment in one building and run eight sets of feeders to the adjacent building to feed apartments.	Madison St., 1052 and 1054 Putnam Brooklyn NY	Denied	\$350.00
Code: 225.30.						

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51159		Triborough Electric Inc. 36-20 164th Street Flushing NY 11358	Requesting permission to tap power for a fire pump from the load side of a C.T. located in the same cubicle that contains overcurrent protective devices due to there being no Con Ed copper detail box to tap power from or another remote service in the building	Coler Hospital 900 Main Street Roosevelt Island NY	Approved	\$0.00
Code: 695.3(A)(1).						
51160		Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street, 7th Floor New York NY 10001	Requesting permission to leave as installed 1000 KVA service switches with front clearances of 4' on a job where the buildings structural footing prevented the electrical equipment from having 5' clearances.	425 Lafayette Street New York NY	Approved	\$0.00
With the stipulation that insulated material is installed on the outside cover of the transformer that is facing the service switches. Code: 230.64(B)(1).						
51161		Jaros Baum & Bolles Consulting Eng 80 Pine Street New York NY 10005	Requesting permission to reuse existing feeders to supply new chillers where the feeders will have a 4.31% voltage drop and the last branch circuit overcurrent device with a total 4.6% voltage drop for the feeder and branch circuit combined.	55 Water Street New York NY	Approved	\$0.00
Code: 215.2(A)(1) and 210.19(A)(1).						
51162		H & L Electric Inc. 41-11 28th Street Long Island City NY	Requesting permission to install a junction box behind switchgear equipment where the clearance between the front of the junction box and the rear of the switchgear equipment is 25"	Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Denied	\$0.00
51163		S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requesting permission to install "E2 Path and composite sheet". Products to separate normal feeders and emergency fire pump feeders and fire pump control wiring in a shared pull box, all conductors are THHN and installed in exposed E.M.T. From the second to 40th floors of a building.	311 West 39th Street New York NY	Denied	\$350.00

ADVISORY BOARD CALENDAR

March 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51164		AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission on a job where Con ED is discontinuing 5KV radial feeders and the campus is refeeding 11 buildings from their 27 KV substation from 4160 volt switchgear to existing transformers using new and existing feeders	St. John University Queens Campus Queens NY	Approved	\$0.00
51165		Schulte Electro Systems Corporation 41W020 Seavey Rd Sugar Grove IL 60554	Requested approval of equipment for use in New York City of your EVOLine Port 1636, EVOLine Dock 2122		Hold	\$200.00
<p>The models Evoline R Port 1636 and Evoline R Dock 2122 are not listed in the Certificate of Compliance. Report by CSA, please be advised that the NYC Electrical Advisory Board does not approve relocateable power taps. Receptacle outlets required by the electrical code must be hard wired.</p>						