

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55894	18A0761CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from 12/19/18 meeting. 1) Item #1 is partially addressed-line side and load side bus bar connected to 4000A switches shall be with density 800A/square inch -Dwg #E & F. 2) Medium voltage conductors feed "SST-B" and "SST-C" are undersized. 3) Fix typo related to "ATS-EL-11" or "19" in dwg # F & E. 4) Co-Gen was noted in the coordination study and not on the one line-verify. 5/9/2019 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/9/2022 Amended Plans # A Rev- 5, # E& F & L Rev- 7, # F-1 & G Rev-6, # H Rev-3, # I Rev-9, # M Rev-2, and # N Rev-3, Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
56044	19A0064	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 3/13/19 1) Provide Asbestos Abatement compliance document. 2) New 350A fuses in 23rd floor are overfused-240.21.. 7/5/19 1) Confirm area if new work is included within provided ACP5H 1451199 7/30/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/27/19 Swap Dwg # 1 rev.2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55772	19A0077CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>OR Carry over from January 23, 2019 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	19A0091CO	Requested approval for the electric service equipment proposed to be installed	Pending	\$0.00
<p>Carry over from January 23, 2019 meeting. 1) Provide more detailed power system study. 2) Confirm conflict between ESCO-574132-004 1 of 6 gen swbd with ATL-D-17-01 057-B-Revision 2. 5/21/19 1) Old revision (Rev 1 & 4) were re-submitted - please confirm. 2) None of comments were addressed.</p>				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55787	19A0102	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 3/13/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56175	19A0106	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Existing service bus bar is undersized-A230.42(2). 2) Provide 5' clearance to new 400A ss#6-A230.64(B)(1). 3) Provide AIC rating and available s. c. current at new equipment.. 3/20/2020 1) Provide 5' clearance to new 400ASS#^ 5/7/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 6/5/2020 Swap drawings # 1 rev1 & 2 rev 0. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55891	19A0136CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from February 20, 2019 meeting. 1) Confirm CB BR "B" to be normally closed (In this case call up generator connection section will be energized on the first floor, is there any interlock?) 4/4/19 1) EGC from 250A CB at generator is undersized -T250.122 2) Provide bonding & grounding to all service switches. 3) Clearly explain the sequence of operation when using the roll up generator to feed the loads. 4) Provide conductor size from 1600A breaker of roll up gen. 5) Confirm complying with 760.41(D)(2). 5/2/19 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/19/19 Swap Dwg # 1 of 4 Rev 3 and Dwg # 2 of 4 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
56106	19A0137	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide short circuit at fire pump controller. 2) Bubble new work verses existing. 3) Provide the source feed existing 3000A switch and the sequence of operation. 4) Clarify KVA size of existing transformer feeding fire alarm. 5) Confirm that new switchboard is front accessible only with temper proof hardware.</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>7/23/2019 1) Address previous comment #5 per 230.64. 2) Provide coordination between the 2000A fuse and downstream 600A fuses. 3) Provide correction to undersized section bus linking to 600A fuses. 4) Provide correction to undersized fire pump conductor size. 5) Comply with 695.3A 8/23/19 1) Comply with 695.4(B)(3). 2) Confirm that asbestos doc includes area of new work. 11/6/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/10/20 Amended Plan # B Rev-9 and # C Rev-4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/23/2020 Amended Dwgs# A Rev 9, B Rev 10 and C Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55798	19A0150	Requesting Equipment Approval for LED luminaire.	Approved	\$200.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
56111	19A0155	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide 5' clearance to service to service switches in "ss-20-1" and "ss-20-2" service switchboards-verify front of switchboards. 2) Incoming service busbar feed 4000A service switches in "ss-20-1" & "ss-20-2" are undersized. 3) Comply with 700.6(G)-provide disconnecting means & show neutral bonding and grounding on the drawing. 4) Confirm that the service room is 2 hr fire rated. 5) Clarify that the job is having 2 addressed and provide ACP control number to 2nd address. 6) Confirm using ground fault protection and not just ground fault sensing-230.95. 7) Provide ATSS AIC rating. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/6/19 1) Provide portable pull-up generators breaker size feed new cubicle . 2) Provide service conductor size feed new service switchboard "SS-20-5 & 6" and "SS-20-1" and "SS-20-1" and "SS-20-2". 3) Verify if new service switchboards are front accessible only and confirm compliance with 230.64(B)(4). 4) Confirm that 2500A CB & 1600A KRPC fuses curves are not intersecting. 11/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/19/2021 Amended Plans :AB20 1 of 4 Rev- 4, , AB20 2 of 4 Rev- 4, AB20 3 of 4 Rev- 4, AB20 4 of 4 Rev- 2, FP20 1 of 1 Rev- 5,GB20 1 of 1 Rev- 2, SB20 1 of 4 Rev- 6, SB20 2 of 4 Rev- 7, SB20 3 of 4 Rev- 8, SB20 4 of 4 Rev- 5, SB21 1 of 2 Rev- 2 & SB21 2 of 2 Rev- 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55888	19A0156	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>3/14/19 - 1. Remove bonding from "CL-SW" switch. 2. Confirm that service room is 2HR fire rated. 3. Comply with 408.36 for "Garage panel". 4. New 200A "TW-SW" service switch is included within coordination study & not shown in EAB one line dwg. 5. Vertical busbar in main "MSB" switchboard in section #6 is undersized. 3/20/19 - Pending. 5/6/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/8/20 Swap Dwg # sheet 1 rev. 2, sheet 2 rev. 2, sheet 3 rev. 2</p> <p>Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/6/2020 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55961	19A0157	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide asbestos abatement compliance required document. 2) Provide bonding & grounding to main service swbd. 3) Provide N.D.L to SS #3 & 4. 4) Provide signage to inform that F.P s.sw is in the fire pump room.</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/25/2019 1) Added steel grating lacks req. dedicated work space. 2) Extend or widen the steps / provide fall protection. 3) Verify req. dedicated work space depth in front of distribution eq. 5/28/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/24/2023 Amended Plan # 1 Rev- 2,# 2 Rev- 1 and # 3 Rev- 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55915	19A0161	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) GEC of s. sw #6 (supplemental ground) is undersized. 2) Confirm having approved special permission for not grouping service switches in one room. 3) Provide available s.c current at new 400A & 600A panels and verify if AIC rating of 400A ss #5 is more than available s.c current. 4) Verify if there is dwg #1 of 2 and provide it if yes and clarify cut sheet of 250A panel. 5) Provide asbestos abatement compliance doc. 6) Confirm 5' clearance in front of ss #5. 7) Clarify the termination of 22 sets per phase at the CT. 8) Clarify incoming service cond. Size from CT feeding new ss #6 is 500 MCM or 350 MCM. 5/20/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	19A0163	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>3/13/19 OR 1) Comply with 230.72. 2) Provide Asbestos Abatement compliance document.</p>				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55908	19A0164	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Provide busbar size connected to SS#5. 2. New copper detail from SS#2 to new tap is undersized and show physical detail of this connection. 4/25/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/16/19 Swap dwg A-Revision 2, dwg B-Revision 0 and dwb c-Revision 1.				
55806	19A0167	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/13/19 - 1. Verify project address for dwg & asbestos document doesn't match address of the submittal. 3/20/19 - Pending. 3/27/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55794	19A0168	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55788	19A0169	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 3/13/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55799	19A0170	Requesting SP for 1000V PV equipment	Approved	\$0.00
with stipulation installation and inspection of the 1000V PV system shall be in accordance with 2014 NEC, Article 690. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55830	19A0172	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide available s.c. current at new "DP-1" . 4/22/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/8/2021 Amended Plans# A, B & C Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	19A0173	Requesting SP to keep shared emergency and normal power circuits for new installation in the same raceways and enclosure.	Denied	\$0.00
56042	19A0174	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination between 1200A Br. and downstream fuse 800A KLPC. 2) Provide conductors feed "ELP-G", "ELP-G1" "DP-Elv-R" & time warner off ATs & and/or service switch. 3) Clarify using 3P or 4P ATs and confirm using neutral to elev- panel.</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/29/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.2/25/2022 Amended Plans # A.2 & B.2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/17/2022 Amended Plan # B Rev-4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55793	19A0175	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55792	19A0176	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/23/19 Swap dwg 1-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/11/2020 Swap drawings # A Rev # 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 6/16/2020 Swap drawings # 1 REV3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55790	19A0178	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
56127	19A0179	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Emergency side of F.P. conductor undersized (page (page 4 of 5). 2) Provide coordination study with the stipulation: review serviceability requirement of emergency electrical feeders per NYC building code. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/30/19 1) Comply with 215.10 for all OCPD above 1000 A at 480 V - Dwg 4 of 5. 2) Comments #2 is not addressed. 3) Fire Pump "FPL" OCPD -normal side- is undersized - Dwg 4 of 5. 4) ATS - Hotel - LR "Amperage rating is undersized - Dwg 4 of 5. 9/23/19 1) Comment #3 from last revision is not addressed. -FIA of Table 430.250 shall be used. 2) Provided coordination study is incomplete. 3) Physical doesn't match one line. 10/25/2019 1) The TCCs are missing the sign & seal. 11/25/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	19A0180	Requesting a SP install ATSs with new service equipment.	Denied	\$0.00

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0183	Requesting a SP to relocate a portion of 5kV cable	Denied	\$350.00
. Special permission is not required or applicable to the request.				
56045	19A0185	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1. Provide coordination & short circuit study signed & sealed by P.E. 2. Provide available S.C. current at F.P. controller & all ATSS. 8/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/27/2021 Amended plans# A & B Rev 2 .</p> <p>Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56039	19A0186	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>3/13/19 - 1. Show grounding of co gen & transformer on the dwg. 2. Provide equipment cuts. 3. Confirm that available S.C. current at new 'SBDP' is less than it's AIC rating (65kA). 4. Provide asbestos abatement compliance doc. 3/20/19 - Pending. 7/26/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/21/20 Swap Dwg # A rev.7 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
	19A0187	Requesting SP to keep line voltage and low voltage shared in the same enclosure	Denied	\$350.00

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
56094	19A0188	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/13/19 - With stipulation 2HR fire rated for service room new wall. Confirm compliance with 695.3(A) 10/1/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56138	19A0189	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance doc. 2) Cond. feeds new "ADS" panel is undersized. 3) Provide conductor size between sections in "ADS" panel & provide cut sheet for new panel. 4) Provide coordination between new fuses in "ADS" and upstream fuse signed & sealed by P.E. 11/14/19 1) Item #4 from last revision was not addressed. 2) Confirm NRTL listing of retrofitted panel "DB-2". 3) Confirm panel "ADS" after 2nd level of OCPD with stipulation the trim cover shall be provided with provisions to cover all gaps and/or set backs from the surface or edge of finished wall. 12/18/19 This drawing is approved with the stipulation that the retrofitted panel to be field evaluated & listed by an OSHA recognized NRTL bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report to be kept on site for inspector's review. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/19/2020 Amended Dwgs# D1 & D2 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
	19A0190	Requesting a SP to approve a replacement to failed busway section without NRTL approval	Denied	\$350.00
55906	19A0191	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify stand by cannot feed life safety loads. 2) Provide sight specific sequence of operation of system. 3) Provide cogen cuts. 4) Provide NRTL listing.. 4/25/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/3/19 Swap Dwg # A031901 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/9/19 Swap Dwg # A031901 Rev 3.1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55897	19A0192	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 3/15/19 1) Provide approval/submittal for existing equipment. 5/9/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
56208	19A0194	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - 1) Service cond feeds SS#5 (1200A) is undersized.</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>2) Provide available S.C current at point of entry and provide short circuit study to all new equipment. 3) Provide equipment cuts. 4) Provide asbestos abatement compliance doc. 3/30/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 6/7/2021 Amended Plan# 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/18/2021 Amended plan# 1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55884	19A0196	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide asbestos abatement compliance doc. 2) Provide existing service bus bar size on the line side of existing ss#1. 3) Provide AIC rating for new equipment and available S.C current. 4) Confirm that there are no more than six service switches. 5/3/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/21/19 Swap Dwg # D-1902-31213-A Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55791	19A0197	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer 9/16/2019 Swap Dwg # AB-19383-B.1 Rev-1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/2/2020 Amended Dwgs# 1 & 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/22/2020 Amended plans # 1 & 2 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				
55800	19A0198	Requesting SP to install retrofit kits in existing enclosures.	Approved	\$350.00
with stipulation installation of trim shall comply with sections 214.20 and 214.21.				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0199	Requesting a SP to keep equipment non-complying clearances as required by 110.26.	On Hold	\$350.00
Additional documentation is required				
56210	19A0203	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump GEC is undersized -250.66 2) Provide cut sheet of "EDB1" & "EDB2"</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/7/19 1) Fire Pump GEC within the incoming service conductors feed the fire pump service sw is #4 Cu GND and is undersized as per T250.66 7/2/19 - 1. Provide ground conductor per table 250.66 for ATS #2. 7/2/19 1) Provide ground conductor per Table 250.66 for ATS #2. 6/2/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
55917	19A0204	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/13/19 OR 1) Provide asbestos abatement compliance document 5/20/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55785	19A0205	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 3/14/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
55885	19A0206	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance doc. 2) Confirm service room is 2 HR fire rated. 5/3/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/2/2020 Amended Dwg # 1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55789	19A0207	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/17/2022 Amended Plans# 1&2 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55950	19A0208	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Confirm if replacing existing ss#6 with new same in like and kind in the same location and confirm if there was an approved special permission for not grouping service switches in one location. 4/25/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55786	19A0209	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 3/13/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/19/19 Swap Dwg rev 1.				
55795	19A0210	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/26/2021 Amended Plan # 1,2 & 3 Rev-1.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/29/2021 Amended Dwgs# 1 , 2, & 3 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

March 20, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0211	Requesting a SP to approve PLFA above 8 ft. in mechanical space in free air.	Denied	\$350.00
	19A0212	Requesting a SP to approve PLFA above 8 ft. in mechanical space in free air.	Denied	\$350.00