

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54365	15A0720CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from December 16, 2015 meeting. Equipment cut sheet do not show rear doors, layout drawing doesn't match manufacturer's cut sheets. 2/7/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54016	16A0003	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Indicate breaker size for CB 5-F1, and CB2--F1. 2) Correct GF sensors representation between oneline and the schematic. Rejected, Item #2 not addressed. 7/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/27/18 - swap dwg # 1 of 4 Rev 3 7/27/18 Swap dwg # 1 of 4 Rev 4 5/1/19 1) Provide 2nd copy of as built drawings. 2) Mark new changes to the dwg with new triangle for the new revision number. 6/5/19 - Swap dwg # 1 of 4 Rev-5, 2 of 4 Rev-1.				
53916	16A0017CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from February 10, 2016 meeting. 1) Equipment grounding conductor supplying fire pump undersized. 2) The emergency system must selectively coordinate. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/23/16 revision number is not correct (Rev 3 instead of Rev 2). 1/11/17 Swapped drawing 2 of 3-Revision 3.				
	16A0020CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from March 9, 2016 meeting. 1) Fire alarm service switch to be fed from load side of CT not ATS. 2) All ATS' rated at 50,000 withstand rating with 180,000 incoming verify ratings. 3) Provide physical showing barriers in the twin 4000 amp switches. 4) Show fault current at devices on 1 Line. 5) GTB the breaker to be 4 pole type.				
	16A0021CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from January 13, 2016 meeting. 1) If MI cable is terminated to switch lugs provide manufacturer's installation instructions for MI cable 2) MI transition conductors sizes and wiring methods not shown .. 3) Main bonding jumper undersized. 4) Coordination study has seven point that must be addressed and coordinated. 5) Elev-PH2-1 must coordinate normal and emergency sides as per Article 620.				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53938	16A0026CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from February 10, 2016 meeting. 1) Verify that Time Warner service switch complies with 110.26(A)(2). 2) Identify fire pump transformer in service room. 3) DP-Gen panel undersized for parallel generators. 4) Fire pump to be identified as fire pump not special service fire pump. 5) Short circuit study does not show full curves. 6) Emergency system for elevators, exit signs voice communications required. 6/27/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/7/18 1) Provide 7' clearance in front of ss# 1 and 2 in "MS-C" dwg #B. 2) Cond. between sections of "TDP-A2" panel is undersized. 7/27/18 Swap dwg A & G4-Rev 7; B & G1-Rev 8; C & F-Rev-5; E & G2-Rev 6; G3-Rev 10 and D-Rev 4. 10/7/2019 Swap Dwg D-1511-27249-G4 Rev 8 and D-1511-27249-B Rev 10. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
	16A0027	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1.Dwg K feeder to Switchboard – RI- FP undersized 2.Swbd – em over fused , dwg K 3.F.A. Transformer tap length not shown, dwg K 4.Dwg K does not indicate feeders are installed in fire rated enclosure 5.Dwg K does not show 600 amp fire pump switch or feeder 6.Show bus size on 4000 amp on Substation 1 & where is it located 7.Switch board RI has more than 6 service switches 8.Future switch boards to be identified on room layout 9.Show substation room layout with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53928	16A0058CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from February 10, 2016 meeting. 1) Verify 2 sets 500 MI to fire pump. 2) Verify amount of conductors between sections of EMDB panel. 3) Verify that no tails will be used for 4/0 MI conductors. 6/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/28/18 Swap dwg 1-Revision 3 and Dwg 3-Revision 3. 11/28/18 Swap Dwgs 1,2 and 3-Revision 4.</p>				
53830	16A0073	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1.Fire Pump & Fire Alarm service switches not shown on room layout 2.If fire alarm service switch is mounted undet its trans 5' front clearance is required 3.Verify 5' front clearance in front of 5 KV switch FP40-1 4.AB 20 – 1 – typo retail trough trans identified as Fire Alarm Trans S 5.AB 20 – 1 – verify that no cable support boxes for service entrance conductors will be installed 6.Transformer primary conductors undersized for 750 KVA transformers 7.Coordination study, signed, sealed and performed by a P.E. not provided. 5/23/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 7/3/18 - swap dwg AB20 - 1 of 6 & 4 Rev 3, AB20 - 5 of 6 Rev 1 7/17/18 1) Remove bonding from F.A. sw emergency side dwg #AB20- 6 of 6. 2) Provide tap length for life safety load switch dwg #AB20 6 of 6. 3) verify that breaker type used in new "EDP-Gen" is same as in coordination study 1/22/2020 1) Items from last revision were not addressed. 6/18/2020 Amended dwgs 22412AB20-01 of 6- Rev 5, 22412AB20-02 of 6- Rev 3, 22412AB20-03 of 6- Rev 3, 22412AB20-04 of 6- Rev 4, 22412AB20-05 of 6- Rev 1, 22412AB20-06 of 6- Rev 4 , 22412FP20-01 of 3- Rev 4, 22412FP20-02 of 3- Rev 2, 22412FP20-03 of 3- Rev 3,,22412FP40-01 of 1- Rev 7, 22412SB40-01 of 2- Rev 6,, 22412SB40-02 of 2- Rev 1, 22412SB80-01 of 4- Rev 4, 22412SB80-02 of 4- Rev 2, 22412SB80-03 of 4- Rev 1, 22412SB80-04 of 4- Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/20/2020 1) MV cables are undersized as per tables 310.60 (C) , see mark up plans for more details. 2) Confirm Compliance with 110.14(C) if using 105® F rating for conductors ampacity. 8/3/2020 Amended Dwgs# AB20 - 1 of 6 Rev 5, AB20- 2 of 6 Rev 5, AB20- 3 of 6 Rev 5, AB20- 4 of 6 Rev 6, AB20- 5 of 6 Rev 1, AB20- 6 of 6 Rev 4, FP20- 1 of 3 Rev 4, FP20- 2 of 3 Rev 2, FP20- 3 of 3 Rev 3, FP40- 1 of 1 Rev 8, FP40- 1 of 1 Rev 8, SB40- 1 of 2 Rev 6, SB40- 2 of 2 Rev 1, SB80- 1 of 4 Rev 5, SB80- 2 of 4 Rev 3, SB80- 3 of 4 Rev 2, SB80- 4 of 4 Rev 5, PB20- 18 of 33 Rev 7 and PB20- 19 of 33 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
	16A0106	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Length of transformer secondary's not shown, DWG 1. 2) Emergency side EGC to panel "PPELR" undersized, Dwg 1. 3) Show short circuit current at fire pump, DWG 1. 4) Main 2 and 3 cond undersized, DWG 1. 5) Verify connector of 1200 amp switch on load side of Main 1, DWG 1. 6) DWG 2, length of transformer secondary's not shown. 7) EGC undersized on load side of DRRB main, and transformer. 8) F.A. transformer secondary is not protected. 9) Show coordination between s.s. and 1600 cb, and 1600A cb and meters. 10) Gen voltage has discrepancy.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53911	16A0107	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>I. Block off rear of switch board with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	16A0108	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>I. Fire Alarm ATS and their emergency feeders shall not be located in the same room with the service equipment with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54534	16A0119	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Emergency feeder to ED-DSFP-S2(B) undersized. 2) Verify that compact conductors will be used to feed switchboard. 3) Verify that 5000 amp generators switchboards are listed. 4) Equipment grounding conductors on load side of 5000 amp switches with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/28/16 Denied. 1) Emergency feeders to fire pumps fused 3 times. 2) Provide submission or approval # for normal fire pump feeders. 3) Show normal feeders to fire pumps or approval # from others with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/9/17 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
	16A0129CO	Requested approval for the electric service equipment proposed to be installed	Rejected	\$0.00
<p>Carry over from February 10, 2016 meeting. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/27/18 1) Vertical bus in 'TDP-AZ' panel Section #2 is undersized.-Dwg "G1".</p>				
53627	16A0178	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53915	16A0181CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from March 9, 2016 meeting. Fire alarm emergency side EGC undersized. To ATS. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53657	16A0187	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0196	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) No coordination study. 2) Indicate the special permission or showhow complied with. 3) Show the co-gen protection and room layout with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
53908	16A0201CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from March 9, 2016 meeting. New SS and distribution are mislabeled. 6/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/26/16 Swapped drawings 1 and 2-Revision 3s.				
53633	16A0204	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/4/18 Swap dwg A-Revision 2, Dwg B-Revision 6/4/18 Swap dwg A-Revision 2, Dwg B-Revision 3				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53658	16A0210	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/3/16 Swapped drawing 1-Revision 1. 2/6/17 Swapped drawing 1-Revision 2. 2/16/17 swap dwg 1 rev 3. No More Swap				
53628	16A0213	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/17/17 - swapped dwg 1 revision 6/30/17 - swap dwg- A20 with rev 2				
53634	16A0216	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0232	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Bus on load side of 4000 amps to be 800 amps square inch for the first 4', 1 Line does not match physical. 2) Explain panel "PPR" between fire pump service switch and fire pump. 3) Fire pump feeders not fire rated. 4) Fire pump equipment ground undersized normal side. 5) Feeder and conduit size to load bank not shown. 6) Equipment grounding conductor to generator distribution panel undersized. 7) Equipment grounding conductor to service switch #2 undersized with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
	16A0245	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1. Not in Advisory Board format</p> <p>2. Verify MI Cables, Feeders</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53632	16A0246	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53844	16A0247	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Panel MDP 10' tap rule exceeded. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. This submittal voids out 52758. 5/25/16 Job finalized.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53629	16A0248	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54029	16A0249	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Fire pump feeder to be fire rated with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/1/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 8/28/17 - swap dwgs 1,2, & 3 rev 1</p>				
53917	16A0252	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump service entrance conductors, service switch, emergency switch and feeders undersized. 2) Tapped conductors undersized. 3) Emergency side EGC for tapped conductors undersized. 4) Fire alarm SEC feeders on normal and emergency sides overfused. Check voltage drop for "bar" panel located on 14th floor. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/1/17 - swap dwg 1 & 2 rev 2 12/18/17- Remove bonding from Gen neutral & fix No. of wires from Gen. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/5/18 - Swap dwg # 2 & 3 Rev 4 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53659	16A0254	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53609	16A0256	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
54059	16A0257	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Move new equipment against wall to provide better access around switchboard. 2) Equipment grounding conductor for service entrance conductors undersized. 8/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53937	16A0259	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Block space between equipment. 6/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/16 Swapped drawing FP-01-Revision 2. 3/22/2017 - F.A. Enclosure to be 2hr fire rated.9/12/17 - swap dwg FP50- 1 pf 1 rev 4 , AB50 1 of 1 rev 2				
53927	16A0260	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Fire pump emergency fusing undersized. 2) Provide 1 Line coordination drawing. 3) Address discrepancies on short circuit study. 4) Add note that ATS' do not supply life safety loads with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for. 10/29/18 Swap Dwg #2 of 6 and 1 of 6-Revision 4. 5/24/19 - Swap dwg #1, 2, & 6 Rev-5. 7/19/2019 Swap Dwg # SSL-10412-2 Rev-6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53630	16A0261	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53631	16A0262	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53904	16A0263	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Switchboard MDP-1 section bus undersized where new 1200 amp switch is installed. 6/14/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53626	16A0264	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/20/16 Swapped Drawing 1-Revision1.				
53614	16A0265	Requesting permission to install Schedule 80 non-metallic conduit as a wiring method for overhead services conductors and branch circuit wiring in a corrosive area close to the water front in Far Rockaway, Queens for 12 two family homes..	Approved	\$0.00
62-07, 62-03, 62-13, 62.-15, 62-19, 62-21, 62-25, 62-27, 62-31, 62-33, 62-39 and 62-43 Decosta Avenue, Far Rockaway, Queens Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53660	16A0266	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/20/18 Dwg A-Revision 3; dwg D-Revision 4 and dwg E-Revision 5. 4/18/19 Swap Dwgs A-Rev 4; B-Rev 5; C-Rev-5; D-Rev 5 and E-Rev 6				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0267	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR 1) There is no 3000 amp switch on Approval #53466. 2) Bonding and grounding to comply with 250.32(B). 3) Electrical equipment room to be ventilated. 4) Tap conductor to 800A disconnect switch undersized. 5) Secondary of 300 KVA transformer not bonding and grounding.				
	16A0268	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR 1) There is no 2500 amp switch on Approval #53466. 2) Bonding and grounding to comply with 250.32(B). 7/27/18				
53661	16A0269	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/1/18 -Swap dwg #1 and 2-Revision 1.				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53918	16A0271	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Correct ground at Gen emergency board with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.16A The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/20/16 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/30/16 Rejected 1) When is 40 HP fire pjp splice box located, 3M interam mat cannot be used to wrap individual conductors. Note not clear (cable?). Fire pump splice not 2 hour fire rated. 2) Coordination study to be updated reflecting changes. 3) Explain comment 1A. 2/10/17 - 1. 3m interam mat (endothermic mat) not listed for the purpose intended 2. Item 2 not addmended-show ss # 2,3,4 and 6 & 2nd fusing 8/24/17 - Item # 1 & 2 not addressed. 12/4/18 1) Provide 4 pole ATS to F.A.-for neural will be bonded twice in case using emergency side with 3 pole ATS. 2) Coordination study one line doesn't match EAB one line drawing with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code and Fire Rated Enclosure's must comply with the following: 5/9/19 Swap dwg # 1 of 2-Revision 5 and dwg 2 of 2-Revision 4 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code</p> <p>1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 8/21/19 1) Provide coordination study. 10/29/19 Swap Dwg # LNY0014914-SH1-OL 1 of 2 Rev 6 and SH2--PD 2 of 2 Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/22/2020 Amended Dwgs # 1-Rev 7 and 2-Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53615	16A0273	Requesting permission to leave as installed service equipment mounted on the outside of a building that was replaced due to flooding from hurricane Sandy where the old service was located in a 4' crawl space subject to flooding..	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53641	16A0274	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/24/16 Swapped drawing 1-Revision 1				
	16A0276	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1.Approval #15A0735 is Denied</p> <p>2.Switch Sizes & over current devices feeders equipment for this submittal not shown on this drawing</p> <p>3.MOS-2 middle section switch & fuse size not shown</p> <p>4.Show length of transformer secondary taps for A2 & B2</p> <p>5.Transformer secondary's do not comply with tap rules</p> <p>6.Transformer A2 conductors & conduits not shown</p> <p>7.Fire alarm to be tapped ahead of service switched</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53926	16A0277	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that rear doors of paralleling switchgear can fully open with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the North field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Fire alarm panel to have 3' front clearance. 3) AB50-2 #6 tap conductors undersized for 25' taps. 4) Address the double neutral return on the double ended substation. 6/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53646	16A0278	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53654	16A0279	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/21/16 Swapped drawings AB sheets 1 and 2-Revision 3. FP-Revision 1. SB sheets 1,2,3 and 4-Revision 2s. 5/17/2017 - swap dwg # FP20-01 of 1 rev-2 12/20/2019 Swap 22533 AB20-01 of 2 R4, -02 of 2 R4, FP20-01 of 1 R3, SB20-03 of 5 R3, -04 of 5 R3, -05 of 5 R0. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
53662	16A0281	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53951	16A0282	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1.MSB - Service entrance conductors and service Bus from Con-Ed box to first section containing 1200 & 800 amp service switches under sized 2.Provide cut sheets of meter banks & breakers. 6/28//16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/5/18 1) Comply with 695.4(B)(3)(4). 4/30/18 - swap dwg # 1 of 1 Rev 2				
53663	16A0283	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawing 1-Revision 1. 2/5/19 Swap Dwg 1- rev2				
	16A0284	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
OR 1) New loads can't be connected to a switch containing fuse links. 2) Show coordination between first and second fusing. 3) Incoming short circuit current not shown, 4/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/24/17 This submittal is void in lieu of submittal number 17A0155.				
53664	16A0285	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/15/17 - swap dwg B Rev 9 7/24/18 - swap dwg B Rev 9				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53934	16A0287	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1.ATS - SDP to be 4 Pole with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/23/ 16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
54020	16A0288	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) MI cable for fire pump undersized. 2) Show detail of how MI cable will be transitioned into ATS and service switch and emergency disconnect switch. 4) Correct typo in ATS supplng DP-OSB with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/19/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	16A0291	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1. Water damage equipment to be replaced or tested by an NETA certified Testing Agency and witnessed by a P.E. who will Sign, Stamp the test report 2.Is the existing equipment manufactured by Lincoln Electric</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0293	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Identify service switches in service room. 2) Service switch clearances to comply with 230.64(B)(1). 3) Verify that the utility is supplying 10 sets of service laterals. 4) Fire pump wiring methods not shown. 5) Fire pump fire rated conductors to be installed as per manufacturer's installation instructions. 6) Verify fire pump fire rated conductors to service switch. 7) Fire pump service entrance conductors and feeders undersized. 8) Neutral in 30 amp F.A. switch not bonded to enclosure. 9) Remove 2nd 30 amp F.A. switch on emergency side. 10) Lengths of taps not shown. 11) Tap conductor undersized. 12) Verify bus sizes in switchboard with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
	16A0294	Requested approval for the electric service equipment proposed to be installed - Joint Venture with AECOM	On Hold	\$650.00
53948	16A0295	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Secondary of transformer to be grounded SEC. 2) 1200 amp 480 volt switch to be ground fault type. 3) Bus feeding 2000 amp service switch undersized.. 4) 2000A S.S. GCE and water/supplemental. 5/25/16 Rejected 1) Secondary of transformer to be bonded and grounded in one location not two. 2) Item #3 not addressed. 3) Equipment grounding conductor to transformer undersized. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53665	16A0297	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/17/17 - swap dwg # ACS-D-12213-1 Rev 1. ACS-D-12213-2 Rev 1 3/23/18 - swap dwg 1 Rev 2, Dwg 2 Rev 2</p>				
53635	16A0299	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53923	16A0300	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Service Bus feeding 2000 & 400amp service switcher undersized. 6/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/25/16 Swapped drawings 1, 2, & 3-Revision 2s. 5/9/2017 - swap dwgs 1,2,&3 rev 3's				
53924	16A0301	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Fire pump feeder not fire rated with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/21/16 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53666	16A0302	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/14/16 Swapped Drawing 1 and 2-Revision 1.				
53775	16A0304	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. TAP Conductor to 100 amp disconnect switch under sized. 4/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53668	16A0305	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/20/16 Swapped drawings 1,2 and 3-Revision 1s.				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53669	16A0306	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/6/19 Swap Dwgs 1,2,3 rev3				
53644	16A0307	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54987	16A0308	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/5/17 - Contractor Name Change 1) Show clearance in front of new pull box in service room and indicate the height of pull box. 2) Fire rated fire pump conductors not installed as per manufacturer's installation instructions. 3) Fire pump emergency conductors and wiring method not shown. 4) Switchboard 1 Line does not match physical with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/20/16 Rejected 1) Fire alarm ATS not to be installed in the main service room. 2) Fire rated conductors not installed as per manufacturer's installation instructions. 3) Pole ATS installed on a non separately derived system for fire alarm with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code 10/6/17 - 1) Provide equipment ground conductor for NM & EM side of FP controller. 2) Remove ground fault protection from SS# 3) Provide supplemental ground for all service switch. 4) Provide fuse coordination between "3000A A4BQ" service switch and downstream "2000A ASBQ" fuse. 5) Service entrance conductor undersize for FA service switch. 6) Provide equipment ground conductor at all location where PVC conduits is used. 7) Show note at generator state that "Not a separately derived system". 1/19/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/1/2021 Amended Plan # 16338 Rev- 3.. Received notarized letter stating changed name of contractor. 3/8/2023 Amended plan # 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/31/2023 Amended Plan# 16338 Rev-5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53953	16A0310	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) MDP-C-H fuses don't coordinate with 1200 amp main fuse. 2) S.S. #2-1600 amp fuse does not coordinate with 600 amp fuse in MDP-2-HA with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/1/17 - swap dwg 2 rev 3 2/5/18 - 1) F.P. cond is undersized 2) Provide vertical bus size in MDP-2-HA switchboard section (2) 3/1/18 - swap dwg AB-16117 A4, AB-16117 B5</p>				
53772	16A0312	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/30/16 Swapped drawings 1,2 and 3-Revision 3s. 2/3/17 swapped dwg's 1,2,&3 revisions 4's</p>				
53640	16A0313	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53639	16A0314	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53637	16A0315	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53906	16A0317	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Service room doors to open outwards. 6/14/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/24/17 Swapped drawing #A-Revision 3. 8/1/17 - swap dwg B & C with rev 2				
53903	16A0318	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Service bus feeding 1200 amp SS and fire pump undersized. 2) Show bonding and grounding of 600 amp service switch. 6/14/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53914	16A0319	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Fire Alarm ATS to be 4 pole type with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/20/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/23/18 - 1) Neutral conductor for normal side of "150A ASCO ATS" ATS SS# tap before N.D.L. 2) Verify EM generator is separately derived or not, if not remove neutral bonding from generator. 3) Confirm FA ATS (ASCO 150A) is 3P or 4P 3/23/18 - swap dwg A, B & C</p>				
53851	16A0322	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Generator Feeders & Distribution Panel over fused</p> <p>2. Section Bus Undersized. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53843	16A0324	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) One line doesn't match physical sections 1 and 2. 2) Rear of switchboard to comply with 230.64(B)(4). 5/25/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/22/18 - swap dwg A Rev 4, Dwg B & C Rev 2. 10/31/19 Swap Dwg C rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/19/2020 Amended Dwgs # A Rev 6 and C Rev 8 . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
53955	16A0325	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Service Switchboard #4 show tap method for 3 sets of 600 KCM to 6 sets of 500 KCM to Panel DP-R 2. Verify that service Bus complies with Section 368.119 3. Verify set of conductors between panel DP-R, 1 line and physical don't match with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/15/15 Swapped Drawings A-Revision 3; Drawing C-Revision 3; Drawing D-Revision 3 and Drawing E-Revision 4. 12/15/17 - Address Change Swap dwg A Rev 5, B Rev 3, C Rev 4, D Rev 5, E Rev 6</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0326	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) 1 Line doesn't match physical or room layout (MD5-2). 2) Fire pump wires are undersized and shall be fire rated. 3) Remove purge panel from F.A. ATS and load. 4) Coordination study is not provided with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/22/16 Denied 1) Item #4 not addressed. 2) wiring method for special service fire pump not shown. 3) Verify bus size to service switches #3 and #6. 4) Verify conductor type to panel DP-2 and # of conduits. 5) Conductors to EDP-2, panel overfused. 6) Provide conductor spec's for type EDPM conductor. 8) Fire pump service switch to be provided with neutral conductors to be bonded and grounded - Review stopped. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer 				
53935	16A0327	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1,500 KVA Transformer secondary to be bonded & grounded in one location with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/16 Swapped drawing 1-Revision 3 10/6/17 - swap dwg# 16314 Rev 4, 16314-2 rev 4 & 16314-4 rev 4. 12/24/18 Swap dwg #16314-1, 16314-2 and 16314-3-Revision 5.</p>				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54554	16A0329	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Bonding, grounding, neutral link not shown on existing service. 2) Tap conductor to new 400 amp switch undersized. 5/19/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/31/17 - swap dwg 1 & 2 rev 1				
54312	16A0330	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Verify Bus sizes to 1600 amp service switch 2. Show Bus Size on line side of 3000 amps service switch 3. Provide coordination study per formed, signed, sealed by a P.E. for emergency System 4. Verify Fire Rated Door for Emergency Room</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/25/16 Coordination study need to be signed and sealed by a P.E. 1/5/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53645	16A0331	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53647	16A0335	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53653	16A0336	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
SANDY Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53638	16A0337	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53643	16A0338	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53770	16A0339	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53636	16A0340	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53771	16A0341	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/21/17 - Swap dwg 1 Rev 1 5/15/19 Swap dwg 1-Revision 2.				
53648	16A0342	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Note: 5/23/17 Former Contractor was Phasepoint Electrical/ See Email: OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

April 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53649	16A0343	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR With the stipulation that SE20KUS Solar Gage three phase inverters can be installed. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0344	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) Drawing not in Advisory Board format. 2) Is any bus work being installed in service switch. 3) Contractors name to be in title block. 4) Who is Solar One?				
53642	16A0347	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				