

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49905CO	10A0013CO	Naber Electric Corp. 350 5th Avenue, Suite 3304 New York NY 10118	Requested approval for the electric service equipment proposed to be installed	Carnaise Plaza Avenue D & East 89th Street Brooklyn NY	Approved	\$0.00
Carry over from January 13, 2010 meeting. 1) Provide conductor sizes in outdoor switchgear. 2) Transformer grounds to be terminated to interior grounding system. 3) Fence in outdoor equipment and ground fence to grounding grid. Job finalized 6/2/10.						
49958CO2	10A0059CO2	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	106-21 Beach Channel Drive Rockaway NY	Approved	\$0.00
Carry over from March 17, 2010 meeting. Show coordination between 1600 amp main and 1600 amp secondary breakers. Special permission needed. Job finalized 7/26/10.						
50014CO	10A0098CO	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Lincoln Medical Center 234 East 149th Street Bronx NY	Hold	\$0.00
Carry over from March 17, 2010 meeting.						
50034	10A0104	Compsec Electric Corporation 27-01 41st Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	5-19 Borden Avenue Queens NY	Approved	\$650.00
1) Main bonding jumper in Con-Ed box undersized. 2) FP service feeder include neutral. Job finalized 6/3/10.						
50035	10A0105	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Americana Apartments 17-85 215 Street Bayside NY	Hold	\$650.00
1) Transformer secondaries to be bonded and grounded in one location not two, 2) Provide cuts for utility protection panels as noted. 3) Provide sequence of operation.						

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50036	10A0106	Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	NYU-Tisch School of Arts 111-113 Second Avenue New York NY	Hold	\$650.00
Access to vertical trough is blocked.						
50037	10A0107	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	75 Clinton Street Brooklyn NY	Hold	\$650.00
1) Fire pump feeder undersized. 2) Neutrals in service switches to be connected to grounding electrode conductor. 3) Provide short circuit calculations for meter banks and existing Rite Aid panel. 4) Service conductors undersized from end box to bus detail.						
50038	10A0108	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	1192 Park Avenue New York NY	Approved	\$650.00
50039	10A0109	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1700 Grand Concourse Bronx NY	Approved	\$650.00
50040	10A0110	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Binday Residence 11 Riverside Drive New York NY	Ok, but	\$650.00
Reduce fuse to 3000A to conform w/bus rating.						

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50041	10A0111	Jusler Electrical Corporation 26-16 Skillman Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 701 West 168th Street New York NY	Approved	\$650.00
50042	10A0112	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Pet Smart Store 517 East 117th Street New York NY	Approved	\$650.00
50043	10A0113	Heso Electrical Inc. 33-06 Ditmars Blvd. Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Hill Country Chicken 1123 Broadway New York NY	Approved	\$650.00
50044	10A0114	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NYU-Bobst Library 60 Washington Square South New York NY	Approved	\$650.00
Inadequate clearance in front of new FP SS. Job finalized 6/3/10.						
50045	10A0115	Kings Electric Co., Inc. 2113 West 6th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	63-38 99th Street Queens NY	Ok, but	\$650.00
Indicate feeder size to trough						

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50046	10A0116	Compsec Electric Corporation 27-01 41st Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	303 10th Avenue New York NY	Approved	\$650.00
Grounding electrode conductor for SS #1 undersized. Job finalized 6/3/10.						
50047	10A0117	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	East River Science Park 450 East 29th Street New York NY	Approved	\$650.00
50048	10A0118	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	72-06 Northern Blvd. Queens NY	Approved	\$650.00
1) Service entrance conductors and feeders are undersized on 1200 amp service switch. 2) Verify feeders on load side of 600 am disconnect switch. 3) Show size of tapped conductors feeding meter pans and disconnect switches and fuse types. 4) Correct lug size on SEB for SS# 4. 4/23/14 Job finalized.						
50049	10A0119	J.J. Rosenberg Electrical Contrs, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	1400 Broadway New York NY	Approved	\$650.00
1) Grounding electrode conductor terminal not shown, drawing c. 2) 2500 amp service switch #2 fed w/5 sets of 500 MCM on drawing B. 3) Confirm use of 15KV switches for service 'c' transformer if used label as "operating at 5KV". 4) Confirm clearance is adequate in front of 5KV switch in cellar. 5) Clarify 2nd substation on roof "spare" or "future". Job finalized 9/21/10.						
50050	10A0120	BGA Engineering, LLC 99 Bauer Drive Oakland NJ 07436	Requested approval for the electric service equipment proposed to be installed	506 East 75th Street New York NY	Ok, but	\$650.00
Coordinate single lines.						

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50051	10A0121	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	Isabella Geriatric Center 525 Audobon Avenue New York NY	Approved	\$650.00
Explain why generator neutral bonded. Job finalized 9/20/10.						
50052	10A0122	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	2 West 45th Street New York NY	Approved	\$650.00
50053	10A0123	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	470 Vanderbilt Avenue Brooklyn NY	Administrative Closure	\$650.00
Are rear covers removable? This drawing voided see resubmitted drawing 50637.						
50054	10A0124	Rosselco, Inc. 988 Morris Park Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	1 Edgewater Plaza Staten Island NY	Approved	\$650.00
50055	10A0125	Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Hotel Indigo 127 West 28th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50056	10A0126	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1333 Broadway New York NY	Approved	\$650.00
50057	10A0127	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	71 Broadway New York NY	Approved	\$650.00
50058	10A0128	M & R Electl Contg and Repair Servs. Inc. 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	1825 Park Avenue New York NY	Approved	\$650.00
50059	10A0129	KGK Electric Corp. 50-01 25th Avenue, Suite #3 Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Desales Assisted Living 1261 Fifth Avenue New York NY	Approved	\$650.00
1) 4000 amp service switch overfused. 2) Bond neutral in service Switch #3. Job finalized 3/28/13.						
50060	10A0130	Cedar Electrical Contractors, Inc. 224 West 30th Street, Suite 202 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	641 6th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50061	10A0131	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Lincoln Square Synagogue 180 Amsterdam Avenue New York NY	Approved	\$650.00
10/14/14 Swapped A-Revision 4.						
50062	10A0132	Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street, 7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	HSBC Electrical Separation 452 Fifth Avenue New York NY	Approved	\$650.00
1) Bonding and grounding of existing board not shown. 2) Show how many sets of conductors are feeding switchboard and ATS board. Job finalized 6/7/10.						
50063	10A0133	Jartech Electrical Contracting Corporation 100 Hindsdale Street Brooklyn NY 11207	Requested approval for the electric service equipment proposed to be installed	228-06 Northern Blvd. Little Neck NY	Hold	\$650.00
1) Provide 2nd means of egress in service room. 2) Provide manufacturers cut sheet of MCC. 3) Coordination study not submitted. 4) If future generator is roll up type a fused disconnect switch must be provided. 5) Provide sequence of operation.						
50064	10A0134	Revma Electric, Inc. 2203 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	86-55 Queens Blvd East Elmhurst NY	Ok, but	\$650.00
1) Verify job address. 2) Verify that fire pump tap is not made in the switch section.						
50065	10A0135	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Battery Park Site 24 200 North End Avenue New York NY	Ok, but	\$650.00
1) Block off rear of board "MS-1-2". 2) Transformer secondary to be bonded in one location. 3) Fire pump branch circuit to be fire rated.						

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50066	10A0136	Kings Electric Co., Inc. 2113 West 6th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	37 Bridge Street Brooklyn NY	Approved	\$650.00
1) Panelboard HDP" not properly bonded and grounded. 2) Verify service entrance conductors to fire pump. 3) Verify fire pump branch circuit conductors. 4) Service entrances conductors to 1200 amp service switch are undersized. 5) AIC not provided. Job finalized 6/17/10.						
50067	10A0137	Hugh O Kane Electric Company, Inc. 90 White Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Nat'l September 11 Memorial New York NY	Denied	\$650.00
The submittal does not comply with the 2005 National Code and NYC Amendments or the Electrical Advisory Board rules.						
50068	10A0138	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Rockefeller University 1230 York Avenue New York NY	Hold	\$650.00
1) All new work to be bubbled on drawings. 2) provide generator cut sheets. 3) Fire pump service entrance neutral and EGC undersized. 4) Fire pump service switch undersized. 5) Fire pump FLA not shown. 6) Fire pump branch circuit not fire rated on normal and emergency sides. 7) Equipment grounding conductors throughout drawing undersized. 8) 1 set of 600 MCM fused at 800 amps. 9) Second fusing off of normal switchboard not shown. 10) Emergency board mislabeled.						
50069		Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requesting permission to install underground concrete encased service entrance conductors in non-metallic conduit	Hyatt Hotel Andaz 485 5th Avenue New York NY	Approved	\$0.00
50070		Dan O Leary, Licensed Electrician 177 Beach 116th Street, Suite G Rockaway Park NY 11694	Requesting permission to install overhead service entrance conductors in non metallic conduit in a corrosive area, Far Rockaway, Queens	442 Beach 144 St. Neponsit, NY, 43' Rockaway Point NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50071		Foster Electrical Service Inc. 1325 Foster Avenue Brooklyn NY 11230	Requesting permission to leave as installed AC cable that does not contain an insulated grounding conductor as a wiring method in a place of assembly	78-02 Roosevelt Avenue Queens NY	Approved	\$350.00
50072		Atkinson Koven Feinberg Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission on an existing partially installed 3000 amp fused parallel feeders ran in metallic wiring methods containing 3/0 equipment grounding conductors where the existing feeder will now be extended, to use and extend the existing 3/0 equipment grounding conductors on a job that was originally installed under the old NYC code.	111 8th Avenue New York NY	Approved	\$0.00
50073		Paul Verardi, Licensed Electrician 176 Canal Street Staten Island NY 10304	Requesting permission to install a outdoor service switch on a commercial building where there is no room on the other side of the wall to mount the switch indoors.	J & M Auto Collision 1341 Castleton Avenue Staten Island NY	Approved	\$0.00
with the stipulation that signage is posted at the buildings entrance indicating where the service switch is located.						
50074		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requesting permission to leave as installed service switches with a front clearance of 3' 10 1/2" on a 1000 KVA service installation.	Adams Houses 720 Westchester Avenue, Bldg. #3 Bronx NY	Denied	\$0.00
50075		Astro Electrical Contractors, Inc. 62-71 Dry Harbor Road Middle Village NY 11379	Requesting permission to install underground service entrance conductors in non metallic conduit, and due to the building having no common area to not group together the service switches where signage will be provided as per 230.2(e)	159-25 Cross Bay Blvd. Queens NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

April 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50076		H & L Electric Inc. 41-11 28th Street Long Island City NY	Requesting permission to replace a defective 5000 amp 480 volt service switch with new that will have ground fault protection.	New York Hilton Hotel 1335 6th Avenue New York NY	Approved	\$0.00
50077	10A0139	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Energy Manager. Model/Series Numbers: PT130		Approved	\$200.00
50078	10A0140	USI of North America, Inc. 565 Commerce Street Franklin Lakes NJ 07417	Requested approval for use in New York City of your Modulo Master 80.40.28.IS and Modulo Master 70.40.28.IS automobile refinishing equipment.		Approved	\$200.00