

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50373CO		Apollo Electric, Inc. 390 Manhattan Avenue New York NY 10026	Requested approval for the electric service equipment proposed to be installed	Veselka Bowery 9 East 1st Street New York NY	Approved	\$0.00
Carry over from December 22, 2010 meeting.						
50816CO3		Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	1717 Broadway New York NY	Hold	\$0.00
Carry over from March 14, 2012 meeting. 1) Explain fire resistant construction what is being used. 2) Generator frame to be grounded. 3) Transformer secondaries not bonded and grounded on drawing. 4) DP-EM-5A, verify which switches feed life safety and are all located in same switchboard Section, NEC 2008 code.						
50874CO4		Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	26th Ward Water Pollution Con Brooklyn NY	Approved	\$0.00
Carry over from February 15, 2012 meeting.						
50927CO		Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Brooklyn College-James Hall 2910 Bedford Avenue Brooklyn NY	Approved	\$0.00
Carry over from October 19, 2011 meeting.						
50936CO2		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1470 Madison Avenue New York NY	Ok, but	\$0.00
Carry over from February 15, 2012 meeting. 1) Emergency side feeders to ATS 13 and 14 not shown size and conduits. 2) Fire pump normal feeders, fusing not shown. 3) Feeder to ECH-2 and ATS 16 misidentified. 4) 3 pole ATS' used on separately derived system. ATS 1,5,3,4..						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51001CO2		J & R Rey Electrical Contrs Inc. 3471 Steenwick Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	250 East 57th Street New York NY	Hold	\$0.00
Carry over from February 15, 2012 meeting. 1) How are primary feeders routed to transformer and his access provided to transformer? 2) Show that the wire bending radius is code compliant.						
51033CO		Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	45-35 Van Dam Street Long Island City NY	Hold	\$0.00
Carry over from January 11, 2012 meeting.						
51081CO		Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	500 Hamilton Avenue Brooklyn NY	Hold	\$0.00
Carry over from February 15, 2012 meeting. 1) Fire alarm service switches neutrals not bonded to enclosures. 2) Verify whether 3 or 4 pole ATS' will be installed. 3) Neutrals not brought into fire pump service switch/controller and bonded; 4) Provide cut sheet for "C-ATS-04" and show AIC at this device. 5) Issues in short circuit study must be addressed. 6) Clarify fire pumps ATSS and utilities scheme. 7) Indicate OVPD on all ATS devices. 8) Provide partition on generator board between EM and standby.						
51138CO		Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	570 7th Avenue New York NY	Approved	\$0.00
Carry over from March 14, 2012 meeting.						
51139CO		Samco Electric Corp. 39-08 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	476 5th Avenue New York NY	Approved	\$0.00
Carry over from March 14, 2012 meeting.						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51144CO		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	550 First Avenue New York NY	Approved	\$0.00
Carry over from March 14, 2012 meeting. Move rear barrier to side of board emergency board. Job finalized 5/7/12.						
51166		Brandl Electric Inc. 1926 Mott Avenue Far Rockaway NY 11191	Requested approval for the electric service equipment proposed to be installed	Jetro/Restaurant Depot 100 Oak Point Road Bronx NY	Approved	\$650.00
1) Section bus sizes not shown on drawing. 2) Emergency side fire alarm disconnect switch bonded. 3) Remove transformer primary switch on load side of ATS. 4) Show feeds to emergency disconnect switches. 5) ATS 1 not to be located in service room. Feeder to ATS 2 conduit undersized. 7) Supplemental ground not shown on drawing. Job finalized 11/28/12.						
51167		Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1328 Broadway New York NY	Approved	\$650.00
51168		Jorob Contracting and Electrical Co. Inc. 104-29 Jamaica Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	90 Broad Street New York NY	Approved	\$650.00
51169		A to Z Electl Maint. & Service Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	650 Park Avenue New York NY	Hold	\$650.00
1) Need special permission for second service room. 2) Provide plan and egress for the new space (complete floor plan and detailed).						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51170		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Nyu Generator Feeder Project 550 First Avenue New York NY	Approved	\$650.00
1) Provide physical for new board. 2) Indicate max OCPD for fixture loads. 3) Door to open out. 4) Relocate barrier as shown. Job finalized 2/8/12.						
51171		Zev Electrical Contracting Corp. 54 Pearl Street Brooklyn NY 11201	Requested approval for the electric service equipment proposed to be installed	29-28 41st Avenue Long Island City NY	Approved	\$650.00
1) Provide size of equipment grounding conductor. 2) Relocate jockey pump connection out of ATS as shown. 3) Verify what shaftway is used for (not to access or haul packages from street). 4) Confirm no water issue that may come for shaftway. Job finalized 1/14/13.						
51172		Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weill Cornell Medical College 2315 Broadway New York NY	Hold	\$650.00
Provide coordination curves fpr DPN-WP-2-1 and SSW #1.						
51173		& H Electric Corp. d/b/a Mage Electl Cont 156 Flushing Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	632 Broadway New York NY	Approved	\$650.00
5/6/14 Swapped 2 drawings Rev 1.						
51174		Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	42-37 Main Street Flushing NY	Hold	\$650.00
1) Correct contractors name in title block. 2) 5' clearance required in front of fire pump service switch. 3) Through bus to 4000 amp service switch undersized. 4) Equipment grounding conductors undersized. 5) How do 500MCM terminate on 60 amp service switch, emergency side FACP & EMPD-2 feeders reversed. 6) Emergency side fire pump feeder overfused. 7) Indicate neutral conductor for fire pump conductors.						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51175		J & R Rey Electrical Contractors, Inc. 3471 Steenwick Street Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	New York Eye and Ear 310 East 14th Street New York NY	Approved	\$650.00
1) Verify feeder sizes to EDP-EES and fusing. 2) Verify emergency side fusing to 1000 amp ATS-3 switch. 3) Equipment grounding conductor to new 400 amp disconnect switch undersized. Job finalized 6/21/12. 9/12/13 Drawing swapped for Rev 2.						
51176		Heso Electrical Inc. 30-36 41st Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	11 East 1st Street New York NY	Approved	\$650.00
51177		Linphill Electrical Contractors Inc. 4850 White Plains Road, 2nd Floor Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	King Hotel 2416 Atlantic Avenue Brooklyn NY	Hold	\$650.00
1) Verify that switchboard does not have rear access and covers can't be removed. 2) Provide 5' clearance in front of service switch. 3) Rearrange equipment to allow egress from behind equipment.						
51178		H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requesting permission to install a junction box behind switchgear equipment where the clearance between the front of the junction box and the installed restricting access to the rear of the switchboard.	Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Approved	\$650.00
This is a special permission.						
51179		Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	53 West 36th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51180		A.S.M. Electric & Machine Corp. 333 West 39th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1560 Broadway New York NY	Approved	\$650.00
51181		Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	301--305 East 86th Street New York NY	Approved	\$650.00
51182		Matore Campisi & Sons Lic. Electl Contrs. 18-31 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	500 East 63rd Street New York NY	Approved	\$650.00
Tap conductor undersize. Job finalized 6/18/12.						
51183		Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	132 4th Avenue New York NY	Approved	\$650.00
Emergency fusing for fire pump undersized. Job finalized 10/9/12.						
51184		Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	330 5th Avenue New York NY	Approved	\$650.00
1) Over 10ft tap. 2) Use one OCPD as a main for 25ft rule. Job finalized 5/7/12.						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51185		C.B. Electric, Inc. 130-43 92nd Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	2 West 13th Street New York NY	Approved	\$650.00
51186		C.B. Electric, Inc. 130-43 92nd Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	575 Castle Hill Avenue Bronx NY	Approved	\$650.00
51187		Frank Manna, P.E., P.C. 19 Ambler Drive Bedford NY 10506	Requested approval for the electric service equipment proposed to be installed	770 Lexington Avenue New York NY	Approved	\$650.00
51188		OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	4 East 88th Street New York NY	Approved	\$650.00
51189		Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	#1 Lincoln Plaza aka 20 W. 64th St. New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51190		M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	The Ritz Tower 101 East 57th Street New York NY	Approved	\$650.00
51191		Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	150 East 72nd Street New York NY	Approved	\$650.00
51192		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	319-317 West 124th Street New York NY	Approved	\$650.00
51193		Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	375 Pearl Street New York NY	Approved	\$650.00
51194		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Brooklyn Army Terminal 5803 1st Avenue Brooklyn NY	Hold	\$650.00
1) Provide physicals of all equipment in Advisory Board format showing side views. 2) Verify that park metal switchboard manufacturer is a listed shop. 3) Someone who knows job to appear next meeting. 4) Verify that Gin-Pan transformer is listed for use in the USA. 5) Verify that all clearances comply with 110.34.						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51195		R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	SuperDry 729 7th Avenue New York NY	Approved	\$650.00
51196		New Phase Electrical Contractors, Inc. 725 East 136th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	171 Madison Avenue New York NY	Approved	\$650.00
Tap conductor undersized for 800 amp fusing, 240.21. Job finalized 6/21/12. 11/27/13 Swapped Rev 2.						
51197		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Spring Creek IS/HS 1065 Elton Street Brooklyn NY	Approved	\$650.00
1) Provide size of equipment grounding conductor to fire pump. 2) Relocate fire alarm switch to more accessible location. Job finalized 3/21/13						
51198		A Tech Electric Enterprises, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Bronx Zoo 2300 Southern Boulevard Bronx NY	Approved	\$650.00
1) Indicate what is new and existing on 1-Line, switchboards and feeders. Please use bubbles. 2) Show clearance in front of new ATS. 3) 1-Line does not match generator switch. Job finalized 8/6/12.						
51199		Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	Sky View Park 40-22 College Point Blvd. Flushing NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51200		Contact Electric Corp. 1275 43rd Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	95 Bedford Avenue Brooklyn NY	Approved	\$650.00
1) Service entrance conductors to 3000 amp service switch undersized. 2) C board through bus undersized. 3) Fire pump circuit undersized. 4) Fire pump equipment grounding conductor undersized. Job finalized 7/25/12. 7/30/13-Drawing swapped for Rev 2 on page 2.						
51201		Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Trevor Day School 312-318 East 95th Street New York NY	Denied	\$650.00
1) Room layout not provided. 2) New service entrance box incorrectly identified. 3) Verify that service entrance pull box does not contain splices. 4) Fire pump emergency switch undersized. 5) Emergency generator misidentified. 6) ATS not identified 3 or 4 pole, will dictate generator neutral bonding. 7) Submission not complete.						
51202		Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Park Avenue Armory 643 Park Avenue New York NY	Approved	\$650.00
51203		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	One New York Plaza New York NY 5	Approved	\$650.00
51204		AECOM 695 Third Avenue New York NY 10158	Requested approval for the electric service equipment proposed to be installed	NYC DEP Croton Water Treatment 3701 Jerome Avenue Bronx NY	Approved	\$650.00
1) Normal feed to fire pump must be on line side of 4000 amp service switch but not in same cabinet. 2) Emergency side fire pump overfused. 3) Provide new electrical room layout showing new changes on normal and emergency fire pumps on old drawing and the submittal. 7/31/15 Job finalized. Fire rated conductors cannot be installed in RGS conduit, as per manufacturer's installation instructions. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51205		P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	The Interchurch Center 475 Riverside Drive New York NY	Approved	\$650.00
51206		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Columbia University 615 West 131st Street New York NY	Approved	\$650.00
1) Provide lengths of transformer secondaries. 2) Remove neutral bonds in all disconnect switches and bond and ground in transformer. 3) Transform secondary disconnect switches to be grouped. Job finalized 6/18/12.						
51207		Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	166 West 18th Street New York NY	Approved	\$650.00
1) Verify size of service entrance conductors to fire pump. 2) Show grounding in house switch bonded. Job finalized 5/30/12. 11/27/13 Swapped Rev-2 only 1 drawing submittal changes made on REV-Rev 2						
51208		Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Tapestry 245 East 124th Street New York NY	Approved	\$650.00
Provide length of taps. Job finalized 5/8/12.						
51209		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	25 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51210		H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Hilton 1335 Sixth Avenue New York NY	Approved	\$650.00
51211		H & L Electric Inc. 41-11 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Radisson Hotel 511 Lexington Avenue New York NY	Approved	\$650.00
1) Through bus in DSBD undersized, should be 800 amp per square inch to 2nd section. 2) Vertical bus to 3000 amp switch undersized. 3) Verify that lugs in transformer S can accommodate #10 conductors. Job finalized 5/30/12. 9/12/13 Drawings swapped for Rev, 6 on A and Rev 5 on B						
51212		Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Columbia Medical 1290 Sixth Avenue New York NY	Approved	\$650.00
51213		DeFalco Electric 32-26 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	235 West 75th Street New York NY	Approved	\$650.00
Provide supplemental ground. Job finalized 5/30/12.						
51214		Allan Briteway Electrical Contractors, Inc. 43-01 21st Street, Suite 315-B Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	227 East 45th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51215		Allan Briteway Electrical Contractors, Inc. 43-01 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	235 East 45th Street New York NY	Rejected	\$650.00
Verify that switchboard has rear doors. Job finalized 5/30/12. 8/26/14 Rejected, This is not a swap. New submission required.						
51216		ICOR Associates, LLC 485C Route 1 South, Suite 200 Iselin NJ 08830	Requesting permission to leave as installed, balconies on a 12 story building without receptacle outlets due to the railings being glass.	524 West 19th Street New York NY	Denied	\$350.00
Code: 210.52(E)						
51217		Brandl Electric Inc. 1926 Mott Avenue Far Rockaway NY 11191	Requesting permission to install overhead service entrance conductors in Schedule 80 non metallic conduit in a corrosive area, Far Rockaway, Queens.	1209 Channing Road Far Rockaway NY	Approved	\$0.00
Code: 230.43						
51218		J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requesting permission to replace a defective 600 amp fire pump service switch with new on a 1000 KVA service.	77 West 66th Street New York NY	Approved	\$0.00
Code: 110.2(B)(2).						
51219		Ramdeens Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requesting permission to leave as installed in eye glasses examination rooms AC and MC cables that do not comply with 517.13(A) and (B).	3130 Grand Concourse Bronx NY	Denied	\$350.00
Code: 517.13(A) and (B).						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51220		Triboro Electrical Contracting Corp. 39-02 29th Street Long Island City NY 11101	Requesting permission due to lack of space in the service area to leave as installed service equipment that is not grouped together and located on the wall behind the existing service equipment.	51 Bank Street New York NY	Approved	\$350.00
Code: 230.72(A). With the stipulation that signage is provided at each service indicating whether other service is located.						
51221		NJS Electrical Service Corp. 36-16 13th Street Long Island City NY 11106	Requesting permission to use a second utility source as alternate power source in lieu of a generator to supply power to a limited service fire pump.	555 5th Avenue New York NY	Hold	\$0.00
Code: 695.4 Exception No.2. Provide documentation that the utility supply is not supplied from the same vault.						
51222		Robert Directors Associates 19 West 44th Street New York NY 10036	Requesting permission to utilize the exception to Section 250.52(A)(1) in an all concrete building.	156 West 56th Street New York NY	Denied	\$0.00
51223		Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requesting permission to leave as installed several feeders supplying power from one building to another utilizing Section 225.30(E) documented switching procedures.	Madison St., 1052 and 1054 Putnam Brooklyn NY	Denied	\$350.00
Code: 225.30(E).						
51224		Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requesting permission on a replacement 5KV medium voltage switchboard to have a rear clearance of 4' for condition 2 of Table 110.34A.	Brooklyn College 2910 Bedford Avenue Brooklyn NY	Approved	\$0.00
Code: Table 110.34A.						

ADVISORY BOARD CALENDAR

April 18, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51225		Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to allow the use of MI-SE cable in a ventilated metal tray in lieu of 230.6 and to allow the lack of coordination on feeders.	851 Grand Concourse Bronx NY	Approved	\$0.00
Code: 240.12. With the stipulation that the emergency generator feeder must be at 5000 amps at 75 degrees 9 set (MI + 500 kc mil) are undersized.						