

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 55242 | 18A0014 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55325 | 18A0016 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Provide coordination between "SS#1 1600A A4BY" and downstream "800A LPN-PK" fuse sign & seal by P.E; 2) Remove "GEC" lugs from emergency FA disconnect switch 3) Verify neutral conductor for FP controller. 4) Clarify ATS # 4 5/30/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/28/19 Swap dwg 2 of 3-Revision 3 and dwg 3 of 3-Revision 3. 1/12/2021 Amended Dwgs # 1, 2 & 3 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| 55301 | 18A0070 | Requested approval for the electric service equipment proposed to be installed | Approved | \$0.00 |
| 1) Provide coordination between 1200A A4BQ & downstream A4BQ 800A fuse. 5/22/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/5/2020 Amended Dwgs# 1,2 & 3 Rev 1 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| | 18A0091 | Requested approval for the electric service equipment proposed to be installed | On Hold | \$650.00 |
| 1) Verify short circuit rating at (DP-1) dist. Panel & provide available sc current - dwg.# 1 of 7 2) Verify complying with 330.10A(3) - Dwg # 6 of 7 3) Sectional buses in emergency service switch bond section 3 & 4 are undersized - dwg # 7 of 7 4) Provide available s.c at all F.P. controllers 5) 150 HP F.P. conductor (normal side) is undersized dwg # 2 of 7 6) Provide coordination between LPS 600A fuse & upstream 1000A KRPC fuse in 'DPP-B3' dis panel dwg 2 of 7 and coordination between 5000A BR & downstream fuses in 'Gen-39' dwg # 7 of 7 7) Provide cuts for all MC feeder sizes. To verify that MC Eq gnd is size adequately to trip the OCPD with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 55874 | 18A0097 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Provide asbestos abatement compliance doc. 2) Provide trip size of L6 & L7 breakers in "G-2" switchboard - New MV cond are undersized 3) Provide updated coordination study with full size one line, follow recommendations, clear TCCs & include the scope of work of this submittal, and to be signed & sealed by P.E. 5) Physical doesn't match one line dwg # 4 & 5. 10/3/18 1) New provided coordination study does not include the scope of work. 2) Provide Asbestos Abatement compliance document. 4/25/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| 55438 | 18A0138 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Provide coordination between 700A C.B. (within the Gen Set) & downstream breakers. 2) Verify photo votic sys & show it on one line and verify special permission if required. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/6/18 1) Follow recommendations of coordination study page (4-2). 8/21/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/28/2020 Swap dwg # A & B-Revision 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| 55222 | 18A0143 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55444 | 18A0148 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Comply with sec. 695.4(B)(1). OCPD for "FP-27" is undersize. 2) Service entrance conductor for FA SS# is undersize. 3) Provide dedicated fuse disconnecting means on the secondary side of FA x'mer on emergency side. 4) Show FP conductor size between splice box and FP controller. 5) Relocate FA panel from "North Electrical Service Room." Emergency equipment is not permitted in service room. 6) Comply with sec 695.6(B)(1) and kept FP conductor entirely independent from all other conductor at "Generator output switchboard" 7) Comply sec 700.9 and verify that all Emergency level is separated from standby load. 8) Verify FA & FP taps on the load side of the C.T 9) Verify the OCPD size on the jockey pump controller. 10) Verify that (SS-A) is front accessible only. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/16/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/10/2020 Amended Dwgs #23542AB20-02 of 3-Revision 3, 23542FP90-01 of 2-Revision 2, 23542FP90-02 of 2 Revision 1, 23542SB10-01 of 1-Revision 8, 23542SB30-01 of 2-Revision 6, 23542SB30-02 of 2-Revision 1 and 23542SB80-01 of 4--Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 12/1/2020Amended dwgs# AB20-01 of 3 Rev 1, AB20-02 of 3 Rev 4, AB20-03 of 3 Rev 1, FP90-01 of 2 Rev 3, FP90-02 of 2 Rev 2, SB10-01 of 1 Rev 9, SB30-01 of 2 Rev 6, SB30-02 of 2 Rev 1 and SB80-01 of 4 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| 55345 | 18A0161 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Provide coordination between Existing "1200A A4BQ" fuse (SS #6) and downstream breaker 800A, fuses 600A TR & 400A TR in "DP-H" panel sign & seal by P.E. 2) Conductor from 150kva x'mer to "PP-CHP" panel is undersize. 6/6/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/30/19 Swap dwgs 1 & 2-Revision 2.</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55312 | 18A0169 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Provide asbestos abatement compliance doc. 2) Show bonding in F.A. S.sw - fix typo 3) Sectional bus in last dist. Section (section #1) in the main switchboard is undersized. 4) Verify main bus size in (MC-10) & (MC-4) one line doesn't match physical (provide cut sheet) 5) Provide coordination between 1000A KRPC fuse & upstream fuse 1600A KRPC 6/18with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 5/30/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/12/19 Swap Dwgs 1 & 2 & 3 rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/18/2020 Swap drawings # 1, 2 and 3 REV4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/21/2021 Amended Plans# 1,2 & 3 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/2/2021 Amended Plan # 3 Rev- 6. <p>There is no more PAA allowed for this job, this is the 4th Swap.Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 55670 | 18A0188 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Show section bus size in compartment 1, vertical bus size in compartment 4 & 5 for "service switchboard -1" 2) Comply 430.28 for JP tap. Tap conductor undersize & provide tap length 3) Provide dedicated FA OCPD on Emergency side- separate enclosure. 4) Provide service switchboard 1 & 2 physical detail with section view & bus detail. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer | | | | |
| 55319 | 18A0211 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Provide full size drawing in readable format 2) Vertical bus is undersize in section-4 lower distribution of "MS-A" switchboard 3) Provide asbestos abatement compliance documents. 4) Comply sec 230.64(B) and provide 5' working clearance in front of SS#. 5/22/18 - 1) Item # 2 is not addressed - vertical bus are undersized in section 3 & 4. Lower distribution of "MS-A" switchboard. 6/7/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/17/18 Swap dwg #EJ-JJE-TMP-002-Revision 3. 11/16/18 Swap dwg #EJ-JJE-TMP-002-Revision 5</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55302 | 18A0229 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Bus bars connected to S.SW # 1,4 & 5 are undersized. 2) Provide bus bar size connected to S.SW # 2 3) Provide coordination between 4000A A4BY (SS#4) & downstream 2500A A4BY fuse. 4) Provide available S.C current at F.P. controller OR verify that available S.C current at F.P. controller less than 100kA with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/23/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/26/2020 Dwg #1 & 2-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/9/2020 Amended Dwgs# 1 & 2 rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| 55914 | 18A0231 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) The incoming service conds and transformer (1A-1B) primary conds are undersized. 2) Provide emergency rating & verify if SDS and show the tap 3) Provide OCPD size & type that feed New MV cables 4) Show grounding of F.A. S.SWs. 2/8/19 - 1. Confirm that neutral is bonded and grounded only in one location for the emergency system as SDS verify bonding of FA-SW-E. 2. Confirm supplemental grounding to all FA S.SWs. 5/20/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/3/19 Swap Dwg # 1 of 3 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/13/2020 .Dwgs Amended LNY0016344-S1-OL-Rev 4; LNY0016344-S2-FP-Rev:and LNY0016344-S3-PD-Rev.4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| 55231 | 18A0238 | Special Permission | Approved | \$350.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55232 | 18A0239 | Special Permission | Approved | \$350.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55310 | 18A0243 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - 1) Provide available S.C current and AIC rating of FP controller or verify that AIC rating of F.P. controller is more than the available S.C. current. 5/25/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55239 | 18A0246 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55347 | 18A0251 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - 1) Provide coordination between 400A A6D fuse & upstream 1200A LCL fuse. 6/28/18 Job finalized. .Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55656 | 18A0257 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Provide cond size feeds F.A. control panel. 2) Fix typo for SS# 2 & SS# 3 - floor plan doesn't match one line. 3) Comply with 230.64(B)(1) - Provide 7' clearance for 400A s.sw & F.A. s.sw 4) Label all new work in the electrical room. 5) One line doesn't match physical. 6) Asbestos abatement compliance doc. Required. 7) Verify existing crown box elevation. 11/20/18 1) Scope of work not included in Asbestos Compliance document. provided. 1/17/19 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/25/19 1) Approved Dwg # J18-012218 (2 of 2) Rev 1. 2) Swap Dwg # J18-012218 (1 of 2) Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/6/2020 Amended plan #1 of 2 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| 55241 | 18A0261 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/23/19 Swap dwgs AB90-01 of 1-Revision 1 and FP90-01 of 1-Revision 2. 2/5/2021 Amended Plan #1/3 Rev-4 & 2/3 Rev- 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 55318 | 18A0279 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - 1) Provide available S.C. current 'PP-1' Panel. 6/6/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55230 | 18A0281 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55297 | 18A0284 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) F.P. OCPD on the emergency side is undersized 2) F.P. G.E.C & equipment grounding cond are undersized - Table 250.66 & 250.122 3) F.A. OCPD emergency side - is overfused 4) Vertical bus in "DB1" distribution SWBD (Section 3) is undersized. 5) Fix typo about ATSS note connected to breakers in "HDP1-1" panel. 5/22/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| | 18A0286 | Special Permission | Denied | \$0.00 |
| Applicant dd not propose a safe alternative that meets code intent | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55355 | 18A0287 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Re-submit coordination study with P.E. sign & seal. 2) Comply with sec 230.42 service entrance conductor between "BLDG-4-CT" & "MSS-BLDG4" is undersize. 3) Equipment ground conductor undersize between SS# 1,2 and respective ATS-6, ATS-7 4) Vertical bus undersize in section 2 of generator parallels swbd "SWBD-GEN" 5) Verify scope of work for this EAB submission. If BLDG 2 & 3 is included, submit one-live & physical detail drawing for respective bldg, otherwise update floor plan. 6) Submit the gen set cut sheet and paralleling scheme 7) Provide room layout for gen set with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/7/18 - 1) Comply with sec 230.42 service entrance cond between "Bldg - 2-CT" & "MSS-Bldg2" and vertical service bus in "MSS-Bldg2" switchboard are undersized 2) Verify how many sets of 500 MCM (MI Cable) from "SWBD-GEN" to ATS-3 3) Comply with 250.92(2) - Add Bonding to "MSS-Bldg 2, 3 & 4 4) Verify No. of cond sets that feed EM-DP Bldg 2 5) fix typo of EGC size feeds ATS-7 normal side with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/2/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.6/12/2020 Amended Dwgs # D1, 2 & 3 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| 55260 | 18A0288 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Asbestos abatement compliance doc. Required. With stipulation to add a signage of KIIK keys system in operation. 4/30/18 - ok withstip to add signage of kir-keys system in operation Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| 56151 | 18A0289 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Equipment grounding cond of tap conductors that feed the two 100A disc. Switches are undersized. 2) F.P. cond is undersized. 3) Jockey pump equipment grounding cond is undersized. 4) Provide available s.c current at F.P. controller. 5) Verify raceway type for F.A & ARCS service connection. 2/7/19 1) Fire pump and Jockey Pump EGC is undersized-T250.122. 1/15/2020 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/3/2020 Amended dwgs# 1 & 2 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55435 | 18A0290 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>OR - 1) Provide asbestos abatement doc. 2) Provide coordination between 1500A KRPC fuse & down stream 800A KRPC fuse. 6/7/18 - Provided coordination to be signed & sealed by P.E. 8/17/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/2/19 - Swap dwg #A Rev-2, B Rev-1. 7/26/19 Swap Dwg # D-1803-30063-A Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| | 18A0292 | Requested approval for the electric service equipment proposed to be installed | Pending | \$650.00 |
| <p>1) Provide asbestos abatement compliance documents. 2) Provide coordination between "1600A KRP-C" fuse & downstream breaker in "DP" panel sign & seal by P.E. 3) Verify MV cable is a single conductor or 3 conductors 4) Verify that the transformer complies with DOE requirement. 6/19/18 - 1) Item # 2 not addressed - Required TCC not included in the coordination study. 2) Verify NRTL listing for Xfmr. 3) Provide OCPD valve on the line side of MV cable. 10/22/18 1) All comments of revision date 6/19/18 are not addressed.</p> | | | | |
| | 18A0294 | Special Permission | Denied | \$0.00 |
| <p>1) Provide hardship and justification including photo to document lack of space outside the elev. 2) Provide signed and sealed letter from the elev. Servicing co. indicating no objection to the installation of such feeder inside of the shaft.</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|---|----------|----------|
| 56124 | 18A0296 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Vertical bus in Con-Ed CT cabinet is undersized for "MSB-A" & "MSB-B" 2) Provide coordination between "1200A KRP-C" SS# and downstream breakers in "DP-1M-N" & "DP-1M-S" panels - sign and seal by P.E. 3) FA & FP neutral conductor tap before N.D.L. 4) Show FP controller for "FP-1" 5) Remove bonding on secondary side of FA x'mer at emergency disc. Switch. 6) Thru feed (between two section) conductor is undersize for "ADP-5", "ADP-8" & "ADP-11" distribution panel. 7) Vertical bus undersize in (section 3) "DPC-1" switchboard 8) Show conductor size for load bank. 9) Show Electrical service room is mechanically ventilated & have panic hardware on egress door. 10) Verify your statement under general note for emergency pwr & dwg 3 of 5 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/25/19 1) Provide N.D.L. to 2000A service switch in "MSB-A". 2) Comply with 110.26(c) (3)-door to open outward in electrical room of 52nd floor. 11/18/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/8/2022 Amended plans Plan 1, Rev 3; Plan 2, Rev 2; Plan 3, Rev 2 and Plan 4, Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| 55235 | 18A0300 | Requested approval in New York City for the use of structured media centers model 49605-30W | Approved | \$200.00 |
| <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| 55316 | 18A0301 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Show vertical bus size for "New 1600A" SS# 2) Provide 1000 KVA x'mer cutsheet 3) Verify service room is mechanically ventilated & has panicbars on doors. 6/5/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| 55304 | 18A0302 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>OR -1) Provide coordination between 800A BR & downstream breakers. 5/23/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/8/19 1) Provide coordination study between 1200A KIV fuse and down stream 'DPH-2-1' Panel board. 10/23/19 Swap Dwg # AB-18290-A.1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 55223 | 18A0303 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/20/2020 Amended Dwgs # page 1 of 2-Rev 1 and page 2 of 2- Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| 55324 | 18A0304 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Main bus undersize in existing "MDP-A" service switchboard tap section 2) Block the rear access of "MD-B" panel. 6/4/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/30/2019 Swap Dwg # AB-18287-A.2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/20/2020 Amended Dwg # A Rev 3 . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| 55303 | 18A0306 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>OR - 1) Provide coordination between existing "800A SS# 2" (A4BY) and downstream "400A A20" fuse in "DPL-Retail" with sign and seal by P.E. 5/23/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| | 18A0307 | Requested approval for the electric service equipment proposed to be installed | Pending | \$650.00 |
| <p>1) Verify generator is separately derived system -supplemental gnd needed If SDS add note that "neutral is bonded & grounded" 2) Provide available short circuit current at F.P. controller 3) Provide asbestos abatement compliance doc. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> | | | | |
| 55840 | 18A0312 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Provide asbestos abatement compliance document. 4/25/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |
| | 18A0314 | Requested approval for the electric service equipment proposed to be installed | On Hold | \$650.00 |
| <p>1) Verify that existing FA & FP service switches are bonded & grounded. 2) Show FA & FP ATS rating on one-line diagram 3) Submit electrical service room floor plan & show new sprinkler pump SS# on floor plan. 4) Show FA x'mer rating, conductor size between "100A FA" disconnect switch & FA x'mer. 5) Comply with BC-2702.1.7.1. Emergency x'mer T-2 for FP is not permitted in Electrical service room. 6) Verify that conductor between FP x'mer & FP controller comply with sec 695.6(B)(1) 7) Comply sec 695.4(B)(2) Emergency side OCPD for FPs are undersize. 8) Provide generator room layout with FA & FP emergency equipment. 9) Show conductor size between two section of "GEN-SWBD" with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> | | | | |
| 55252 | 18A0315 | Requested approval for use in New York City of Connectrac M-Series Connection Monument asw a junctionbox for the powered furniture panel systems | Approved | \$200.00 |
| <p>Ok for exact model "3.7 M-Series monuments" was approved in 2008 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55220 | 18A0316 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55269 | 18A0317 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Provide cond. Connected to existing 1200A S.SW # 5 & verify S it is new or existing. 2) SS# 5 is new and add cloud on one-line diagram. 5/3/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements . 4/2/19 Swap Dwg 1 rev 2. | | | | |
| 55219 | 18A0319 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR -Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| | 18A0320 | Requested approval for the electric service equipment proposed to be installed | Pending | \$650.00 |
| OR - 1) Asbestos abatement compliance required. | | | | |
| | 18A0321 | Special Permission | Denied | \$0.00 |
| 1) Provide documentation for lack of space outside the elev. shaft including pictures. 2) Provide signed and sealed letter from the elev. servicing co. indicating no objection to installation of such feeder inside of the elev. shaft. | | | | |
| 55225 | 18A0322 | Special Permission | Approved | \$0.00 |
| with stip: installation and inspection shall be in accordance w. 2014 NEC, Article 690 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/7/19 Swao new drawing. E101.01. | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55227 | 18A0323 | Special Permission | Approved | \$0.00 |
| With Stop: Installation and inspection shall be in accordance w/2014 NEC, Article 690. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55224 | 18A0324 | Special Permission | Approved | \$0.00 |
| with stip: Installation and inspection shall be in accordance w/ 2014 NEC, article 690 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55229 | 18A0326 | Special Permission | Approved | \$0.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55228 | 18A0327 | Special Permission | Approved | \$0.00 |
| With Stip: That the conduit when existing the shaft shall be installed in a 2-HR rated enclosure Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55233 | 18A0329 | Special Permission | Approved | \$0.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55226 | 18A0330 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/9/19 - Swap dwg # 1 of 1 Rev-2. | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55876 | 18A0331 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Verify complying with 695.6(F) - Provide junction 60 x for JP tap. 2) Provide tap length for the jockey pump & OCPD of JP controller. 3) Comply with 408.60(A) - N.D.L. shall be located downstream of main bonding jumper & grounding electrode cond. 4) 600A TR fuse doesn't coordinate with upstream 2000A A4BQ fuse and, provide coordination study signed and sealed by P.E. 5) Provide KVA rating of transformer "T-4" & provide cut sheets to all xfms 6) Equipment grounding of SS# 2 is undersized - comply with table 250.122 7) Provide cond size feeds 800A breaker from the generator 8) Verify that the primary OCPD energizing 1000KVA xfms is rated for in rush current. 9) Provide available SC current F.P. controller & F.P. controller AIC Rating. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/13/18 1) Item 4 is partially addressed-provided coordination study signed and sealed by P.E. 2/25/19 1) You shall provide 4 pole ATS with switched neutral for separately driven system fire alarm transformer to void double bonding. 2) Verify trip size of transformers T-1 and T-2 primary OCPDs for one line doesn't match coordination study. 5/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/10/2020 Amended Dwgs# 1 Rev 3 , 2 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/31/20 - swap dwg # 2 Rev- 5 & # 1 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| 55413 | 18A0332 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Comply 240.21(B). Tap conductor undersize for 400A Tras-S (tap) from SS# 6. 8/3/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/20/2020 Amended Plan 1/1 # Rev- 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| 55295 | 18A0333 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Provide asbestos abatement compliance doc. 2) Provide 2nd level OCPD type & size in 2nd floor & 3rd floor distribution - Provide the coordination with SSW# A1 & A2 & downstream OCPDs 3) Correct the floor plan scale. 5/17/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55236 | 18A0334 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/2/2020 Amended Dwgs# 1, 2 & 3 Rev 7 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| 55294 | 18A0335 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Provide supplemental grounding in service SS-8N & SS-9 2) Provide OCPD's size & type, AIC rating and physical of MCC-A or cut sheet (service-SS-8N) 3) MV distribution board cut sheet doesn't match one line & show NRTL listing. 4) Verify if existing fire alarm equipment doesn't contain F.A. S.S.W. 4/18/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55238 | 18A0336 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/11/2021 Amended dwg# 1 Rev 1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/4/2021 Amended Plan# 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| 55365 | 18A0337 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - 1) Asbestos abatement compliance required. 7/16/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| 55244 | 18A0338 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/30/19 Swap Dwg # ACS-D-13049-2 Rev 1 and ACS-D-13049-1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| 55305 | 18A0340 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Provide asbestos abatement compliance documents. 2) Comply sec 250.66 grounding conductor for FP SS# is undersize. 5/22/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/26/2023 Amended Plan # 1 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| 55243 | 18A0341 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |
| | 18A0342 | Special Permission | Denied | \$0.00 |
| This permission shall be submitted to the Boro commissioner's office for variance | | | | |
| 55317 | 18A0343 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 1) Provide "SS-A-3" switchboard section view with bus detail. 5/25/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/21/18 Swap #A031802-Revision 3. | | | | |
| 55237 | 18A0344 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| OR- Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. | | | | |

ADVISORY BOARD CALENDAR

April 18, 2018

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| 55323 | 18A0345 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Show that FP ATS is FP service rated. 2) Comply section 695.6(B)(1) and provide 2HR fire rating to FP emergency side conductor. 3) Vertical bus undersize for 1200A distribution section from SS# 2. 5/29/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/8/2022 Amended plans # 1, 2 & 3 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/4/2022 Amended Plan 1, 2, and 3 Rev-4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/19/2022 Amended Plan # 1 Rev- 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| 55461 | 18A0346 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>1) Provide asbestos abatement compliance doc. 2) Verify that AIC rating of F.P. controller is more than the available S.C. current. 6/19/18 - Fire pump cond is undersized, the FLC valve as per table 430.250 is 528A. 8/24/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/18/19 Swap Dwg # ACS-D-13182-1 Rev 3, ACS-D-13182-2 Rev 3, ACS-D-13182-3 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/15/19 Swap dwg #ACS-D-13182-(1,2,3)-Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/26/19 Swap Dwgs 1 rev 5, 2 rev 5, 3 rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p> | | | | |
| | 18A0347 | Special Permission | Denied | \$0.00 |
| <p>This special permission shall be submitted to the Borough office as a CCD1</p> | | | | |
| 55240 | 18A0350 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.. 11/26/18 Swap Dwg A-Revision 2 and B and C-Revision 1. 5/24/19 Swap dwg #A-Revision 4 and dwg C-Revision 2</p> | | | | |