

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54612	16A0356CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carryover from 11/16/16 - 1) DWG 3 of 4, vertical bus undersize in 'MSWBD-BB' compartment-4 2) Comply section 695.6 (B) (1) and keep fire pump cables independent from other cables. 5/15/2017 - 1) need to comply with 695.6(B)(1) for emergency side. 2) Fix typo for vertical bus in "MSWBD-BB" 6/28/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54522	16A0868CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from December 14, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/31/19 Swap dwg # 1 of 1-Revision 4. 6/8/2020 1} Comply with 230.71 - clarify the new 60 A service switch as it count the 7th service switch. 6/22/2020 Amended Plan 1 # Rev- 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54553	17A0003	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Cond. Feeds F.P. is undersized. 2) Provide Asbestos abatement compliance document. 3) Provide Short Circuit at the meter stack. 4) Time current curve to be signed and sealed by certified engineer. 5/19/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/22/19 Swap Sheet 1-Revision 2. 5/21/19 - 1. Provide coordination between 800A A3T fuse &amp; downstream breakers signed &amp; sealed by P.E. 6/10/19 Swap dwg #1-Revision 3</p>				
55342	17A0105	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply section 240.21 (B) tap rules for jockey pump tap. 2) Comply section 695.6 (B) for fire rating of fire pump conductor from FP disconnect switch to "JB" and clearly show the location of "JB" 3) Comply section 230.42 (A) for 2000A SS# FP &amp; FA tap service bus undersize in compartment 1 &amp; 2 for FP, FA &amp; 2000 SS disconnect) main service switchboard. 9/14/17 - item # 1 not addressed. 10/31/17 - 1) Verify supplemental grounding to F.A. &amp; F.P. S.S.Ws 11/27/17 - Provide water main &amp; supplemental ground to F.A. &amp; F.P. S.S.Ws. 6/22/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/26/2020 Amended dwg # A Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54967	17A0106	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service bus [(5) cu 4"x.25"] Feeds 4000A ssw is undersized. 2) Both service switch boards enclosure not to be used as a current path - connect main bonding jumper from neutral to GND bar directly to enclosure. 3) Provide tap length of jockey pump - jockey pump to follow tap rules. 4) Provide asbestos abatement compliance document. 8/30/17 - 1) Comment 3 &amp; 4 not addressed 2) Jockey pump shall follow tap rule (section 430.28) 3) Show available fault current at FP controller. 4) Provide barriers in gen. Panel in accordance with section 700.9(B) to separate all emergency loads from other loads. 5) Jockey pump not to be tapped after ATS [Section 695.6(F)] 6) FP ATS to be listed for FP use and rated for locked rotor current with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 12/29/17 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/7/19 Swap dwg #A011704-Revision 3</p>				
54706	17A0180	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) S.SW # 3 feeding panel board 'EDB-1' is overfused. 2) Ground bus is undersized in switchboard 'DB-1' 3) Show available fault current at panel board. 4) Provide physical indicating bus details and connections. 5) Provide barriers in ACC. W/ 700.9 (B) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/14/17 Comment 5 is not addressed. Verify that generator panel have barriers in accordance with Section 700.9(B) to separate all EM load from other standby load. 8/25/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/8/18 - swap dwg 1 of 2 Rev 3</p>				
54596	17A0182	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination study. 2) Confirm length of tap include up-cross-down. 6/13/2017 - 1) Verify that electric service room comply section 230.64(B) &amp; have 2hr fire rating and accessible to qualified persons. 2) Provide separation for the electrical equipment from existing plumbing pipe &amp; verify it's protected from leaks and breaks. 6/20/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 9/19/17 - swap dwgs 2 rev 3 &amp; short circuit study</p>				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54660	17A0202	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide GF Protection to all 1000A or more OCPD, 1st &amp; 2nd level 2) Equipment grounding conductor of 3000A fuse is undersized. 3) Verify neutral and ground cond. Sizes. 4) Provide panic hardware on all egress doors. 7/31/17 - job finalized -Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/21/18 - swap dwg with Rev 2 11/16/18 Swap Dwg A-Revision 3 and Dwg 3-Revision 4.</p>				
	17A0211	Requested approval for the electric service equipment proposed to be installed	Rejected	\$0.00
<p>1) Provide FP data. 2) Comply with 110.26 - clearance of the back of gen. Switchboard. 3) Provide asbestos abatement compliance document. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/29/17 - job finalized -Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/1/18 - fire pump GEC is undersized - T250.66</p>				
54617	17A0213	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that SS#5 comply section 230.64 (B) working clearance requirement. And show the finish floor level before and after two steps. 2) Provide the asbestos abatement compliance document. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/29/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/19/2019 1) Provide coordination study (signed and sealed by a P.E) for both SS #2, SS #1 and downstream fuses. 2) Provide correction to undersized load conductor at "ATS-PP-P" 3) Provide cover letter with Lic name and number. 10/3/19 Swap Dwg # AB-17203-A.3 Rev 3 and AB-17203-B.3 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/8/2020 Amended Plans A4 &amp; B4..Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/17/2020 Amended Plans B5 &amp; A5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

May 3, 2017

Approval #	Submission #	Type of Request	Status	Fee
54584	17A0221	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide the asbestos abatement compliance document. 6/13/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	17A0249	Requesting approval for use in New York City of your Connectrac Wireway. Model numbers: 2.7 Under-Carpet/In-Carpet/On-Floor Wireway	Denied	\$200.00
!) EQ is not listed as a complete assembly. 2) Manufactured wiring when listed shall comply to article 604 of NYC EC and limited for LTG only - wiring devices are evaluated by lil subject.				
54810	17A0250	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide jockey pump tap cond length. - Jockey pump has to follow tap rules.. 2) Provide asbestos abatement compliance document. 3) SS # 1 & 1600A SEC 5 don't coordinate. 8/3/17 - Comment 1 not addressed. Comply sec 430.28 for JP tap. 2) Provide fuse coordination between "SS#2 4000A A4BY" and "2000A A4BY" fuse. 3) Verify neutral conductor for FACP-1 & 2 9/18/17 - comment 2 not addressed. 9/21/17 Provide fuse coordination between "ss #2 4000A A4BY" and downstream "2000A A4BY" fuse. 10/17/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/3/19 Swap dwg # 1 of 4, 2 o4 4 & 3 of 4-Revision 3. 8/22/19 1) Remove neutral bonding from new retail switches - Dwg 1 of 4. 2) Tap conductors feed "ReT#4-sw" & "ReT#5-sw" are undersized - Dwg 1 of 4. 3) Confirm tap conductor length to retail 1, 3 & Green house. 9/23/19 Swap dwg # 1 of 4 and 2 of 4, Revision 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
54993	17A0254	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) PU Array grounding. 2) Verify minimum working space in front of solar pu distribution - A 3) Verify the use of EMT after inverter. 4) Neutral is bonded and grounded in two locations. 5) Not advisory board format. 6) Provide all bus sizes for SS & dist. Board. 7) Provide EQ physical/and Cuts. 8) Provide coordination study. 9) Provide abatement letter. 10) not advisory board format. 7/19/17 - 1) Provide list of 1000VDC equipment that will be installed in letter of Special Permission & that all the work will be performed in accordance with 2014 NEC PV proviswions. 2) Item # 2,3,6,7,8 & 9 not addressed. 10/27/17 - 1) Item # 6 is not addressed - Show bus sized not just the ampacity. 2) Separate submission is required to the special permission. 3) Verify utility approval to the direct connection to utility xfmr. 4) Provide 5' clearance in front of 89L solar generator disconnect switch A & B 5) Provide main bonding jumper size. 11/28/17 - Service bus feeds 300A Fuse is undersized - sec 230.42(A) 2) Distribution bus in 522T-A1, A2 & A3 and 52IT-B1 are undersized. 3) Verify the address. 4) Verify bonding Bar to 800A & 600A 12/22/17 - 1) Show bus size on one line dwg. 2) Provide cut sheet to 52IT-B1 Panel. 1/22/18 Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
	17A0255	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
Not Advisory Board Format.				
54655	17A0256	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with 408.60 (E) (3) 2) Clarify the No. of MI cables used to feed EMDB 3) Fix typo in ATS 4) Physical doesn't match one line. 5) Provide asbestos abatement compliance document. 6) Feeder feeding EMDB is undersized. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7) Verify 800A fuse feeds 600A ATS. 8) Provide panic bars on exit doors.7/27/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	17A0292	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Provide catalog cut sheet for inverters showing NRTL listing (approval) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
54548	17A0301	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) 5' clearance required in front of FP S.SW # 2 2) Asbestos abatement needed. 5/17/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54512	17A0304	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR -Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54723	17A0305	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply section 230.64 (B) for SS#2 &amp; SS# 3 working clearance. 2) Explain how this affected by sandy. It look like new tap to existing service switchboard. If not affected by sandy then pay the appropriate fee. 3) Verify the neutral cable for 3P "sump pump" &amp; "LP-EM" life safety ATS. 4) Show the tap length for "square D 400 Disc" switch and comply the section 240.21 (B) 5) Relocate all EM equipment (FA FCO Panel) to EM Room. 6) Clearly show the "EPP-FP" panel on single line and if this is EM panel than relocate to EM room. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. (UL 2200) 8/4/17 - 1) Comment (6) partially addressed. Comply BC-Chap.27 and relocate standby panel "EPP" with 2 hr FR cloet. 9/1/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/8/19 Swap Dwg Rev 3.</p>				
54637	17A0306	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show grounding in all existing service switchboard. 2) Provide coordination study for new plug in disc sw with TTS upstream circuit breaker. 7/17/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54558	17A0314	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show KAIC rating of switchboard 'New DB-2' 2) Coordination study to be sealed by P.E. 5/26/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/5/18 Swap dwg D-Revision 3.				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54638	17A0316	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Coordination study to be sealed by the P.E. 7/17/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54524	17A0319		Approved	\$0.00
1) First Request - ok 2) second request - no special permission needed. 3) Third request - is ok, with 2" concrete encased for the whole run to the service room including the all 90° bends & (pull boxes)				
54657	17A0320	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
1) Distribution SWBD 'E' and SWBD 'B' one line does not match with physical point of entrance is reversed. 2) Service room doors to be equipped with panic hardware. 7/28/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/13/18 Swap dwg #A,B, & C-Revision 2, Dwg D-Revision 5 and Dwg E-Revision 3. 12/27/18 Swap dwg #D-Revision 5 and dwg E-Revision 4. 3/18/19 Swap dwg #A & B-Revision 3; dwg D-Revision 6 and dwg E-Revision 4. No more swaps.				
54516	17A0321	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR-Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54952	17A0322	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Service Cond feeds SS# 1,2,& 3 are undersized. 2) Show grounding and bonding of FP at FP controller. 3) FP Cond is undersized. 4) FP equipment grounding cond is undersized. 5) Provide vertical bus size & all OCPD's valves of EDPL panel. 6) Physical doesn't match one line. 7) Provide asbestos abatement Compliance document. 8) Verify that ATS-EDPL is rated 2000A 9) Bonding and grounding of 2000A SSW is on the load side of disconnect SW. 11/16/17 - Item # 1 from 1st meeting comment not addressed - waiting for SP decision. 12/19/17 - Job finalized * with stip: A sign to be place at the 2000A service sw indicating that the Maximum fuse to be installed is 1800A Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54600	17A0326	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Vertical bus feeding SS#1 2000A in main switchboard "B1-B" is undersized. 2) Show neutral termination in FA disc. SW 3) Show neutral conductor on line side of FA switch. 4) Conductor from SSW# 2 &amp; 3 in switchboard "B1-B" &amp; "B1-A" to meter bank is undersized. 5) Conductor from SSW# 1 in switchboard "B1-A" to "HDP" is undersized. 6) FPS SW# 4 is overfused. 7) Neutral is bonded to enclosure at 600A DISC.SW 8) Show length of tap conductors from retail meter trough. 9) Provide TCC to show coordination for SSW# 2 &amp; # 3 to its downstream circuit breakers. 10) Service room to be 2-hour fire rated construction. 6/22/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/20/18 Swap dwg-Revision 3.... 12/6/18 1) Comply with 408.36-Provide main OCPD to panel "DP-Rest-B!". 2) Provide the available s.c. current at P.O.E.. Meterbank 5 and panel "DP-Rest-B!". 1/31/19 1) Remove bonding and grounding of new 600A switch. 2) Verify that available s.c. at point of entry is 56 KA. 2/1/19 Swap dwg #A041702 Rev-6. 5/10/19 Swap dwg Revision 7</p>				
54555	17A0328	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) FA SSW - Room layout doesn't match with one line. 5/24/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/27/18 Swap dwgs 1 and 2-Revision 3.</p>				
54519	17A0329	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54513	17A0330	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR-Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/2/18 - swap dwg D Rev 1				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54565	17A0331	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide catalog cut sheet for inverters showing NRTL listing. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/5/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/2/17 - swap dwg with rev 1</p>				
54567	17A0332	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Provide supplementary ground for the service switchboard. 2) Provide the asbestos abatement compliance document. 6/6/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54514	17A0333	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/13/2017 -swap dwg 12835 Rev 1 8/4/17 - swap dwg with rev 2</p>				
54646	17A0334	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) comply section 110.26 for "100A" switch in ATS Room. 2) Verify that "ELPC" is a normal equipment or emergency. If it's EM equipment relocate to EM Room. 6/21/17 - 1) S.SW# 1 does not coordinate with 600A downstream fuse. 2) Phase and neutral bar is reversed in S.SW # 5 7/19/17- job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/20/17 - Swap dwg # 1 &amp; 2 Rev 7 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54557	17A0335	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Panic Bars 2) Provide asbestos abatement compliance document. 5/25/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/15/23 Amended plans # 1, 2, 3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/26/2024 Amended plans # 1, 2, &amp; 3 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
54582	17A0340	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1) Provide supplemental ground to the service equipment. 2) Remove bonding from "New Dist SWBD" 3) Vertical bus undersize in section 2 of new dist swbd 'MDP' 4) Provide short circuit and coordination study. 6/12/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/26/18 - swap dwg A &amp; B Rev 3</p>				
54705	17A0341	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply section 408.60 (E) for vertical bus in compartment 2 of 'MDP-1C' switchboard. Vertical bus undersize ( in service C DWG) . 2) Show the vertical &amp; section bus size in "SECT # 2" of "EMDB-H" switchboard. 3) Verify comment for C/B 2500A SWBD. 8/23/17 - 1) Item # 3 not addressed, 2) Provide sectional bus in 'MDP-1C' section # 2 8/24/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/19/19 1) The grounding conductor between new fuse and transformer is undersized. 10/17/19 Swap Dwg # ATL-D-1611085-00 Rev-4 and ATL-D-1611085-000 Rev-6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/10/2020 Swap Dwg #00-Revision 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
55250	17A0342	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide bus size off 3000A S.SW 2) Provide asbestos abatement compliance document. 3) Provide coordination study - signed and sealed from certified engineer. 4) Clarify ATS in service room. % Main bus feeds emergency SWBD is undersized. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/5/18 - 1) Sectional bus in MDP-section 3 is undersized 2) Verify water main ground to main sw board &amp; water main &amp; supplemental grounding to F.A. SW 3) Verify that distribution associated with emergency &amp; standby power sys do not pass through the main service room. 4/24/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/8/19 Swap Dwg # A041703 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/5/19 Swap Dwg # A041703-A Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55257	17A0343	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide bus size off 3000A SSW 2) Provide coordination study - signed &amp; sealed from certified engineer. 3) Provide asbestos abatement compliance document. 4) Clarify the ATS's in the service room. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5) Service bus feeds emergency SWBD is undersized. 2/6/18 - 1) Verify water main grounding to main swboard and water main suppl to F.A. sw. 2) Verify that distribution associated emergency and standby power systems do not pass through the main service room. 3) Cut sheet of MDP doesn't match one line (section 3) 4/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/10/19 Swap Dwg #A041704 Rev-3. 12/6/19 Swap Dwg # A041704-A Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54586	17A0344	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination between OCPD's in the normal & emergency side. 2) Verify if CoGed area and new emergency room are 2 hr fire rated. 3) Fix physical of right elevation - New 4000A MLO emergency sw board. Section # 2. 4) Cond. From 4000A is undersized. 6/13/2017 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54633	17A0345	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) DWG 1: Show feeder D & G sizes in the drawing. 2) Show the location of new 350E sw fuse & tap box if secondary conductor is outside than comply section 240.21 (C) (4) 6/9/2017- comment 2 not addressed. New 3505.5KB fuse to comply with 240.21(C)(4) 6/22/17 - Provide cut sheet for 1200A ATS showing that space for termination. 2) Add note for existing building # 1 "Not emergency load" 7/14/17 - job finalized - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	17A0346	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) Provide detailed drawings for each new substation doubled & single. 2) Provide size of conds that feed loads off all the ATS. 3) Verify if gen sets are SDS or not. 4) Jockey pump cond is undersized - JP to follow tap rules. 5) Provide vertical bus size of Panel EM-PPH-6W1 & EM-PPH-6N1 6) Provide room layout for all substations & the font has to be clear and bold. 7) Provide physical dwgs.				
54521	17A0347	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54515	17A0349	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR-Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**May 3, 2017**

Approval #	Submission #	Type of Request	Status	Fee
54523	17A0350	Requesting approval for use in New York City of your pre-manufactured modular wiring system to connect base building electrical of movable wall boxes and floor boxes.	Approved	\$200.00
Approved for limited application in accordance with NYC EC 604 for LTG above accessible ceilings and the products to contain instruction as req by NY Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54520	17A0351	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54701	17A0352	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Emergency feeder to 1600A ASCO ATS from new generator undersize. Clearly show the number of conduits. 2) Provide the asbestos abatement compliance document with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/22/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	17A0363	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Provide Panic Bars 2) Provide asbestos abatement compliance document. 3) Provide the conduit size from transition box to FP ATS. 4) Clarify the bonding of the generator 5) The current curves to be signed by certified engineer. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				