

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55287	18A0018CO2	Special Permission	Approved	\$0.00
<p>Carry over from January 17, 2018 meeting. With the stipulation to provide signage for both rooms. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	18A0023	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Verify the project address 2) Secondary cond of 1500 kva xfmr is undersized - dwg AB20 1 of 4 3) Bus bar in low voltage section # 5 in new portable generator substation is undersized. 4) Provide sectional &amp; vertical bus size in low voltage sections in new auto transfer s.w gear (lineup # 1 &amp; 2 - section # 4 &amp; 1 respectively) dwg AB20 - 2 of 4 5) Provide cond. Size from 5 kv main section -6 5 kv dist sections in new unit substation 'Ti' - dwg AB20 - 2 of 4 6) Provide appropriate clearance to 1500 kva xfmr in 12th floor switchgear room - dwg FP 20- 2 of 2 7) Verify that ATS-1 &amp; ATS - 2 feed optimal stand by loads. 8) Verify compliance with 700.6 (G) 9) 1000 kva xfmr secondary OCPD is overfused - dwg AB20 4 of 4 10) Verify listing of generator &amp; 1000 kva xfmr &amp; penn - panel switchboard. 11) Verify GF protection &amp; provide coordination and short circuit study. 7/16/18 - 1) Provide GFP at 480V side of new portable gen substation - dwg AB20 1 of 4. 2) Coordination study doesn't include the whole scope of work. 3) Clarify routing of cond. Of the portable generator to confirm routing is not entered into the building. 4) Provide submission \$ of normal service feed connected to new unit substation "T1" and "T2". With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/4/19 - 1) Conductor feeds distribution switchboard 'CB' is undersized - dwg # AB20-04. 2) Confirm that you followed the recommended settings within coordination study. 3) Verify the NRTL listing of existing distribution switchboard 'CB' after the addition of new section.</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55387	18A0028	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Jockey pump cond is undersized &amp; provide tap length 2) Cond feeds 1000kva xfmr is undersized (xfmr primary) 3) Verify that the primary OCPD energizing 1000 kva xfmr is rated for in rush current. 4) verify ATS # of poles note &amp; F.A. ATS - remove the note. 5) Provide cond size feeds load bank 6) Provide coordination between 3000A C.B. &amp; downstream breakers in 'EMDS-1' signed and sealed by P.E. 7) Verify ground fault current protection of 3000A C.Bs - sec 230.95 &amp; 1200A 8) Provide rear doors or captive screws or suitable latches to "SB-A" &amp; "SS-A" with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/26/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.6/14/2021 Approved dwgs# 1,2,3 &amp; 4 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55573	18A0047	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination between new 3000A KRPC &amp; upstream existing fuse "4000A KRPC" 2) Verify tap length ( not over 25ft) 3) Provide ACP-5 # on the dwg 4) Verify FP controller AIC Rating is 100 KA or 150 KA 5) Comply with 695.3(A)(1) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/5/18 - Provided TCC to be signed and sealed by P.E. 8/2/18 - 1) Comply with 695.3(A)(1) 2) Comply with 408.60(E)(3) for bus bars connected to 3000A switches 3) Bus bars different than cond. 11/20/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55588	18A0124	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Grounding cond for 'T-FP22' xfmr secondary is undersized 2) Verify compliance with 760.41(D)(4) - for fire alarm emergency side. 3) Verify vertical bus size in "DPH-9-LS(I) &amp; (II) 4) Comply with 408.36 for "Gen-SWBD" 5) Conductor between sections of 'DPH-25' is undersized 6) Verify OCPD valves ( main &amp; emergency) that feed 'DPH-9-EM' panel 7) Floor plan doesn't match one line &amp; physical MSA &amp; MSB switchboards. 8) Verify applying the recommended settings of the adjustable trip circuit breakers - page 2-2 coordination study - &amp; provide the rest of the coordination study page 4-4 9) Coordination one line doesn't match submittal one line. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/19/18 1) Provide F.A. transformer secondary cond length show F.A. disconnect switch in floor plan in relation to transformer.. 11/28/18 Job finalized.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/11/2020 Amended Dwgs # 1 Rev 4 2 , 3, 4, &amp; 5 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/28/2021 Amended Plans# 1 Rev 4, 2 Rev 5 , 3,4,5 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/6/2021 Amended Plans# 1 Rev 4, 2 Rev 5 and . 3,4,5 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55496	18A0131	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination of OCPD (27.30181) (1 RCNY 3505.C(1)(E)(0). 8/23/18 1) Coordination between 16A00A KLLU SS#1 and downstream 500A FLNR fuse not included within coordination study.. 9/26/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/27/2021 Amended Plan # 1,2 &amp; 3 of 3 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/6/2021 Amended Plan# 1 of 3 Rev 4, 2 of 3 Rev 4, 3 of 3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55457	18A0199	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify grounding and bonding to existing service switch board DS-B &amp; D add note to the drawing. 2) Verify new fuse size 400A or 200A. 8/24/2018 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55290	18A0235CO	Special Permission	Approved	\$0.00
Carry over from March 28, 2018 meeting. With the stipulation no splices are permitted in the shaft. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55291	18A0236CO	Special Permission	Approved	\$0.00
Carry over from March 28, 2018 meeting. With the stipulation no splices are permitted in the shaft.. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0293	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) tap cond from exist 1200A 16th floor swbd &amp; exist passenger elevator swbd are undersized and provide the existing bus size for both taps - dwg # C 2) Provide 5' clearance to F.A. S.SW 3) Provide available S.C current at 'EM-DP' &amp; 'LRSP' panels and provide cut sheets. 4) Show grounding to xfms secondary. 5) Provide coordination between 800A br &amp; downstream fuses in exist 800A 2nd sub-cellar owner switchboard and between 400A FRN fuse &amp; upstream fuse 11200A A4BQ 6) Provide asbestos abatement compliance doc. 7) Verify using manual F.P. Controller with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
55374	18A0295	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination for OCPD (27.3018.I). 2) Connect voltage for trans on floor plan. 6/28/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/9/2020 Swap dwg #AB20-01 of 2-Revision; dwg AB20-02 of 2-Revision 1; FP20-01 of 1-Revision 2; SB10-01 of 3-Revision 4; SB10-02 of 3-Revision 4; SB10-03 of 3-Revision 3 and SB12-01 of 1-Revision 1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/19/2023 Amended Plan # 1, &amp; 3 of 5 Rev- 4 and Plan # 2 of 5 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55411	18A0297	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Selective Coordination study to be stamped, signed and sealed by P.E. (1 RCNY34-05) 8/3/18 - Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/7/19 Swapped dwg AB21-1 of 3-Revision 1 and dwg AB21 3 Of 3-Revision 1.				
56067	18A0298	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Fix typo in the following: a. Breaker size in note A9-Dwg# AB21-03. Cond size feed A2 & B2-Dwg #AB21-01 and AB21-04 c. Breaker size in B9 note-Dwg #AB21-06 d. Breaker size in A10, B7 & A7-dwg #AB21-07. 2) Verify rating of "CDP-UPS-A" dist. Switchgear dwg #AB21-03 (Fix the typo) and cut sheet doesn't match one line. 3) Conds. Charge UPS #A1, A2, B1 and B2 are undersized. 4) Verify the not mats address on the provided coordination study. 5) Show neutral bonded and grounded as SDS on the dwg-dwg AB21-OL. 6) Verify frame size of Gen mounted circuit breaker-one line doesn't match related provided doc. With transmittal no. TRN00015. 7) Cut sheet of "TA-8-DP-E-M-B1" and "TA-5-DP-M-AC-B" don't match one line. 8) Comply with 408.60(E) (2). 9) Provide large size dwg for coordination one line with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/19/19 1) Follow recommended setting to coordination study. 8/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/1/19 Swap Dwg # 23547FP61-01 of 3, -02 of 3, -03 of 3 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55361	18A0299	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide grounding & bonding to new 1200A S.S.W. 7/5/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55275	18A0308	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55881	18A0311	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination of OCPD (27-3018-I) 2) Verify providing mechanical ventilation (34-05.c(1) EM 3) Verify clearance &amp; working space dimensions. 4) Verify that the primary OCPD energizing 1500kva xfmr is rated for the in rush current 5) verify listing for 'HS-1' 'MV-H'. 11/8/18 1) 1000 KVA transformer "XF-H2" secondary cond are undersized. 2) 3000A C.B. and downstream 2500A C.B. and 300A MV fuse and 200A MV fuse are not coordinating - "TCC1-1" and "TCC1-a" * with stipulation that the NRTL field evaluation report of : "MV-H" is to be kept on site for inspector's review. 3/1/19 1) 1000 KVA xmfr "XF-H2" &amp; "XF-H3" secondary bus bars are undersized. 2) Item #2 from last revision not addressed. 4/9/19 1) Item #2 from last revision still not addressed. 5/2/19 Job finalized. "With the stipulation that the NRTL field evaluation report of "MV-H" is to be kept on site for inspector's review". 5/26/2021 Amended Plan# A Rev 7, B Rev 6, C Rev 8 and D Rev 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55486	18A0313	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - 1) J.P. tap cond is undersized- sec 430.28 2) Jockey pump equipment grounding cond is undersized - 250.122 3) Provide the location of the tap box. 4) Provide 5' clearance for F.P. S.SW 5) Provide available S.C. current at F.P. controller 6) Existing service bus is undersized - 230.42 (A)(2) 8/3/18 - Item # 1 &amp; 2 not addressed.. 9/25/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/29/20 - swap dwg#D Rev 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55348	18A0318	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - 1) Provide coordination between new 1600A A4BQ &amp; upstream 5000A KRPC fuse signed and sealed by P.E. 6/27/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55373	18A0348	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 5/9/18 1) Provide Asbestos Abatement compliance document . 2) Provide existing bus size of the new switches in switchboard A1 &amp; A2. 3) Verify that 1200A fuse energizing the 500KVA transformer is rated for inrush current. 7/18/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55349	18A0349	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Jockey Pump tap length. 2) Provide F.P. from cond transition tap/box to fire pump controller and fire pump and the location of transition/tap box.. 6/27/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/19 - Swap dwg #A, B, & C Rev-2. 12/9/19 Swap Dwgs A rev 3, B rev 4, C rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55277	18A0351	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/17/18 Swap Dwg #B-Rev-1.				
55451	18A0352	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Verify that F.P. cond on the load side of the OCPD kept entirely independent of all other wiring - sec 695.6(B)(1) 2) Verify that available S.C. current at F.P. controller is within the F.P. controller rating. 3) Provide asbestos abatement compliance doc. 8/22/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/2/19 Rev. 2, Swap, Drawing No D-1804-30163-A Rev #2. 2/21/2020 Swap Dwg #A-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55364	18A0355	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide selective coordination study of OCPD performed , signed sealed by P.E. 2) One line does not match equipment cut. 7/12/2018 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/26/2018- Swap Dwg 1 & 2 rev 1. 8/15/19 Swap Dwg #1 and 2 Rev.2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
	18A0356	Special Permission	Denied	\$350.00
Installation shall be submitted to Electrical Advisory Board for review.				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55771	18A0358	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) EGC of 800A dis. Sw (feeds rectifier) is undersized DWG # E-1 2) Provide secondary cond size of 300 kva xfms &amp; step up 75 kva xfmr and primary cond size of step down 75 kva xfmr 3) Remove bonding from AT &amp; T wireless dist. Panel - xfmr secondary bonding &amp; grounding to be only in one location dwg # 56 - EL 4) Provide cut sheet of AT&amp;T dist. Panel, xfms showing listing. 5) Provide asbestos abatement compliance doc. As per DOB April change note - provide ACP-5 form 6) GEC of new S.S.. # 6 is undersize - T-2250.66 dwg # 56-E1 7) verify clearance of service disconnect # 6 clear of all obstruction. 8) Verify the current connection of step up 75 kva xfmr 9) verify grounding at SS# 6 &amp; 75 kva xfmr primary &amp; the incoming service connection service. 10) verify mechanical ventilation for electrical room. 11/19/18-1) Comments #1,5 and 6 are not addressed. 2) Comments #4 is partially addressed. 3) Verify installing the new exhaust fan doesn't affect 2 hr fire rated construction of existing service room-dwg #56-E1. 3/14/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55274	18A0359	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55367	18A0361	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide mechanical ventilation to electrical service room(34-05.c(1)EN) 2) FP fuse undersized 3) Verify gen SDS or Mon SDS 4) Provide available short ct at fire pump controller (34-05((1)EN) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/8/18 - Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/12/19 Swap sheet 1 of 1 rev 2. 6/29/2021 Amended Plans# 1 of 1 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/15/2021 Amended Plans# 1 of 1 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/16/2021 Amended Plans# 1 of 1 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				



# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55407	18A0363	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide selective coordination of OCPD (27-3018.I) 7/2/18 - Provide asbestos document 8/1/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/21/18 Swap dwg #B-Revision 3				
55462	18A0365	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) SS#1,2 and 3 are backwards. 2) Provide selective coordination for OCPD(27-3018.I). 7/26/18 1) Service bus bars feed ss# 2 and 3 are undersized. 9/7/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/27/2018- Swap Dwg 1 & 2 rev 1.				
55399	18A0366	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide selective coordination of OCPD (2703918 I) - include short circuit after meter banks 2) Fix typo of service Sw# 4 repeated in room layout 7/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55452	18A0367	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) SSW#1 is backward. 2) Provide coordination and short circuit study. 8/21/18 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/24/19 Swap Dwg # AB-18293-A.1 rev. 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
56172	18A0368	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide asbestos abatement compliance documents. 2) comply with 695.3(A)(1) 3/26/19 1) Special permission is required to comply with 695.3(A)(1) 2) Comply with 110.26(A)(2) - provide 30" width of working space to 30A fire alarm service switch. 4/15/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/12/2022 Amended plan # AB Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55516	18A0369	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with 408.60(A)-ND.L to be on the load side of grounding and bonding with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. .2) Provide coordination study signed and sealed by P.E. and provide available s.c. current at f.p. controller. 8/23/18 1) Verify incoming service cond. From S.E.B. to Time Warner and 800A service switch #2 are concrete encased. 2) Provide "EGC" size to all MC cables. 3) Provided coordination study to be signed and sealed by P.E. 4) Include all 1st and 2nd level of OCPD to coordination study. 5) Verify following recommended settings of coordination study. 10/4/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.. 4/6/2020 Dwg 1 of 1-Revision 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55278	18A0371	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55321	18A0373	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 5/9/18 1) Verify if you are replacing fused in ss#1 and 2 for some like in kind and provide the vertical bus size for ss#1 & 2 6/8/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/24/18 Swap Dwg B-Revision 3 2/28/2019 Swap Dwg B - Rev 4				
55288	18A0374	Special Permission	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55276	18A0377	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos doc. 5/11/18 OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/27/18 Swap dwg #16342				
55893	18A0378	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) correct typo in physical drawing from EDPR to SEDP panel. 2) Provide manufacture cut sheets for all equipment. 3) Provide selective coordination of OCPD 927-3018 I) 4) Verify mean of egress from switchboard room leads to legal exit (34-05.c(11 EH) 5) Provide signs posted at each entrance door &amp; each room when more than one service location 6) Verify ATS are 3 pole or 4 pole &amp; verify GEN is SDS or not.. 11/2/18 1) Provide short circuit study of all new equipment all OCPD within manufacturer ratio. 11/9/18 2) Fire pump "GEC" and EGC are undersized-T250.66 and T250.122. 3) Provide grounding and bonding to FA service switch (normal side). 4) Verify location of Jockey Pump tap box, inside or outside fire pump room. 5) Jockey pump tap cond is undersized. 6) Comply with 760.41(A)(1)-FA tap to be before N.D.L. 2/7/19 Item #5 from last revision is not addressed-Jockey Pump tap cond is still undersized, follow tap rules. 5/7/19 - This drawing is approved</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55680	18A0381	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify # of sets of service entrance conductors (not matching room layout &amp; one line diagram) 2) FP conductor undersized 3) Correct typo 3000 A CT no 4000 A CT in one line diagram 4) provide manufacture cut sheets for all equipment. 5) Provide selective coordination &amp; OCPD (27-318.I) (1 RCNY 39.05.C (1)(E)(0). 11/7/18 1) Provide 7' clearance between "FAI-SSW" and main ss#1 and 5' clearance in front of "FA2-SW" 2) Item #4 is not addressed. 1/24/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/10/19 Swap Dwgs 1 of 3-Rev 3; 2 of 3-Rev 2 and 3 of 3-Rev 1. 11/1/19 Swap Dwgs 1 &amp; 3 of 3 rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55453	18A0382	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Provide coordination study for OCPDs (27-3018.I).. 5/23/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55822	18A0383	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination of OCPD (27-3018-I). 2) Provide required 2hr fire rating of electrical service room(230.64B). 3) JP not permitted to be tapped from TR secondary conductor. 4) F.A. transformer emergency side required secondary protection. 5) Verify JP tap conductor follow tap rule (240.21B). 6)Verify Tr sec grounding and protection (408.36B). 7) Provide coordination for life safety equipment (517.17B). 7/20/18 1) Fire pump EGC is undersized. 2) Item 1 is not addressed. 3) Secondary OCPDs of 750KVA transformer are overfused Sec-450.3B-"MDP-A" switchboard. 10/16/18 1) Fire pump EGC-emergency side-is undersized. 2) GEC of Jockey pump is undersized. 2/27/19 1) Item #1&amp;2 from last revision is not addressed Please refer to T250.122 for "EGC" and T250.66 for "GEC" 2) Fire pump OCPD -emergency side- is overfused. 4/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/9/19 - Swap dwg # D Rev-5. 7/17/2020 Amended Plan # D Rev-6, # C Rev-4 &amp; #B Rev-2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/30/2020 Amended dwgs# A Rev 2, B Rev 2, C Rev 4 and D Rev 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/28/2021 Amended dwgs# A Rev 3, B Rev 2, C Rev 4 and D Rev 9. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55281	18A0386	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/30/18 Swap dwg1 and Revision 1.</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0387	Special Permission	Denied	\$0.00
Provide documentation for conduit at each floor(photo).				
55296	18A0389	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55298	18A0390	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55464	18A0391	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide asbestos abatement compliance required documents. 2) Provide short ct at fire pump controller (34.05.C(1)EN) 3) Verify clearance around ATS-T4 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/26/18 1) Ground electrode cond. (GEC) for 200A ss#3 is undersized-Table 250.66. 2) EGC of FP2 tap is undersized. 3) Provide cond size feed emergency side. 4) Provide coordination between 1200A breaker &amp; downstream breakers. 9/6/18 1) GEC of fp#1 is undersized. 2) Verify GFI or GFP to service switches above 1000A. 9/12/18 Job finalized.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/20/18 Swap Dwg 2-Revision 4</p>				
	18A0392	Special Permission	On Hold	\$0.00
Provide a sample or a mockup of proposed outlet concealing cover.				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55282	18A0393	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55285	18A0394	Special Permisison	Approved	\$0.00
Installation and inception shall be in accordance with 2014 NEC, Article 690.Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55280	18A0395	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/27/18 - swap dwg 3 Rev 1. 10/16/18 Swap dwg #3-Revision 2 11/19/18 Swap Dwg #1 and Revision 3. 9/20/19 Swap dwgs 1 & 2 of 3-Revision 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 5/26/2020 Swap drawings # 1, 2 & 3 Rev5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs .				
	18A0397	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
<p>1) Remove bonding from "FA-SW-E1", "FA-SW-E2" and FP-SW-E with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Primary and secondary OCPD of transformer T6 are overfused. 3) Comply with 695.5(A)(2)-Remove FP-SW-E on the secondary of T7. 4) Verify 2hr fire rated to F.P. cond-emergency side-connected to secondary of transformer T7 &amp; the location of the transformer and 2nd FP-SW-E. 5) Provide coordination study signed and sealed by P.E. 6) Conds connected to LVP-SW are undersized. 7) Verify 'LVP-KCA' rating and provide cutsheet. 1/23/19 This job is void in lieu of Submission #19A0005.</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55472	18A0398	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Asbestos Abatement compliance document. 2) Provide coordination and short circuit study. 3) Provide UL certification for precision switchboard. 9/19/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55916	18A0399	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fix missing on drawings. 2) Provide Asbestos Abatement compliance required document. 4) Provide selective coordination of OCPD (27-3018.I). 5) Provide available at fire pump controller(34-05.c (1) (e)(N). 6) Jockey pump tap conductor shall follow tap rule (240.21.B). 7) Provide supplemental ground (250.53D2). 8) Provide physical drawings for all equipment.. 3/25/19 1)Tap conductor feeds 100A switch is undersized. Also confirm 10' tap length 2) Provide conductor size feeds solar panel 3) Provided coordination study shall be signed &amp; sealed by P.E. 4) Verify 1200A s.sw is A4BQ or A4BY coordination study doesn't match EAB one line. 5/20/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/11/2021 Amended Plan # A041801 Rev- 3.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/19/2021 Amended Plan# A041801 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55865	18A0400	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with 408.60(A) - NDL to be on the load side of bonding and grounding. 2) Provide available S.C at 'LPC' &amp; 'LPB' &amp; 'HDPB' panels. 3) Provide coordination between 2000A fuse (S.SW # 1) &amp; downstream fuses. 4) Bond metal fence to equipment grounding system. 3/8/19 - 1. Item #3 addressed but study needs to be performed by P.E. and signed &amp; sealed - also verify fuse type of SS#1 is A4BY or A4BQ for one line dwg doesn't match coordination. 2. Provide conductors size feed SS#2, 3, &amp; 4 on one line dwg. 4/25/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.. 8/10/2021 Amended Plan # A Rev 3 . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55577	18A0401	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination between ssw #2,3 and 4 and downstream breakers in meterbanks. 8/16/18 1) Item #1 is not addressed-provide coordination between ss#2, 3 and 4 and downstream br Section 240-12. 2) Verify # of incoming service conds.. 11/23/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55708	18A0403	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply with 110.26A(2) for 200A D.S in floor plan 2) Service entrance cond is undersized 3) Verify flame retardant plywood is 2 hr fire rated - provide documentation. 10/29/18 1) Provided document for flame retardant plywood doesn't show NRTL listing to be used as 2hr fire rated. 2/8/19 Ok, with stipulation that it is contractor responsibility to comply with Chapter 33 of NYC Building Code, 2 HR Fire rated construction is not warranted to temporary service unless there are hazards adjacent to the temporary electric service. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0404	Special Permission	Denied	\$350.00
	18A0405	Special Permission	Denied	\$350.00
Construction code variance shall be submitted to the borough office with CC D1 form.				
55350	18A0406	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance required documents. 2) Provide supplemental ground (250.53D2) 3) Provide coordination study of OCPD (27.3018.I). 6/7/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0407	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR - 1) Provide asbestos abatement compliance doc.				
55403	18A0408	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance required document. 2) Provide selective coordination of OCPD (27-3018.I) 3) Provide mechanical ventilation when service equipment totaled 2000 KKVA or larger ( 34--05 C(1 ) EM) 7/27/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				



# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55320	18A0410	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination between 400A TR fuse and upstream fuse signed and sealed by P.E. 6/7/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/4/18 Swap dwg 1-Revision 1				
55311	18A0411	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide selective coordination OCPD 927-3018.I) 5/29/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55289	18A0412	Special Permission	Approved	\$0.00
Provide physical protection such as plywood wall with doors to allow access. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55279	18A0413	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/3/19 Swap Dwg No. AB-18298-A.I-Revision 1 11/6/19 Swap Dwg # AB-18298-A.1 (1/1) Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55353	18A0414	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide Asbestos Abatement compliance required document sealed and signed . 2) Provide drawing with standard size. 3) Provide selective coordination of OCPD short circuit study calculations 4) Make new and existing installation ( bubble or bold) on drawings ( 34-05.c(1 )EB). 6/25/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0415	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Verify fire pump voltage 2008 or 480 2) Provide asbestos abatement compliance required documents (April 2017 notice) 3) Provide selective coordination of OCPD (27-3018-I) 4) Verify mean of egress from switchboard room leads to legal exit (34-05.C(1)EH) 5) Verify for more than one service location signs posted at entrance door of each room (34-05(2)EI) 6) Show service entrance equipment at point of service entrance shall be grouped (34-05.C(1)EL) 7) Provide mechanical ventilation (34.05.C(1)EN) 8) Provide short circuit at fire pump controller (34-05.C(1)EN) 9) Provide required 2 hr fire rating of electrical service room (230.64B) 10) Provide panic hardware in electric room containing OCPD (110.26(C)(3)) 11) Physical drawing and one line diagram don't match in Sb1G - distribution section # 2 &amp; SB2F distribution section # 1, SB2G-Section 1 &amp; Section 2 swapped 12) Verify # of set of SEC of SB2 &amp; SB2F 13) Verify ground fault coordination on 208 VAC system</p>				
55286	18A0416	Special Permission	Approved	\$0.00
<p>Installation and inspection shall be in accordance with 2014 NEC, Article 690 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55651	18A0417	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Asbestos Abatement compliance required documents with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.            NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.(BC 2702.1.2). 2) Provide selective coordination of OCPD (27-3018-I). 3) Provide available short circuit at fire pump controller (34-05 CC1 EN). 4) Provide mechanical ventilation (34-05.CC1)EM 14). 5) Provide equipment manufacture cut sheets. 6) Provide vertical bus bar size in generator distribution board. 7) Verify F.P. Listed for fire pump use. 8) Life safety wirings shall comply with (700.9B5). 9) Provide supplemental ground (250.53D2) 10) Provide barrier between optional standby and life safety (300.3C1A).. 10/10/18 1) Verify that limited service fire pump is located above street level-Section 695.2. 2) Provide OCPD and Cond. Valves that feed "SP-ATS", "SB1-ATS", and "LS-ATS"-Normal side. 3) Special service fire pump OCPD is overfused Section 295.4(B)(1)(2). 4) Provide AIC rating and available s.c. current of fire pump controller. 12/26/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/25/2020 Swap dwg 1-Revision 5 and dwg 2-Revision 6. 7/6/2020 Amended Plan # 2 of 2 Rev-7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**May 16, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55450	18A0419	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination of OCPD (27-3018.I) 2) Provide manufacturer cut sheets for all equipment. 8/21/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/2/2020 Dwg amendment. Dwg 1,2 &amp; 3-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				