

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
	14A0551CO	Requested approval for the electric service equipment proposed to be installed	Pending	\$0.00
Carry over from October 22, 2014 meeting. New transformer not properly protected on the primary side; and secondary of transformer not grounded on line drawing.				
53107	14A0568	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that rear covers on switchboard "MDBW" are not removable. 2) Clearance in front of 15 KV switches to comply with Table 110.34(A) and around the equipment in the back. 3) Switchboard MDBW room to be mechanically ventilated. 4) Verify length of transformer secondary conductors. 5) Verify that this is one building with common area access to all service rooms, verify compliance with Article 225 Part 2. 6) Bond at the sync gear instead of individual gen bonding with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/25/15 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/25/19 - 1. Comply with 700.10(E)(2) and 760.41(D)(4). 2. Provide 4pole ATS to FA. 3. Fire pump GEC & EGC are undersized. Tables 250.66 & 250.122: Service "2": EGC of 125HP fire pump and EGC & GEC of 75HP fire pump. Service "1": EGC of 125HP fire pump. 4. 75HP fire pump conductor is undersized. 5. All doors shall be equipped with panic bars -- 110.26(C)(3). 4/8/19 Swap Dwgs 1 of 3 rev 4 and 2 of 3 rev 3. 11/8/19 Swap Dwg # 34923110AB (1/3) Rev 5 and (2/3) Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
	14A0707	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Section bus undersized for 2-1200 amp switches in "MSB-B" switchboard. 2) Fire pump equipment grounding conductor undersized on load side of service switch. 3) Correct room layout scale. 4) Show conductors to load bank. 5) 3 and 4 pole ATS mixed, verify bonding and grounding of generator, 4 wire systems used.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53332	15A0044CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from March 18, 2015 meeting. Provide EAB calendar number for the existing generator. 11/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53520	15A0046CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from March 18, 2015 meeting. 1) Transformers FA-A & FADs not protected. 2) Confirm that the controllers are limited service controllers. 2/16/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/5/16 Swapped drawing FP50-01-Revision 3.. 6/25/18 Cond. Connected to 3000A s.sw in "MS-A" is undersized. 2) Verify # sets of gnd and conduits from 500A fuse in "MS-A" to transformer T!1. 3) Provide vertical bus size in 2nd section of new 'PP-H63' panel. 4) Verify NRTS listing of 'D-ODP' switchboard with new changes. 5) Provide coordination between new 400A C.B. and upstream fuse and 600A breaker in 'TDP-63' panel and upstream fuse. 6) Provide bonding and grounding to new 30A dis-sw-dwg 2 of 3 . 7) Reflect new changes to 'MS-B' switchboard on physical dwg. 8) Provide appropriate clearance to new quadlogic. 10/26/18 Swap Dwg # AG50-1 of 3-Revision 3; Dwg AB50-2 of 3-Revision 4; Dwg AB50 3 of 3-Revision 3; Dwg SB50-1 of 4-Revision 6; Dwg SB50 2 of 4-Revision 5; Dwg 4 of 4-Revision 3; Dwg FP50-1-Revision 5 and Dwg SB50-3 of 4-Revision 1. 3/26/19 Swap dwg #AB50 1 & 3 of 3 rev 3 Dwg AB 50 2 rev 5				
53035	15A0049CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from March 18, 2015 meeting. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53104	15A0135	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify which way the generator switch is facing. 2) Incoming fault current not shown. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/23/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/25/16 Swapped drawing E-Revision. 2/3/17 - swap dwg E Rev-5</p>				
53198	15A0143	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>New feeders are overfused. 8/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53147	15A0150CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from March 18, 2015 meeting. 4/0 fused at 400 amps emergency board. 7/28/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/3/15 Swapped Drawing 4 of 5, Revision 1.</p>				
	15A0188CO	Requested approval for the electric service equipment proposed to be installed	Pending	\$0.00
<p>Carry over from March 18, 2015 meeting. 1) Clearances of equipment to comply with 230.64(B). 2) Rear of equipment to comply with 230.64(B)(4) or 408.60(F).</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0191	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
<p>Service room doors to open outwards with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/23/15 Job finalized. This drawings is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.2/10/17 1. Provide 5' clearance in front of SS # 1 2. Verify 3 wires off generator to FA Sws and 4 wires off FA sw to ATS. 3. Emeergency side- explain neutral cond feeding FP.with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/5/17 - void in lieu of 17A0440</p>				
53038	15A0208	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/26/16 Swapped drawing 1 and 2-Revision 1.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53835	15A0214	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) S.S. #1, verify that load side bus is over 4' in length, no height of equipment shown. . 2) Fire pump emergency feeder to 50 HP fire pump undersized. 3) S. S. for 75 HP fire pump is undersized. 4) 50 HP fire pump mislabeled as special service fire pump and indicates wrong FLA. 5/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 4/19/18 - 1) Provide coordination between 900A LCL fuse & downstream fuses and between SS # L 2000A LCL & downstream 400A AJT Fuse. 2) Cond connected to SS# 1 is undersized. 3) Verify that CoGen sys is connected after 2nd level of OCPD 4) Provide Tap length for retail # 8 - Tap cond is undersized. 6/25/18 1) Tap cond for retail #8 is undersized-Sec 240.21(B)(2). 8/2/18 - swap dwg# 1 of 3 Rev 4; 2 of 3 Rev 1; 3 of 3 Rev 1 11/27/18 Swapped Dwg # 1 of 3 and 3 of 3-Revision 5. 1/9/19 1) Remove bondign from 400A and 600A switches feed EDP and EDH panels respectively-emergency side. *Note that service switch #2 900A fuse and 500A ECSR downstream fuse are not coordinating. 1/29/2019 Swap dwg #2 of 3 Rev-6, #1 of 3 Rev-7 Last Swap</p>				
53022	15A0238	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0239	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/13/17 Rejected. Water main ground undersized for 3/0.				
53021	15A0244	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0254	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) Tap of a tap is not permitted. 2) Existing taps off of existing service switch are not protected, dangerous condition, tap rules not followed.				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53052	15A0255CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from April 15, 2015 meeting. 1) Drawings do not indicate Revision 1. 2) Verify MI cable installed in conduits. 3) Add note on drawing that all ATS' are 4 pole except fire pumps. 4) Explain how portable generator will connect to 4000 amp disconnect switch. 5) Verify if system is separately derived system or not and indicate bonding accordingly. 6) Provide neutral disconnect to completely isolate the neutral from other sources. 5/28/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/19/16 Swapped Drawing 1-Revision 3 and Drawing 2-Revision 3.3/17/17 - swap dwg 1 of 3 rev- 4</p>				
53144	15A0258CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from April 15, 2015 meeting. 1) Correct voltages on drawings and indicate 3 wire system. 2) Provide sequence of operation. 7/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/24/18 - swap dwg No. D-510034 Rev 2</p>				
53143	15A0259CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from April 15, 2015 meeting. Provide sequence of operation of key system. 7/22/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/24/18 - swap dwg 1 of 3 Rev 2</p>				
	15A0262	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>1) 12 pages of drawings submitted, all that is needed are pages 7 and 11 other drawings don't pertain to 1000 KVA service installation. 2) Drawings are not in Advisory Board format. 3) Tapped conductors are undersized. 4) Short circuit study to be provided by a PE bearing the stamp. 5) Bonding and grounding of existing service equipment not shown. 6) Bus bar sizing not shown. 6/23/15 Rejected 1) Bonding and grounding of main switchboard not shown on 1 Line. 2) Verify that tapped conductors are not over 25' in length. 3) Cut sheet of new equipment not provided. 4) Explain 1/0 to ground bar coming out of new equipment that is second fused.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0263	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Verify bus sizing, cut sheet and 1 Line. 2) Show size of system bonding jumper. 3) Provide vertical bus sizes. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
53040	15A0265	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	15A0266	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
<p>1) Address on drawing to be 140 West 62nd Street. 2) Neutral in generator is bonded and grounded using 3 pole ATS'. 3) #6 MI cable undersized for fire pump, normal feeder to fire pump not fire rated. 4) Section bus in "MDB" undersized. 5) Verify that line and load are not mixed together on load side of the 1600 amp switch. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. This job is void in lieu of Sub. #15A0587.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53197	15A0268	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>4/0 MI cable undersized to FP-2 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/20/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/28/15 Swapped drawing 1,2,3-Revision 7. 5/3/18 - swap dwg - 1,2, & 3 Rev 8 1/10/19 Swap Dwg 1,2,&3 Rev 9. 7/2/19 Swap dwgs 1, 2 and 3-Revision 10. 12/11/19 Swap Dwgs 1, 2 & 3 Rev 11. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. No More Swaps.</p>				
53356	15A0269	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show concrete encasement of SEC up to service room. 2) Show cut of the splice chambers. 3) Show circuit breaker trip settings on 1 Line. 4) Bus sizing to be on 1 Line drawing not chart. 5) Correct typo on ring bus B-B. 6) Show connection point of snubbers and transformers. 7) Clarify ground points of hold equipment and transformers. 8) Provide ground fault protection of equipment. 8/19/15 Rejected 1) Provide manufacturer's heat rise test report for switchboards. 2) Have coordination study signed and stamped by a P.E. 12/7/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53120	15A0271	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1) Tapped conductor off of 800 amp fusing is undersized, length of tap not shown. 2) Show length of transformer secondary conductors for fire pump. 3) Explain open air conductors off of generator, not allowed. 4) Fire pump and fire alarm system transformer voltages mismarked on 1Line. 5) 480 volt 1200 amp switch to be ground fault protected with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/30/15 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53041	15A0275	Requesting permission to install corrosion-resistant jacketed mc cable outdoors underground as per Table 300.5 for amusement park wiring.	Approved	\$0.00
Code: 300.5(A), 330.10(5). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53042	15A0276	Requesting permission to install corrosion-resistant jacketed MC cable outdoors underground as per Table 300.5 for amusement park wiring.	Approved	\$0.00
Code: 300.5(A), 330.10(5). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53412	15A0277	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify existing 8 sets of 500 KCM feeding 5000 amp service switch #2, or reduce fusing. 2) Existing 5000 amp fuse to new 2000 amp fuse are different fuse types. 3) 600 amp ATS to be 4 pole between 2 points of entry. 7/20/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/29/17 - swap dwgs C & D rev 2. 7/6/18 1) Provide coordination between 5000A KTA fuse and downstream signed and sealed by P.E.. 10/10/18 Swap dwg #D-Revision 3. 1/10/19 Swap dwg D-Revision 5. No more Swaps.				
53017	15A0278	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 5/5/15 Advisory Board approval limited to solar photovoltaic system final connection to utility. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0281	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/12/17 - void in lieu of 17A0269				
53145	15A0282	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Tapped conductors undersized See 240.21(B)(1). 2) Existing 3000 amp switchboard fused at 4000 amps. 7/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53180	15A0284	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Correct address on drawings and contractors name. 2) Verify that switchboard will comply with 408.60(F). 3) Secondary of transformer to be bonded and grounded in one location not two. 4) Will the public be walking through the service room to get to the storage rooms? 8/17/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53141	15A0285	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Is 2nd floor vault room new? 2) Equipment grounding conductor to 400 amp service switch undersized. 3) Show lengths of tapped conductors off of 400 amp switch. 4) Equipment grounding conductor to 100 amp disconnect switch undersized. 5) Service switches misidentified as #2. 6) What level of the building is the existing service room located on? 7) Provide cut sheet of ceiling tap box 1 A. 7/21/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53043	15A0286	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53044	15A0287	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53379	15A0288	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>I. F.P. SS. Undersized. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/18/15 1) Provide short circuit 5/19/2017 - swap dwg 1 rev - 5 (No More Swaps)</p>				
53118	15A0289	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Submit Siemens equipment cut for sections and cb. 6/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53113	15A0290	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
7' clearance required in front of service switchboards facing each other. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53112	15A0291	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify amount of sets of service entrance conductors to 800 and 2000 amp service switches. 2) Tap conductors to 2-600 amp switches undersized 25' tap. 3) Provide coordination study for fuse supplying circuit breaker panel. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0294	Requesting permission: 1. Requesting permission to allow the use of seacoast marine type wiring to power the fire alarm system for a floating detention facility. 2) Requesting permission to allow the power for the fire alarm system to be tapped from the 2nd fusing off of the load side of the paralleling switchgear.	Administrative Closure	\$0.00
Code: 90.2(B)(1). Void See Article 90, Section 90.2(B)(1) and Article 553, Section 553.1. Although the scope of this code indicates that the code does not cover installations in ships, portions of this code are incorporated by reference into Title 46, code of Federal Regulations, Parts 110-113.				
53045	15A0295	Requesting permission to install listed 1000 volt solar photovoltaic equipment on three buildings.	Approved	\$0.00
201 West 27th Street, Manhattan; 3110 Avenue U/2245 Gerristen Avenue, Brooklyn and 83-30 118th Street-Kew Gardens, NY. With the stipulation that this permission is for the equipment use only and the PV installation is to comply with the 2014 NEC.				
53247	15A0299	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show circuit current at fire pump controller rated 100,000 AIC. 2) Verify that motorized valve switch is part of the fire pump. 9/14/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53264	15A0300	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Temporary switchboards installed permanently shall comply with 700.6(G). 2) DLO cables to be dual rated, provide cut sheet. 3) Installation of cable trays to comply with Article 392. 4) Provide drawing of how conductors will be installed in cable trays. 5) Provide cut sheet for cable trays. 6) Verify that temp switchboards are not located in the service room. 10/5/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53036	15A0301	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) S.S. #6C to be grounded. 2) Provide 2nd set of equipment cut sheets. Job finalized 5/21/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53119	15A0303	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Show coordination between 3000 and 2000 amp fuses in switchboards A and B. 6/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/23/16 Swapped drawing A-Revision 3. 5/18/16 Swapped drawing A-Revision 3, B-Revision 5, C-Revision 5 and D-Revision 3. 4/8/19 Swap dwg #A-Revision 4.				
53046	15A0304	Requested approval for use in New York City of your Single, 20A Low profile, Multioutlet Assembly and accessories. Model/Series Numbers: Thread, #PFLTRK, PFLTRKINF, PFLCNCTR, PFLHUB, PFLADPTR.	Approved	\$200.00
With listed accessories. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53047	15A0306	Requested approval for the electric service equipment proposed to be installed	Approved	\$350.00
Code: Section 220.43 (B) Exception Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53025	15A0307	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53059	15A0308	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Explain 2 electrical services for 2 separate buildings located in one service room, each separate building should have their own point of entry. 2) Verify that 90 Lexington Avenue switchboard is not feeding loads in 88 Lexington Ave building. 3) Indicate which building the meterbanks will be located in. 4) Equipment grounding conductor to MB-1 undersized. 5) Does fire alarm service feed 88 and 90 Lexington Avenue buildings? 6) Service entrance conductors undersized or provide load calculations. 7) Provide site plan indicating the two buildings and relationship between the two. 8) Provide details for 90 Lexington service end box. 5/29/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
53058	15A0309	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Explain 2 electrical services for 2 separate buildings located in one service room, each separate building should have their own point of entry. 2) Verify that 88 Lexington Avenue switchboard is not feeding loads in 90 Lexington Ave building. 4) Which building are the meterbanks located in? 5) Explain fire pump feeding 2 separate buildings. 6) Fire pump service switch not bonded and grounded. 7) Provide site plan. 8) Provide detail for 90 Lexington S.E.B. 5/29/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53048	15A0311	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53020	15A0312	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53206	15A0313	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show clearances in service room. 2) Relocate 60 amp fire alarm service switch. 3) Service entrance conductors to 2000 amp service switch undersized. 4) Fire pump emergency feeder to fire pump not fire rated, undersized. 8/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/18/16 Swapped drawing 1-Revision 2.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53101	15A0314	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Signage for additional service rooms to be posted on each service room door. 6/19/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/28/16 Swapped Drawing 1-Revision 2.				
	15A0315	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Fire pump, what is the distance of transformer secondary tap, overcurrent protection not provided for secondary conductors. 2) "DP-BIA" section and vertical bus undersized. 3) Switchboard "B" bus to service switch 2B is undersized. 4) B-MSBA section bus undersized. 5) S.S. 3c fuses don't coordinate with 200 amp 2nd fuses. 6) MSBA-1600 and 1200 amp fuses do not coordinate.				
53024	15A0316	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53023	15A0317	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/21/2021 Amended Plan # A Rev-1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
53018	15A0318	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 5/5/15 Advisory Board approval limited to solar photovoltaic system final connection to utility. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53598	15A0320	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Is the switchboard already installed? 2) Verify neutral disconnect links in 30 and 400 amp switches. 3) Coordination study recommendation is not addressed on plan 1-Line. 3/15/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/1/19 1) Provide busbar size in switchboards "EMDP-G5-MSB-1N1" and "EMDP-G%-MSB-1N2". 2) Trip size of breaker feeds "Shllow EM busduct"-emergency side-is overfused. 3) Provide coordination between 4000A transformer secondary OCPD and downstream breakers in new switchboards. 5/9/19 1) Provided coordination study to be signed and sealed by P.E. and requested TCC to be included. 2) Confirm address of the project on new dwgs #2144.SB60-08 of 9 and 9 of 9. 7/25/2019 1) Comply with 450.3(B) 2) Confirm if 4000A is upstream & new "EMDP-G5-MSB-1N2" swbd - show the connection in one line dwg. 3) Item #2 from last revision is not addressed. 4) Coordination to include P.E license #. 9/19/19 1) Coordination study does not match EAB one line plan in the 1600A circuit breakers setting in parallel switchboard. 2) Confirm the NRTL listing for the new 1000KVA transformer- provide cut sheet. 11/15/19 Swap dwg #AB51-1 of 2 and 2 of 2, Revision 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/14/2020 Swap dwg AB51-1 of 2-Revision 7, AB51-2 of 2-Revision 7 and FP21-01-Revision 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
53181	15A0322	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Drawings to have the 701 West 168th Street address. 2) Switchboards are misidentified. 3) Room layout and 1 Line drawings don't match. 4) Existing feeders to switchboards 2 and 3 are overfused. 5) Switchboards 2 and 3 vertical bus feeding 1200 and 1600 amp disconnect switches undersized. 408.60(B)(5). 6) Provide cuts of replacement switches. 8/17/15 Job finalized. Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53121	15A0323	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service bus feeding switchboard undersized or provide load calculations 230.4(A)(2). 2) Emergency side 3/0 fused at 225 amps. 3) Verify 150 amp fuse type panel "ODP". 4) Provide section view of service board. 5) Siemen cat and bus sizes must be submitted to verify 1-Line bus sizes. Job finalized. 6/30/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53115	15A0324	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump 40 HP is not special service fire pump as per NYC def. Provide correct size s.s. 2) With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PW1 as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53034	15A0325	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swapped Drawing 1, Revision 1.</p>				
53033	15A0326	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53032	15A0327	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53031	15A0328	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
53111	15A0329	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify 3' clearance in front of the Con-Ed service box. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/23/16 Swapped Drawing 1-Revision 2.				
	15A0330	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/24/15 Cal. #53049, Submission 15A0330 is void in lieu of Cal. #53398, Submission # 15A0810.				
53251	15A0331	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify amount of service entrance conductors in service trough. 9/16/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53030	15A0332	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53029	15A0333	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53116	15A0334	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Is transformer owner or utility owned, overfused. 2) Show fuse types in future disconnect switches or remove switch. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0335	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>Block the back This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
53028	15A0337	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR For final connection of solar photovoltaic system only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53027	15A0338	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53026	15A0339	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				