

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50203CO4	10A0245CO4	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	11 Fifth Avenue New York NY	Approved	\$0.00
Carry over from March 10, 2011 meeting.						
50360CO3	10A0381CO3	Star Delta Electric, LLC 17 Battery Place, Suite 203 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	40 Wall Street New York NY	Approved	\$0.00
Carry over from May 25, 2011 meeting. Elevator drawing does not show detail of whether end boxes are installed vertically or horizontally next to each other. Job finalized 7/12/11.						
50567CO2	11A0074CO2	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Long Island Jewish-Zucker 75-59 263rd Street Glen Oaks NY	Approved	\$0.00
Carry over from May 25, 2011 meeting.						
50572CO	11A0079CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Jamaica Water Pollution Control 150-20 134th Street Queens NY	Approved	\$0.00
Carry over from March 10, 2011 meeting.						
50624CO	11A0129CO	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	The NYCDEP Pumping Station 84 West 11th Street Brooklyn NY	Hold	\$0.00
Carry over from April 13, 2011 meeting. 1) Verify that Con-Ed is feeding the buildings, what is the voltage drop 280'. 2) Service entrance conductors undersized. . 3) Provide grounding scheme. 4) Free air ratings of conductors can't be used when installed in conduit.. 5) Provide updated coordination study.						

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50656CO	11A0149CO	Capitol Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Time Warner 409 East 60th Street New York NY	Approved	\$0.00
Carry over from May 25, 2011 meeting.						
50686CO	11A0179CO	Striano Electric Co., Inc. 246 Park Avenue Garden City Park NY 11040	Requested approval for the electric service equipment proposed to be installed	NYIT 26 West 61st Street New York NY	Approved	\$0.00
Carry over from May 25, 2011 meeting.						
50688CO	11A0181CO	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hines 140 Broadway New York NY	Approved	\$0.00
Carry over from May 25, 2011 meeting.						
50693CO	11A0186CO	Shorr Electrical Contracting, Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's Herald Square 151 West 34th Street New York NY	Approved	\$0.00
Carry over from May 25, 2011 meeting. 1) Existing service bus to be built and sized to new code back to vaults. 2) Will transformer on load side of existing 2000A SS be reused? If yes, show location and connection. 3/17/2017 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
50702CO	11A0195CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital 620 West 168th Street New York NY	Approved	\$0.00
Carry over from May 25, 2011 meeting.						

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50712CO	11A0205CO	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	NYU Catholic Center 58 Washington Square South New York NY	Approved	\$0.00
Carry over from May 25, 2011 meeting. Length of tap to Jockey pump not provided. Job finalized 11/29/11.						
50731	11A0214	Horsepower Electric 4109 Fort Hamilton Parway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	124-126 West 23rd Street New York NY	Approved	\$650.00
11/22/13 Dwgs swapped.Rev 3 for Dwg A and Rev 4 for Dwg B.						
50732	11A0215	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Panera Bread 330 7th Avenue New York NY	Approved	\$650.00
50733	11A0216	GMA Electrical Corp. 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 215 West 17th Street New York NY	Approved	\$650.00
1) Show line side tap for fire pump. 2) Verify that fire rated RHH is being installed. Job finalized 6/30/11.						
50734	11A0217	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NBC Studios 30 Rockefeller Plaza New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50735	11A0218	Walsh Electrical Contracting Inc. 76 Midland Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	692 Broadway New York NY	Approved	\$650.00
50736	11A0219	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	535 West 19th Street New York NY	Approved	\$650.00
50737	11A0220	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	200 West 72nd Street New York NY	Approved	\$650.00
50738	11A0221	AMC Electric Services, Inc. 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	640 Broadway New York NY	Approved	\$650.00
50739	11A0222	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S./I.S. 312Q 46-08 5th Street Long Island City NY	Approved	\$650.00
Emergency circuit to fire pump to be fused at 150%. Job finalized 6/29/11.						

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50740	11A0223	Glo Electric LLC 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Navy Green-Building R1 130 Flushing Avenue Brooklyn NY	Approved	\$650.00
<p>1) Substation-Apt-47-Vertical bus undersized. 2) Substation-Aprt-47-neutral link not provided. 3) Apt-19 provide neutral disconnect link. 4) Apt-73-through bus undersized. 5) Apt 73-provide neutral link. 6) Provide supplemental ground,. 7) Confirm transformer primary switches are rate for transformer inrush. 8) Confirm all loads served by emergency gen are 30 3W. If so, gen neut(XO) must be grounded. 9) Confirm Con Ed acceptance of micro turbine system. Show details. 10) DP-4A-73 correct fuse type.</p>						
50741	11A0224	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Carnegie 57 157 West 57th Street New York NY	Hold	\$650.00
<p>1) New work to be bubbled on 1-Line. 2) Service entrance conductors not shown on drawing. 3) Fuse types not shown. 4) Length of taps not provided. Job finalized 10/4/11. 8/28/13 drawings swapped(Rev 2)</p>						
50742	11A0225	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	200 11th Avenue New York NY	Approved	\$650.00
<p>1) New equipment grounding conductors undersized. 2) Remove existing EGC or request permission to leave as installed. 3) Provide bus sizes in SCC-A,; B, UPS-ODP-A1; A2, B1;B2. Section views. 4) Working clearance behind SCC-B should be 42"(480V). 12/14/11 1) Special permission 51031 approved for Item #3 above. 2) Item #4 not addressed. Job finalized 4/20/12.</p>						
50743	11A0226	Hatzel & Buehler, Inc. 45 Broadway, Suite 1240 New York NY 10006	Requested approval for the electric service equipment proposed to be installed	Credit Suisse 11 Madison Avenue New York NY	Approved	\$650.00
<p>1) Switchgear #1 through bus undersized. 2) Verify 2 sets of 500 MCM to ATS-EL-CD. 3) Swbd room doors to swing out. 4) Cables from gen should be treated like service conductors run "outside building." 5) show room layout for EMDP. 6) Review 1st and 2nd level coordination on switchgear.</p>						
50744	11A0227	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	851 Grand Concourse Bronx NY	Hold	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50745	11A0228	Redline Electric Inc. 1715 East 9th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	509 West 34th Street New York NY	Approved	\$650.00
1) Existing service entrance conductors are spliced, was this an existing condition. 2) Verify 2nd fusing of fire pump. Job finalized 7/20/11.						
50746	11A0229	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	165 West 91st Street New York NY	Hold	\$650.00
1) 5' clearance required in front of service switches. 2) Show clearances in front of disconnect switches. 3) Feeders are overfused. 4) Are conductors copper or AL? 5) Conduit sizes not shown. 6) Room layout does not comply with 110.26(c)(2).						
50747	11A0230	Allstate Electric Corp. 555 Eighth Avenue, Suite 809 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	104 West 40th Street New York NY	Approved	\$650.00
50748	11A0231	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Capital Properties 115 Broadway New York NY	Approved	\$650.00
50749	11A0232	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Barclays Center Arena 620 Atlantic Avenue Brooklyn NY	Hold	\$650.00
1) Disconnect switches bonded. 2) EGC undersized. 3) Transformer secondary conductors undersized load side of 400A disconnect switch. 5) Length of taps not shown. 6) #12 fused at 25 amps. 7) Too many switches installed on FA system. 8) Where are life safety switches located?						

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50750	11A0233	Rightway Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	475 Driggs Avenue Brooklyn NY	Approved	\$650.00
50751	11A0234	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	MTI Residential Services 403 Howard Avenue Brooklyn NY	Approved	\$650.00
50752	11A0235	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	88 Central Park West New York NY	Approved	\$650.00
50753	11A0236	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	I.S. 285X 200 West 167th Street Bronx NY	Approved	\$650.00
Show generated overcurrent disconnecting means. 9/13/11 job finalized.						
50754	11A0237	Naber Electric Corp. 3471 Steenwick Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Fordham Place 400 East Fordham Road Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50755	11A0238	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Pave Academy Charter School 732 Henry Street Brooklyn NY	Approved	\$650.00
50756	11A0239	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	53-65 Hope Street Brooklyn NY	Approved	\$650.00
Verify 3/0 conductors to fire pump. Job finalized 6/29/11.						
50757	11A0240	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	Camasie Plaza Avenue D and East 89th St. Brooklyn NY	Approved	\$650.00
1) Verify conductors on load side of transformer. 2) 500 MCM fused at 500 amps. 3) Tapped conductor undersized. 4) Conduits to 600A disc sw mismarked. Job finalized 7/12/11.						
50758	11A0241	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Maspeth Campus IS/HS 585Q 54-70 74th Street Maspeth NY	Approved	\$650.00
1) Service lateral shall supply only one set of service entrance conductors. 2) More than 6 service switches fed from one property line box. Job finalized 6/29/11.						
50759	11A0242	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Promise Academy 245 West 129th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50760	11A0243	LFG Landmark Facilities Group, Inc. 252 East Avenue Norwalk CT 06855	Requested approval for the electric service equipment proposed to be installed	60 West 78th Street New York NY	Approved	\$650.00
50761	11A0244	N.J.D. Wiring & Electric, Inc. 213-08 99th Avenue Queens NY 11429	Requested approval for the electric service equipment proposed to be installed	IS 61 445 Castleton Avenue Staten Island NY	Ok, but	\$650.00
1) Drawing to be darker. 2) Provide length of tapped conductor.						
50762		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requesting permission to install liquidtight flexible nonmetallic conduit and nonmetallic rigid conduit for cooling tower cells and control wiring in a wet semi outdoor area where existing corroded raceways and boxes must be replaced	Time Life 1271 6th Avenue New York NY	Approved	\$0.00
50763		B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requesting permission to leave as installed due to financial hardship to remove or rewire under counter kitchen fixtures connected to small appliance circuits on a job designed under the old NYC Electrical Code	160 Schermerhorn Street Brooklyn NY	Approved	\$350.00
50764		Einstein Electrical Corporation 42-16 28th Avenue Astoria NY 11101	Requesting permission to tap the load side of a 2000 amp fused service switch with 3/0 conductors that are approximately 15'-18' long	1160 Park Avenue New York NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50765		ACP Electrical Contracting, Inc. 412 West 48th Street New York NY 10036	Requesting permission due to lack of space inside of the existing electrical closets, to replace existing circuit breaker panels with 72 and 84 pole 3 phase 400 amp panels.	35-15 Parsons Blvd. Flushing NY	Approved	\$0.00
50766		Shorr Electrical Contracting, Inc. 34-13 10th Street Long Island City NY 11106	Requesting permission to replace a defective 2500 amp 480 volt switch with a new non ground fault type switch	Macy's Herald Square 151 West 34th Street New York NY	Denied	\$0.00
50767		Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requesting permission to leave as installed in 35 new homes which will be a financial hardship to replace service entrance cable not installed enclosed in a threaded metallic raceway	Arverne By The Sea Far Rockaway NY	Approved	\$0.00
With the stipulation that steel plating is installed on both sides of the wall enclosing the entire run of the service entrance cable.						
50768		Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requesting permission to install underground concrete encased service entrance conductors in rigid nonmetallic conduit	Jetro Distribution Center One Hundred Oak Point Avenue Bronx NY	Approved	\$0.00
50769		R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requesting permission to leave as installed kitchen counter top receptacle outlets installed 30" above the countertop due to installing a mirrored backsplash.	145 Hudson Street, Apt. 14B New York NY	Denied	\$350.00

ADVISORY BOARD CALENDAR

June 15, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50770		Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requesting permission to leave as installed 480 volt equipment in Table 110.26(A)(1) condition 3 with a front clearance of 43 1/2" in a new building	NYDEP Newtown Creek WPCP 329 Greenpoint Avenue Brooklyn NY	Approved	\$0.00
With the stipulation that the concrete pad the equipment is installed on does not extend past the front of the equipment covers.						
50771	11A0245	AECOM 20 Exchange Place, 10th Floor New York NY 10005	Requested Concept Approval for :	Rikers Island Cogeneration Queens NY	Approved	\$650.00
Concept approval only.						