

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	15A0017CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>1.Service entrance conductors undersized 2.Fire pump service switches undersized, fusing undersized 3.250 KCM under fused at 1200 amps 4.Verify that the neutral conductor is being switched in FA ATS 5.Designer to appear at meeting to explain the installation with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p>				
54079	15A0455CO2	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from August 12, 2015 meeting to July 13, 2016 Meeting. CUP building, 225.37, 230.2(E)</p> <p>1.Provide Signage in the electrical room indicating which disconnect switches are supplied by the</p> <p>2.Provide unfused disconnect switches for the Fire Alarm systems. Show compliance with 225.36 & 225.31</p> <p>3.Provide signage at Fire pump controller switch indicating where the supply comes from in the Fire pump room and Electrical room</p> <p>4.Verify size of Fire Alarm transformer</p> <p>5.Where is the generator located</p> <p>6.Provide 60 amp 1 and fuse for Fire alarm system with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/28/17 Swapped drawing. Dwg 1 of 2, Revision 3. 10/3/17 - swap dwg 1/2 rev 4, dwg 2/2 rev 3</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
55091	16A0135	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Does switchboard comply with 408.60(F)? 2) Verify incoming SED of Con-ED conductors. 3) SS #3 and 1200 amp KRPC don't coordinate. 4) SS #3 backwards, bond and ground on load side of neutral link. 5) Fire pump feeders not fire rated. 11/2/16 1) Verify 21 incoming sets of Con-ED conductors. 2) Fuses of ss#3 and 1200 amp KRPC don't coordinate. 12/18/17 - 1) Comply sec 240.21 to tap conductor. Conductor between SS # 3 & "Retail cable trough" undersize. 2) Show tap length from "Retail cable trough" to individual" Disc. SW" Tap conductor for "100A" spare is undersize. 3) Comply sec 250.66 for service grounding conductor size. FP SW # 1 & FP SW # 2 ground conductor undersize. 4) Comply sec 695.4(B)(1) for FP # 2 OCPD 5) Verify Electric service room has panic hardware in Egress door. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/23/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/27/18 Swap dwg -Revision 7. 3/2/20 1) Confirm compliance with 408.60(A)-N.D.L to be downstream of main bonding & grounding. Dwg A011606. 2) Confirm compliance with 760.41(A)-F.A. tap to be ahead of N.D.L. - A011606. 3) Vertical busbar in "DP-42-1" section #2 is undersized-Dwg A011606. 11/5/2020 Amended Plan# A0110606 Rev-10. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54237	16A0272	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Neutral to be bonded to enclosures in Time Warner, fire alarm and fire pump service switches 250.64(D)(3). 2) Neutral conductors to remote service switches should be connected to the line side of the neutral link. 3) Equipment grounding conductors undersized on 4000 amp feeders with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/29/16 Item #3 not addressed. 12/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/23/18 - swap dwgs 1 of 2 Rev 2, 2 of 2 Rev 1</p>				
54006	16A0280CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from May 4, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.5/9/2017 - ok-swap dwgs 1&2 rev 2 7/21/17 - swap dwg 1 & 2 rev 3</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54012	16A0309	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. This drawing is approved</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/24/19 - Swap dwg 1 and 2-Revision 1.</p>				
	16A0353	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1. Verify types of ATS that will be installed by note at generator, Dwg 3 2.3 poke ATA for Fire Alarm on separately derived systems, Dwg 3 3. Dwg 2 – provide neutral links for 2500, 2000, 1200 amp service switches 4. Dwg 2 – T1 – 2 transformer secondary switch to be grounded fault type 5. Dwg 2 – transformer secondary's neutral to be bonded and grounded 6. Provide coordination study – signed, sealed by a P.E. 7. Barrier off rear of switch board MSB-C-13 8. Verify that 800 amp ATS and emergency feeder is not for life safety 9. Verify that service room is mechanically ventilated.</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54055	16A0363	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Fire pump service entrance conductors to have a grounded conductor. 2) Fire pump service entrance conductors undersized. 3) Fire pump service switch undersized. 4) Service is not 1000 KVA. 8/23/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/25/17 - 1) Service entrance conductor for FA service switch undersize. 2) FP service entrance conductor from SEB to pull box undersize. 3) Show conductor size between pull box & FP service switch. 8/4/17 - swap dwg 1 of 3 rev 3 9/28/17 - swap dwg 1 rev 4.& 2 rev 1 of 3 2/2/18 - Swap Dwg # 1 of 3 Rev 5 No More Swaps				
53985	16A0400	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54238	16A0405	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Service entrance conductors undersized. 2) Show bus size of 3000 amp ss. 11/30/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53984	16A0416	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0426	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1. Service room where the new 400 amp circuit breakers will be installed, door to open outwards with panic hardware 2. Show Fire pump emergency conductors to generator 3. Tapped conductors to new 400 amp disconnects undersized, equipment grounding conductors undersized. 4. Emergency feeder sizes to ATS not shown 5. Are ATS 3 or 4 pole type? 6. Length of Taps not shown 7. Are new panels feeding life safety loads				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54001	16A0430	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0440	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/3/17 1) Verify if existing 2000A ss#3 has ground-fault protection-Sec 230.95.				
54022	16A0448	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/3/17 Swapped drawing revision 1. 2/5/19 1) Provide coordination study signed and sealed by P.E. 8/23/19 Swap Dwg #A.3 Rev.3 and Dwg #B.3 Rev.3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/8/19 Swap Dwg # AB-16129-A.3 Rev 4 and AB-16129-B.3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
54014	16A0451	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/22/17 - swap dwg 1 of 2 rev 1, dwg 2 of 2 rev 1				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54005	16A0468CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from June 8, 2016 meeting. With the stipulation that the cogen system is listed and this drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 6/7/19 - 1. Verify rear access to 600A sw 4160V in swbd "E" - how rear door will open? Or verify that all connection are accessible from location other than the back. 2. Show connection from service switches to collector ground bar in one line dwg. 7/6/2020 Amended Dwgs# 1-7, 8A, 8B Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				
53996	16A0474	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
56058	16A0479	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Verify 3000 amps Emergency Panel off of 500KW generator 2. Correct typo on Fire pump emergency feeder, or check wire fill for 2" conduit 3. Provide short circuit, coordinator study performed, sealed and stamped by a P.E. 4. Verify that switch board MSB-1 complies with 408360(F) 7/22/2019 1) Provide minimum clearance between sw #2 and #3 enclosure and surrounding equipments per 230.64 2) Provide coordination between 'KLU 4000 A' fuse and downstream 'HHJXD6' fuses. 3) Provide master electrician or P.E. license name and number. 8/13/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/4/19 Swap Dwg # AB-16127-B.2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
53987	16A0486	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/19/2020 Amended Plan # E-101 Rev-1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0487	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1.400 Amp service switch neutral not bonded & grounded 2.Emergency F.A. & F.P. switches neutrals are bonded & grounded 3.Verify MI Cable installed in conduit and MI terminating directly to devices 4.Verify 2 sets of MI cable on lead side of ATS to splice box 5.Show how splices will be made in Fire Pump splice box 6.Equipment grounding conductors undersized to fire pump 7.Each fire pump to have its own ATS 8.3000 Amp service switch, show bonding jumper size and ground lugs, supplemental ground lugs 9.4000 Amp service switch neutral not bonded and grounded Review stopped... with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
53992	16A0488	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53989	16A0489	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/5/16 Swapped drawing B-Revision 1. 2/8/17 Swapped drawing "D-1606-27268-B"-Rev 2.				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0491	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1.TD-ED-DS-37-1 (3) section bus 2nd cubicle and 1600 amp switch bus under sized 2.TD-ED-DS-11-2 (re/co) bus on line and load side of 3000 amp switch undersized 3.TD-DS FP-11-1 (13) remove spare service switch in fire pump board 4.Generator neutral to be bonded and grounded in one location 250.30(A)(1) 5.Show size and fuse size of fire alarm emergency switch 6.Bond and ground transformer secondary of fire alarm transformer</p>				
54025	16A0493	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book Requirements. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/6/19 Swapped Drawing. A-Revision 3 and Dwg B-Revision 2</p>				
53997	16A0494	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/30/16 Swapped drawing A4-Revision 1.</p>				
53995	16A0495	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53988	16A0496	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53993	16A0497	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54085	16A0498	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Tapped conductor undersized length of tap not shown to panel "DPCA1. 2) Provide neutral link in SS #5. 3) Verify location of existing neutral disconnect link in switchboard. 9/1/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 4/28/2017 - 1) show grounding for fire alarm system sw, ssw# 5, ssw# 6. 2) show neutral connection in ssw# 5 3) add supp ground in exist service SWBD EXMDB. 7/28/17 Swapped drawing A, Revision 3.				
54288	16A0500	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Emergency feeders for fire alarm and fire pump reversed. 2) Provide coordination study signed, sealed and stamped by a PE, 2000 amp KLU and 600A FRN don't coordinate with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 12/20/16 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.. 2/25/2020 Swap dwg #A-Revision 2 and dwg B-Revision 2.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0502	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>Dwg 2</p> <p>1.Add note to 1 Line drawings indicating compliance with sections 225.34(A) & 225.37</p> <p>2.Where are the locations of the unfused Fire Pump disconnect switch</p> <p>3.Transformer secondarys' over fused</p> <p>4.TDS-A-1 and TDS-A-2 bus undersized</p> <p>5.Fire Alarm equipment grounding conductors undersized</p> <p>6.1600 Amp Equipment grounding conductors undersized</p> <p>7.EGC to emergency fire alarm switch undersized; how do 2/0 conductors connect to 60 amp switch terminals?</p> <p>8.Remove FA disc switch on load side of ATS</p> <p>9.EGC on load side of FA transformer undersized</p> <p>DWG 3</p> <p>10.Fire pump service switch undersized; FP B1-1</p> <p>Review stopped... with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
	16A0505	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Show clearances in service room, show elevation drawing. 2) Service D all section bus undersized. 3) Provide coordination study signed, sealed performed by a P.E. 4) Transformer feeds more than 6 switches that are not grounded together, transformer shall be Y-Delta.</p>				
54011	16A0506	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0507	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
1) Verify amount of conductors in troughs, not derated. 2) Is entire job new, or bubble new work on all drawings. 8/25/16 This submittal number is void in lieu of new submission number of 16A0646.				
53978	16A0508	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53925	16A0509	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54031	16A0510	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1.Fire pump - remove transformer secondary switch 2.Will MI cables terminate directly to ATS 3.Verify emergency Fire alarm system two switches installed prior to transformer 4.Fire Alarm switch reversed</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
53986	16A0511	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54000	16A0512	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53998	16A0513	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53990	16A0514	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/2/19 Swap Dwg A rev 1.				
	16A0515	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
53962	16A0519	Requesting permission due to the existing space liminations and concrete encased steel beams located in the floors in front of the elevator shaft way to allow a new elevator feeder to be installed inside of the existing elevator shaftway as per section 620.37(C) & 620.37(C)(2)	Approved	\$0.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53963	16A0521	Requesting permission to utilize Section 690.7(c) of the NEC and allow 1000 volt solar photovoltaic equipment to be installed, solar edge three phase inverters, solar bos source circuit combiners and solar edge power optimizer module.	Approved	\$0.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54923	16A0522	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Clearance to comply with Table 110.34(A) conductor #2. 2) Fusing for transformers undersized. 3) Address coordination study by others-Table 3. 3/22/2017- Designer to appear at meeting to explain installation 8/14/17 - 1) Manholes covers to be grounded 2) Confirm if secondary over current protection is required for cond on secondary of substation transformers. 11/29/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	16A0523	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1.Show Clearances in service rooms 2.Who will be replacing copper ¼" x6" bus bars 3.Portable generator connection box to comply with 700.6(G), where is switch located, provide back feed signage 4.Conductor in Trough to be derated; what type of cover will be used? 5.Bus sizes not shown on S.S 4B 6.Provide Key interlock for generator 7.Provide conductor calculations for wire way fill to supply service switches.</p>				
54007	16A0524	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con Edison regarding Blue Book requirements. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
54058	16A0526	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Verify 5' front clearance in front of fire pump service switch. 2) Show clearances in front of store panels, store distribution board #2 and Con-ED store meter. 8/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/9/2017 - 1) F.P. S.Sw is under fused. 2) Update system grounding, add supplemental ground. 10/5/17 - swap dwg with rev 3</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54081	16A0527	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Bus in DP-C undersized and doesn't match physical. 8/30/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/30/17 - swap dwgs 2 & 3 rev 2				
54302	16A0528	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Tapped conductor to 400 amp disconnect switch undersized. 2) New house panel not shown and size of breakers not shown. 3) Verify length of tap to 200 amp disconnect switch. 4) Verify existing house C.T. and house panel and elevator disconnect behind it show clearance. 1/5/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54010	16A0529	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53980	16A0530	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53965	16A0531	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54131	16A0532	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1.Where is the Fire pump disconnect switch located, will MI cable terminate in ATS 2.Where is Generator and emergency equipment located 3.Fire Pump emergency feeder underfused 4.Fire Alarm 200 amp disconnect switch bonded and grounded after service switch 5.Fire Pump disconnect switch to comply with 225.30 if switch is located in fire pump room, remove it and use controller 6.Fuse types in existing building not shown on drawing. 10/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/20/17 1) Remove 2nd FA OCPD (fuse) from FA disconnect switch. 2) Relocate FA pull box in accessible area to get access. 12/14/17 - swap dwg with Rev 3 3/27/18 - swap dwg 1 Rev 4, dwg 2 Rev 3, Dwg 3 Rev 1</p>				
53999	16A0533	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/2/18 Drawing swapped with Revision 1.</p>				
53964	16A0535	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54667	16A0536	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Normal and emergency equipment in the service room. 2) Show how non 1000 KVA genset ties into service. 3) Emergency loads mixed with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/18/2017 - 1) Emergency 100HP F.P. OCPD is undersized. 2) Verify that you comply code section 695.6(B)(1) 3) Show which is existing & new for one line & room layout. 8/3/17 - job finalized -Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
55216	16A0538	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Transformer secondary neutral not bonded and grounded 2. Complete reduced neutral calculations not provided 3. Equipment grounding conductor for fire pump undersized 4.1 line drawings & fonts to be bigger in the future. 4/14/17 Provide coordination study signed and sealed by P.E. 6/27/17 - 1) Coordination study does not match with one line, provide correct coordination study. 3/7/18 - 1) item # 1 from revision 6/27 is not addressed verify generators in coordination study & not shown in one-line 2) Include coordination of all S.SW & downstream breaker up to 2nd level within the study 3/26/18 - 1) Remove bonding and grounding from F.A. SW - Emergency side 2) Verify 3 pole F.A. - ATS 3) Item # 2 of March 7th revision not addressed . 4/4/18 - 1) Item # 3 is partially addressed 4/12/18-Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/27/18 1) Comply with 696.5(A)(2). 2) Fire pumps FP2, 3 and 4 OCPD is undersized and verify if painted red.. 4/7/2020 Dwg Amended Dwg 1 of 3-Rev 7 and Dwg 2-Rev 6 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/18/2020 Swap drawings # AB 1 of 3 Rev # 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
53976	16A0539	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR With the stipulation that the fuel cells are listed equipment. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54004	16A0540	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53991	16A0542	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/24/16 Swapped drawing A-Revision 1. 11/22/16 Received letter to change job location address from 528 to 525 West 28th Street. 11/29/16 Swapped drawing A-Revision 2 No more revisions.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0543	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not Reviewed - OK for 08/17/16 meeting				
	16A0544	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Not reviewed. OK for 08/17/2016 meeting				
53970	16A0545	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/24/17 - 1) Tap cond is undersized - the provisions of 240.4(B) shall not be permitted for Tap conductors [240.21(B)] 8/4/17 - Item # 1 is partially addressed - provision of 240.4(B) shall not be permitted for tap cond. Sec 240.21(B) 10/19/17 - swap dwg # ACS-D-8789-33 Rev 2, ACS-D-8789-4 Rev 2 12/28/17 - Swap dwgs 3 & 4 Rev 3. 8/17/18 Swap dwg #3 and 4-Revision 4.</p>				
	16A0546	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
<p>1.Firm Pump supply to comply with 695.3(A)(1) & 408.3(A)(3) 2.Show fault current at Fire Pump and withstand ratings of ATS & Controller. 10/27/16 Void as per Sub. #16A0787, Approval #54179. 10/19/16.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0547	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Dwg 603 switchboard and notes backward on drawing. 2) Dwg 603 lengths of taps not shown and 400 amp tap conductor undersized. 3) All drawings-who will be installing incoming conductors distribution switchboards labeled as service switchboards, neutrals not to be bonded and grounded. 4) Drawings 603-switchboard to comply with 408.60(F) or 230.64(B)(4) and Table 110.34 clearances. 5) Drawing 602-length of taps not shown. 6) Drawing 605-tap conductors undersized and length not shown and overfused. 7) Drawing-605 doors to open outwards, 8) Drawing 605 section bus undersized middle section. 9) Drawing 604 4 pole ATS' used on non separately derived system. 10) Drawing 604 length of taps not shown. 11) Drawing 602 show elevations of ceiling boxes. Review Stopped. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
54084	16A0549	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service room doors to comply with 230.64(B)(5). 2) Size of switchboard switches not show on 1 Line or physical for MSB. 3) Type of fuse not shown, coordination study performed signed and sealed by a P.E. not submitted. 4) Tapped conductors to 800 amp disconnect switch undersized. 9/1/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
54002	16A0550	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/20/2017 - swap dwg 1 rev 1</p>				
54003	16A0551	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/26/16 Rejected Fire alarm to be connected on line of source equipment. 12/2/16 Swapped drawing A2</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54080	16A0552	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Service bus to 4000 amp service switch undersized, typo on line and load of switch. 2) Generator feeders overfused. 8/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 8/1/18 - swap dwg # A.2				
53966	16A0553	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/24/16 Swapped drawing 1-Revision 1. 2/2/17 Swapped drawings 1-Revision 2.				
53967	16A0554	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54013	16A0555	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/8/2019 Swap Dwg #A Rev-3 and B,C & D Rev-5 7/10/19 1) Conductor feed "DP-7" & "DP-10" are undersized. 2) Provide coordination between 1200A (SS#3) and downstream 600A MCB in "DP-13" 12/11/19 Swap Dwg # D -1603-28032-A Rev 4, -C Rev 8, -D Rev 9. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/19/2020 Amended Plan # C Rev-9, # B Rev- 6, # A Rev-5, and # D Rev-10. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54281	16A0556	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Size of main bonding jumpers not shown, Swbd 1 and 2. 2) Service bus feeding 3000, 800, and 2-400 amp service switches undersized swbd 2. 3) Feeder to load bank overfused. 4) Fire pump emergency feeder underfused, and not fire rated with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/16/16 Rejected 1) Comments above not addressed and also below. 2) Service switchboard #2 to comply with 230.64(B)(4). 3) Provide coordination study performed, signed and sealed by a P.E. 4) Provide a note under emergency panel or generator whether 3 or 4 ATS' will be installed with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 12/16/16 Job finalized. The drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/23/18 1) Verify that F.P. controller AIC rating is equal to or more than available s.c. current. 8/22/18 - swap dwgs A Rev 4; B Rev 2; C Rev 3; D Rev 5</p>				
53968	16A0557	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/13/17 Swapped drawing.-Revision 1 Job addressed changed.</p>				
53969	16A0558	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/26/18 Swap dwg #1 and 2-Revision 2.</p>				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54057	16A0559	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/23/16 Job finalized with the stipulation that SRP-6MA solar panels, 1000 volt sunny tripower inverters, Solar Bos string inverters be installed. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53971	16A0560	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53972	16A0561	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53973	16A0562	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/22/16 Swapped Drawing D-Revision 1				
53974	16A0563	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53975	16A0564	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/22/16 Swapped drawing D-Revision 1				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54008	16A0565	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/23/19 Swap 1-Revision 2 and dwg 2-Revision 2 7/19/2019 Swap #12393-1 Rev 3 and Dwg #12393-2 Rev 3.				
53977	16A0566	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53981	16A0567	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54060	16A0568	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Service room doors to open outwards. 8/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54009	16A0570	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/27/2017 - swapped dwgs 1 & 2 revision 1's 3/23/18 - swap dwg with Rev 2				
53982	16A0571	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53983	16A0572	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/12/17 Swapped drawing #ACS-D-12312-Revision 1. 4/17/2017 - 1) Comply section 230.42 (A) (2) for SS# 5. Service entrance conductor undersized for ss# 5 74/27/2017 - swap dwg# ACS-D-12312 rev - 2				
	16A0573	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
<p>1) Fire pump emergency feeder not fire rated. 2) Add note under D-P Gen panel whether 3 or 4 pole ATS' will be installed. 3) Coordination study signed, sealed and stamped by a PE not submitted with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <p>1. A P.E. or R.A. must file a PW1 as an AIT 3.</p> <p>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 9/9/16 This submittal is void in lieu of new submittal #16A0662.</p>				
53979	16A0575	Requesting permission to install an elevator feeder in the elevator shaftway as per 620.37(c) in a building where the elevator is being upgraded and due to many obstacles in the way of conduits and subject to vandalism to allow the feeder for the elevator to be installed in the shaftway	Approved	\$0.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0576	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/7/2018 Provide coordination between 2000A A4BY and 1200A A4BY signed and sealed by P.E. 10/31/18 1) Provide coordination between new 1800A A4BQ LCL and 400A TR signed and sealed by P.E.				

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54024	16A0577	Requesting permission to utilize Section 220.43(B) Exception of the 2011 NEC to install track lighting.	Approved	\$0.00
With the stipulation that the current limiting panel is listed as a complete assembly. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				