

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49426CO	09A0185CO	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Randall's Island Field Devel. Randall's Island Park Randall's Island NY	Hold	\$0.00
Carry over from April 16, 2009 meeting. 1) Show fire rated doors. 2) Provide coordination study. 3) Show grounding scheme for incoming 15K and 5K switchgear.						
49690CO2	09A0382CO2	Sajun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Coney Island Hospital Brooklyn NY	Approved	\$0.00
Carry over from January 13, 2010 meeting. 1) Fire pump branch circuit to be fire rated. 2) FA tap not shown. Job finalized 10/20/10.						
50014CO2	10A0098CO2	Sajun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Lincoln Medical Center 234 East 149th Street Bronx NY	Approved	\$0.00
Carry over from April 14, 2010 meeting. Special permission required for non-coordination.						
50063CO	10A0133CO	Gartech Electrical Contracting Corporation 100 Hindsdale Street Brooklyn NY 11207	Requested approval for the electric service equipment proposed to be installed	228-06 Northern Blvd. Little Neck NY	Ok, but	\$0.00
Carry over from April 14, 2010 meeting. Section 700.6G requires a disconnect switch located outdoors.						
50098CO2	10A0160CO2	Fas Electrical Contractors Inc. 78-10 67th Drive Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	VBC Industries 156 Standford Street Brooklyn NY	Approved	\$0.00
Carry over from June 16, 2010 meeting.						

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50111CO2	10A0173CO2	Verde Electric Corp. 1402 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Public Safety Answering Ctr. 1200 Waters Place Bronx NY	Approved	\$0.00
Carry over from June 16, 2010 meeting.						
50171CO	10A0219CO	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Kings Plaza Mall Flatbush Avenue & Avenue U Brooklyn NY	Approved	\$0.00
Carry over from 6/16/10 meeting.						
50184CO	10A0232CO	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Lincoln Center Theatre 3 150 West 65th Street New York NY	Hold	\$0.00
Carry over from June 16, 2010 meeting. Detail what work is new and what is existing on the 1-Line drawing.						
50187CO		Samson Electric Corp. 3300 Northern Blvd, Bsmt Level Long Island City NY 11101	Requesting permission to install schedule 80 nonmetallic conduit for branch circuit wiring in a jewelry manufacturing room where acids and other corrosive chemicals are present	31-00 Northern Blvd. Long Island City NY	Denied	\$0.00
50191	10A0233	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	J.H.S. 198Q 365 Beach 56th Street Queens NY	Approval	\$650.00

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50192	10A0234	DNR Electric, Inc. 200-07 Hollis Avenue Hollis NY 11412	Requested approval for the electric service equipment proposed to be installed	604 Clinton Street Brooklyn NY	Ok, but	\$650.00
1) Line side equipment grounding conductor undersized. 2) Indicate interrupting rating of new CB panel.						
50193	10A0235	Ramdeens Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	75 University Place New York NY	Approved	\$650.00
Verify tap connection is new meter 6th service switch or second switch from existing switchboard. Job finalized 9/20/10.						
50194	10A0236	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Times Square Church 226 West 52nd Street New York NY	Hold	\$650.00
1) Neutral disconnect links not shown in service switches. 2) Bonding and grounding not shown on service switches. 3) Length of taps off of service switches not shown. 4) Tap detail off of 1200 amp service switch not shown. 5) #2 tap conductor undersized. 6) Indicate all conductor info for 400A trans. 7) Second fuse 1200A (2) service switches to be coordinated. 8) Name service switches. 9) If existing Telco panel in service room requires: a) Special Permission. b) Build enclosure with door around Telco panel.						
50195	10A0237	A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	Hobbs Court 315 East 102nd Street New York NY	Ok, but	\$650.00
Service switch #1 "TR" 400A fuses. Do not coordinate to 1200A switch-Should be RK!.						
50196	10A0238	C.Q. Electrical Contracting Corp. 10-16 34th Avenue Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	260 East 161st Street Bronx NY	Approved	\$650.00
Show barrier/fence from rear wall to back of service switchboard. Job finalized 9/20/10.						

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50197	10A0239	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	235 W. 56th St. aka 1755 Broadway New York NY	Approved	\$650.00
50198	10A0240	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	200 Chamber Street New York NY	Approved	\$650.00
50199	10A0241	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	116 West 28th Street New York NY	Approved	\$650.00
50200	10A0242	E.D. Electrical Inc. 5402 7th Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	17 Main St. aka 136-20 Roosevelt A Flushing NY	Approved	\$650.00
50201	10A0243	CRM Electric Corporation 461 West 261st Street Bronx NY 10001	Requested approval for the electric service equipment proposed to be installed	Building C 780 St. Anns Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50202	10A0244	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	692 Broadway New York NY	Approved	\$650.00
Provide bus size in panelboard QTY of 1/4 x3". Job finalized 9/20/10.						
50203	10A0245	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	11 Fifth Avenue New York NY	Hold	\$650.00
1) Neutral links not provided in existing 4000 amp service switch and switchboard.(show bonding -grounding). 3) Feeder size and wiring method not shown on load side of 4000 amp service switch. 4) Grounding electrode conductor terminal not shown in 4000 amp service switch. 5) Indicate what is new and existing. 6) Service entrance conductors. 7) Equipment grounding conductors undersized, 8) 750 KVA transformer connections ground neutral 208Y-delta 480. 9) Sequence of operation.						
50204	10A0246	Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	3120 Corlear Avenue Bronx NY	Hold	\$650.00
1) Fire pump service entrance conductors undersized and branch circuit not fire rated. 2) There are more than 6 service switches. 3) Verify through bus installation line and load in same section. 4) Service room to have 2 doors. 5) ADP panel 600A fuse coordination to 1200A fuse. 6) 800A trans 's' fuse coordination to 400A fuse in RDP panel. 7) Panel bars on all doors.						
50205	10A0247	Double K Electric Corp. 247-03 Jamaica Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	521 West 25th Street New York NY	Approved	\$650.00
50206	10A0248	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Building 110 Governors Island NY	Approved	\$650.00
1) Are transformer secondaries physically protected? 2) Service equipment is not grouped. 3) Load side of 400 amp service switches not shown. 4) Fire pump feed tapped in switchboard section that contains a service switch. 5) Grounding not shown in 2500 amp service switch. 6) Distribution panel bus undersized. Job finalized 9/20/10.						

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50207	10A0249	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Lowes of Staten Island 661 Veterans Road Staten Island NY	Hold	\$650.00
1) Verify what work is new and what is existing. 2) Explain future fire pump installation.						
50208	10A0250	Allstate Electric Corp. 481 Eighth Avenue, Suite 920 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	250 West 57th Street New York NY	Approved	\$650.00
50209	10A0251	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	304 East 45th Street New York NY	Approved	\$650.00
50210	10A0252	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Basketball City USA Pier 36 @ South Street New York NY	Hold	\$650.00
1) Transformer secondary to be bonded and grounded not primary side. 2) Show what is feeding the 1200 amp disconnect switch. 3) Verify that service room is mechanically ventilated. 4) Indicate that installation will comply with Article 225.31 and 225.32. 4) Taps supplying service switches do not show that all hot legs and neutrals are being tapped from bus. 5) Provide second means of egress in mezzanial service room. 6) note how new service entrance conductors are routed from one building to the other and are the conduits protected. 7) Is transformer in mezzazine new or existing?						
50211	10A0253	Top Shelf Electric 2842 Richmond Terrace State Island NY 10303	Requested approval for the electric service equipment proposed to be installed	161-21 Jamaica Avenue Jamaica NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50212	10A0254	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested Concept Approval for:	900 Grand Concourse Bronx NY	Ok, but	\$0.00
1) Service entrance undersized. 2) Service room doors to open outwards. 3) Verify that wire ways and service equipment is in a fire rated space.						
50213	10A0255	Tarasis Electric Corp. 36-08 Ninth Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	PS 327K 111 Bristol Street Brooklyn NY	Approved	\$60.00
Service conductors undersized feeding existing 400 amp service switch. Job finalized 7/30/10.						
50214	10A0256	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	1212 Fifth Avenue New York NY	Approved	\$650.00
50215	10A0257	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	121 East 60th Street New York NY	Approved	\$650.00
50216	10A0258	Power Masters Electrical Contracting, Inc. 152 Madison Avenue, Suite 1106 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	400 East 58th Street New York NY	Approved	\$650.00
32 conductors in wireway to be derated. Job finalized 9/20/10.						

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50217	10A0259	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	155 West 68th Street New York NY	Approved	\$650.00
50218	10A0260	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	250 West 93rd Street New York NY	Approved	\$650.00
50219	10A0261	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	37 East 18th Street New York NY	Approved	\$650.00
50220	10A0262	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	130 West 12th Street New York NY	Approved	\$650.00
Fire alarm and fire pump information not complete. Job finalized 11/10/11.						
50221	10A0263	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1221 Sixth Avenue New York NY	Hold	\$650.00
1) Where is new switchboard located and what does it serve.? 2) 2000 amp main to be ground fault protected. 3) Fire pump emergency feeder to be tapped ahead of generator main and be fire rated.						

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50222	10A0264	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	River Place II 600 West 42nd Street New York NY	Hold	\$650.00
1) Does free standing switchboard have tamper/start bolts? 2) MSA-1 south explain pull box. 3) Drawing-2-10' foot tap for 100 amp switch undersized. 4) Reduced neutral calculations needed for residential feeders.						
50223	10A0265	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	RFR Realty, LLC 390 Park Avenue New York NY	Ok, but	\$650.00
1) Verify that rear switchboard covers can't be removed. 2) Service bus in CT undersized. 3) Verify that disconnect switches can handle transformers in rush current.						
50224	10A0266	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Fordham University 655 East Fordham Road Bronx NY	Hold	\$650.00
1) Provide grounding scheme. 2) Equipment contained in vault was submitted without manufacture's cut sheet. 3) Transformer installation instructions not provided showing that transformer can be installed against the wall. 4) Will water enter the vault? 5) Is equipment listed for "wet/submersible" location? 6) Will sump pump/lighting be provided?						
50225	10A0267	Alson Electrical Contractor, Inc. 717 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	2371 Exterior Street Bronx NY	Denied	\$650.00
Not in Advisory Board format. See previously denied submission, Cal. #49959 on 2/10/10 agenda.						
50226		RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requesting permission due to lack of room inside of the existing service room to allow a new service switch for a cell site to be installed on the outside of the building	97-11 North Conduit Avenue Queens NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 14, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50227		WSP Flack + Kurtz 512 Seventh Avenue New York NY 10018	Requesting permission to reutilize existing AC cables that do not contain insulated equipment grounding conductors that feed existing production lighting where the old dimmer racks will be replaced and relocated.	Apollo Theater 235 West 125th Street New York NY	Approved	\$0.00
50228		Grey Goose Electric Co. 32 East 31st Street-8th Floor New York NY 10016	Requesting permission to leave as installed on 3 new 2 family buildings without any common areas service equipment that is not grouped together	738, 3748 and 3752 Neptune Avenue Brooklyn NY	Approved	\$350.00
50229		Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requesting permission to replace a defective section of 4000 amp busway like and kind that is powered by an existing 3000 amp service switch without filing Advisory Board drawings.	Sotheby's 1334 York Avenue, 7th Floor New York NY	Approved	\$0.00
50230	10A0268	USI of North America, Inc. 565 Commerce Street Franklin Lakes NJ 07417	Requested approval for use in New York City of your Paint Mixing Room.		Approved	\$200.00
50231	10A0269	Teknion, LLC 350 Fellowship Rd. Suite 100 Mount Laurel NY 08054	Requested approval for use in New York City of your Teknion Leverage Furniture System.		Hold	\$200.00
1) Need UL report for power pole ECPQ. 2) TU universal light is magnetically mounted. 3) Need UL report for TYQ utility light.						