

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49107CO	08A0562CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Red Hook Water Pollution Plant 63 Flushing Avenue Brooklyn NY	Hold	\$0.00
Carry over from November 12, 2008 meeting. 1) Provide sequence of operation of inter-locking scheme. 2) Provide overcurrent protective device study.						
49317CO	09A0104CO	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Museum of Moving Image 36-01 35th Avenue Astoria NY	Approved	\$0.00
Carry over from March 18, 2009 meeting. 1) Show 700A breaker DP-Mech-C on coordination curve. 2) Confirm feeder size on secondary of transformer(8 sets?). Job finalized 11/9/09.						
49407CO	09A0166CO	alvatore Campisi & Sons Electl Contrs, Inc 453 Onderdonk Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	11 West 19th Street New York NY	Approved	\$0.00
Carry over from April 15, 2009 meeting. 1) Install 3000 amp fuses in existing service switch and install signage on switch indicating 3000 amps maximum. 2) Verify that height of concrete encased bus ties do not interfere with egress and add door in room where replacement board will be installed in. Job finalized 8/4/09.						
49446CO2	09A0190CO2	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	N.Y.U. Co. Gen Expansion 35 West 4th Street New York NY	Approved	\$0.00
Carry over June 17, 2009 meeting.						
49449CO	09A0193CO	Belmont Electrical Inc. 244 Fifth Avenue, Suite 2352 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1150 Park Avenue New York NY	Hold	\$0.00
Carry over from May 20, 2009 meeting. 1) Service entrance conductors are undersized. . 2) Gas meters installed next to 1000KVA service. 3) Explain FB-1 - FB-6. 4) Is this a replacement service? 5) No coordination study between new SS#1 and exiting MDP.						

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49451CO	09A0195CO	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Columbia University 3030 Broadway New York NY	Ok, but	\$0.00
Carry over from May 20, 2009 meeting. Fire alarm shall have an independent emergency feed from generator.						
49495CO	09A0239CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 550 West 120th Street New York NY	Ok, but	\$0.00
Carry over from the May 20, 2009 meeting. 1) Drip pans shall be installed under the A/C ducts. 2) Tap conductor to F.P. switch to be rated at 600 amps..						
49510CO	09A0242CO	J.J. Rosenberg Electrical Contrs, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	R-LIC Realty, LLC 12-16 43rd Avenue Long Island City NY	Approved	\$0.00
Carry over June 17, 2009 meeting.						
49528CO	09A0260CO	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	H & M 435 7th Avenue New York NY	Approved	\$0.00
Carry over from June 17, 2009 meeting.						
49532CO	09A0264CO	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	1844 Second Avenue New York NY	Approved	\$0.00
Carry over from June 11, 2009 meeting. 1) Neutral in generator bonded to enclosure. 2) Verify that note for life safety as per New York City Building Code. 3) Show location of fire pump ATS. 4) Verify neutral bonds for transformer. Job finalized 8/4/09.						

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49550CO	09A0282CO	Coast 2 Coast Electric Cabling, Inc. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Union Club 101 East 69th Street New York NY	Approved	\$0.00
Carry over from June 17, 2009 meeting.						
49572	09A0287	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1 Pierrepont Plaza Brooklyn NY	Approved	\$650.00
Emergency breaker feeding new 3200A bus duct set at 4000A trip must be changed to 3000A. Job finalized 12/28/09.						
49573	09A0288	Apollo Electric, Inc. 224 West 30th Street, Suite 202 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1107 Fifth Avenue New York NY	Approved	\$650.00
49574	09A0289	Crana Electric Inc. 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Costo Wholesale 517 E. 117th Street New York NY	Approved	\$650.00
1) Provide ratings of new Square D switchboard. 2) Remove neutral bond in new Square D switchboard. Job finalized 7/29/09.						
49575	09A0290	Jemco Electrical Contractors, Inc. 92-13 180th Street Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Aviation High School 45-30 36th Street Long Island City NY	Approved	\$650.00
1) New 1200 amp disconnect and service switches to pick up grounding electrode conductor. 2) Verify that new panels are not feeding life safety loads. 3) Generator housing ground only permitted. 4) Remove neutral bond in generator switch. Job finalized 9/23/09.						

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49576	09A0291	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	30 Rockefeller Plaza, 55th Floor New York NY	Approved	\$650.00
1) Is feed to fire pump new or existing? 2) Provide FLA of fire pump. Job finalized 8/19/09.						
49577	09A0292	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Carnegie Hall 881 Seventh Avenue New York NY	Approved	\$650.00
49578	09A0293	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	6 Harrison Street New York NY	Hold	\$650.00
1) Provide second door to service room. 2) 5'c clearance needed in front of service switches. 3) Service entrance conductors to new 1200 amp switch is undersized. 4) Feeders out of new 1200 amp service switch is overfused. 5) Remote service switch to pick up grounding electrode conductor. 6) Service entrance conductors and CT are undersized.						
49579	09A0294	Jemco Electrical Contractors, Inc. 92-13 180th Street Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	P.S. 227K 6500 16th Avenue Brooklyn NY	Approved	\$650.00
49580	09A0295	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	120 East 87th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49581	09A0296	H.P. Electrical Desgins Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Fordham University 403 East Fordham Road Bronx NY	Approved	\$650.00
Provide clearance for transformer ventilation per manufacture's requirements. Job finalized 8/20/10.						
49582	09A0297	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 550 Brush Avenue Bronx NY	Approved	\$650.00
49583	09A0298	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS 101 141 East 111 Street New York NY	Hold	\$650.00
1) Service room layout does not comply with 110.26(c)(2)(a) or (b). 2) Relocate new switchboard away from existing steam pipes.						
49584	09A0299	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Elmhurst Hospital Center 79-01 Broadway Elmhurst NY	Hold	\$650.00
1) Locate new 300KVA transformers in building where load is served. 2) Relocate feed to 1600A FP switch to line side of main breaker of generator 'G.B'. 3)On 480V switchgear breakers 1000A and above to have GF indication(no trip). 4) Correct drafting error on (2) 400 KVA transformers. A-Y backward, ground on wrong side. 5) No device coordination study submitted. 6) Have engineer and/or ASCO appear to discuss sequence of operation. 7) Provide simplified sequence of operation.						
49585	09A0300	Lano Electric Co., Inc. 1633 Williamsbridge Road Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Med Alliance 625 E. Fordham Road Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49586	09A0301	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	16 East 46th Street New York NY	Approved	\$650.00
1) Service bus is undersized. 2) Provide fused cutouts on FA supply (N) to ATS not on load side. Job finalized 8/25/09.						
49587	09A0302	Mage Electrical Contractors 41-11 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	800 Second Avenue New York NY	Approved	\$650.00
1) Neutrals in 2000 amp disconnect switches are bonded to enclosure. 2) Transformer neutral to be bonded to building steel or water grounding electrode. 3) On existing service "B" verify feeders to 600 and 1600 amp service switches. 4) Existing 200 amp disconnect switch is overfused. 5) Provide signage at new service indicating where the other service is located. 6) Verify that room that new service is located in is fire rated. Job finalized 8/28/09.						
49588	09A0303	Mage Electrical Contractors 41-11 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	701 7th Avenue New York NY	Hold	\$650.00
49589	09A0304	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	1199 SEIU Benefit & Pension Fund 330 West 42nd Street New York NY	Approved	\$650.00
49590	09A0305	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	300 East 23rd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49591	09A0306	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	216-218 West 18th Street New York NY	Approved	\$650.00
Transformer neutral to be grounded to building steel or water electrode. Job finalized 7/29/09.						
49592	09A0307	Valmar Electric Corp. 2826 Westchester Avenue, Suite 202 Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	2205-2209 3rd Avenue New York NY	Approved	\$650.00
1) Meter for fire pump not shown. 2) Provide short circuit calculations and curves between service switch fuses and meter bank circuit breakers. 3) Neutral link not provided in switchboard. 4) Grounding and bonding not provided in switchboard. 5) Provide neutral in fire pump service switch. Job finalized 2/17/10.						
49593	09A0308	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	150 William Street New York NY	Approved	\$650.00
49594	09A0309	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Emblem Health 32 Old Slip New York NY	Hold	\$650.00
1) Neutral in generator not be bonded and grounded. 2) ATS #2 not shown. 3) Verify neutrals feeding ATS.						
49595	09A0310	GB Legend Electrical Contractors Corp. 302A West 12th Street, Suite 288 New York NY 10014	Requested approval for the electric service equipment proposed to be installed	40 West 57th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49596	09A0311	Barth-Gross Electric Co., Inc. 110 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	44 Wall Street New York NY	Approved	\$650.00
Provide bus size for bus that feeds the 800 amp switches. Job finalized 8/25/09.						
49597	09A0312	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	800 10th Avenue New York NY	Approved	\$650.00
Provide bus size for bus that feeds the 800 amp switches. Job finalized 8/25/09.						
49598	09A0313	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 24 Humboldt Street Brooklyn NY	Ok, but	\$650.00
Provide bus size for bus that feeds the 800 amp switches. Job finalized 8/25/09.						
49599	09A0314	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	PS 49 63-60 80th Street Middle Village NY	Ok, but	\$650.00
1) Verify bus size for C.T. 298 or 377. 2) Remove neutral bond in emergency side FACO. 3) Fire pump service switch to pick up grounding electrode conductor. 4) Neutral in generator to be bonded to enclosure and building steel or water Electrode. 5) Switches installed higher than 6'7" off of the floor. 6) Provide barrier in switchgear to separate. 7) Grounding terminals are reversed.						
49600	09A0315	Electrical Design Management, LLC 939 Eighth Avenue, Suite 301 New York NY 10019	Requested approval for the electric service equipment proposed to be installed	886 Westchester Avenue Bronx NY	Approved	\$650.00
1) 3 sets of 500 MCM fused at 1200 amps. 2) Parallel sets of conductors not properly installed. Job finalized 8/21/09.						

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49601	09A0316	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Hotel 39 27-05 38th Avenue Long Island City NY	Approved	\$650.00
1) Emergency side fire pump fusing to be 150%. 2) Verify that 3rd point ATS will be 3 pole type. Job finalized 8/25/09.						
49602	09A0317	DMMP Electric Construction Inc. 2571 East 2nd Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	654 Madison Avenue New York NY	Approved	\$650.00
49603	09A0318	Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Marriott Hotel 116 West 28th Street New York NY	Approved	\$650.00
Fire pump service switch not shown in service room. Job finalized 3/5/10.						
49604	09A0319	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Fort Totten. Bldg. #431 431 Walter Reed Road Queens NY	Approved	\$650.00
Outdoor fence to comply with 110.31(c) Job finalized 12/28/09.						
49605		Mega Electric 6406 14th Avenue Brooklyn NY 11219	Requesting permission to leave as installed service equipment for 1 store, 2 apartments and 1 PLP on the outside of a building.	185 Targee Street Staten Island NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49606		Dola Electrical Co., Inc. 3044 E. Tremont Avenue Bronx NY 10461	Requesting permission to replace an existing 200 amp outdoor service with new where the service will be installed inside of a NEMA 3R enclosure.	2950 Atlantic Avenue Brooklyn NY	Approved	\$0.00
49607		Guiding Light Electric, Inc. 5015 Avenue D Brooklyn NY 11203	Requesting permission to leave as installed AC cable that does not contain an insulated equipment grounding conductor as a wiring method in a place of assembly.	123-07 Liberty Avenue Queens NY	Approved	\$350.00
49608		Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requesting permission to leave as installed service entrance conductors for a fire pump that are tapped on the load side of a C.T. that is in the same cubicle of a switchboard that contains a service switch to remove a violation issued to the owner in 2003.	H & M 435 7th Avenue New York NY	Approved	\$0.00
49609		Jen Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214	Requesting permission to leave as installed an existing sprinkler booster pump that is second fused from a 200 amp disconnect switch fed from a PLP meter where the existing PLP panel and meter are being replaced in a building that has special permission for seven service switches.	459 Broadway New York NY	Denied	\$0.00
However, permission is granted to install an eighth service switch to provide power to the sprinkler booster pump.						
49610		V-Mar Electric LTD. 408 Grand Street Brooklyn NY 11211	Requesting permission due to water damage to replace one for one a defective 4000 amp service switch without filing Advisory Board drawings.	30 West 26th Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49611		K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requesting permission due to water damage to: 1) Replace a defective feeder and 400 amp disconnect switch. 2) Replace 2 sets of 500 MCM feeders fed from a 3000 amp service switch fused at 800 amps. 3) Replace 8 sets of 500 MCM fed off of another 3000 amp service switch fused at 3000 amps on a 1000 KVA service without filing full Advisory Board drawings.	244 Madison Avenue New York NY	Hold	\$0.00
49612		WB Engineers Consultants PLLC 110 William Street New York NY 10038	Requesting permission on drawing 49421 to leave as submitted a 100 amp 120/208V fused service switch in lieu of a 100 amp fused cut out to power a fire alarm.	Verizon 208 East 79th Street New York NY	Approved	\$0.00
With the stipulation that approval is required by the New York City Fire Department.						
49613		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to leave as installed due to a hardship to shut down switchboards, where equipment grounding conductors for feeders are installed as per Table 250.66 instead of Table 250.122.	Bank of America One Bryant Park New York NY	Denied	\$0.00
49614		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requesting permission to tap power for the emergency side of the fire pump from within a distribution board that will be second fusing from an existing generator fed paralleling switchboard located hundreds of feet away from the fire pump.	Milstein Family Heart Center 165 Washington Avenue New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49615		alvatore Campisi & Sons Electl Contrs, In 453 Onderdonk Avenue Ridgewood NY 11385	Requesting permission to replace a 2000 amp damaged second fusing distribution board on a 1000 KVA sevice without filing Advisory Board drawings.	11 West 19th Street New York NY	Hold	\$0.00
See Cal # 49407.						
49616	09A0320	Fisher Hamilton LLC 1316 18th Street Two Rivers WI 54241	Requested approval for use in New York City of your Modular Laboratory Bench System. Model/Series Numbers: 547H and 549H series		Approved	\$200.00
With the stipulation that the modular laboratory bench system is fixed in place and hardwired with a Chapter 3 wiring method, however, approval is required by the Office of Technical Certification and Research Department.						
49617	09A0321	Spider Agile Technology 2821 Fenwick Road Kenlowna BC VIX5E	Requested approval for use in New York City of your Modular Wiring System-Power Distribution		Denied	\$200.00
New York City's Amendment to Section 604 of the 2005 National Electrical Code restricts the use of this product in New York City.						
49618	09A0322	Altech Controls 4910 Wright Road, Suite 120 Stafford NY 77477	Requested approval for use in New York City of your Anti-Sweat Heater Controls for glass door refrigerated display Fixtures and coolers. Model/Series Numbers: AASC/57000;AASC- R/57011;AASC-S/57001		Approved	\$200.00
49619	09A0323	Global Finishing Solutions 12731 Norway Rd. Osseo WI 54758	Requested approval for use in New York City of your Paint Spray Booth. Model/Series Numbers: CSD2001.		Approved	\$200.00

ADVISORY BOARD CALENDAR

July 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49620	09A0324	A.L.P. Lighting Components, Inc. 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Fluorescent Strip Fixture with Riveted Ends, Pivot Style. Model/Series Numbers; KDST5, 120, 130, 140, 130T AND 140T.		Approved	\$200.00
49621	09A0325	A.L.P. Lighting Components, Inc. 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Fluorescent Strip Fixture with Riveted Ends, Pivot Style. Model/Series Numbers; KDST5DSM22, 34, 46, 58; KDST824, 36 and 48.		Approved	\$200.00
49622		Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requesting permission to install a fused 120/208 service switch in lieu of a fuse cutout to power a fire alarm system and to also install fuse pull outs in lieu of fuse cutouts that will be mounted inside of locked cabinets that will provide power to fire alarm systems throughout the building where the service switch and all cabinets will be painted red.	DCAS One Centre Street New York NY	Approved	\$0.00

With the stipulation that approval must be granted by the New York City Fire Department.