

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53511	15A0035	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) 5' clearance required in front of service equipment. 2) Verify future load conductors for service switches 1,2, 3 and 4. 3) 2nd fusings not shown. 4) How long will temp service be installed? 2/11/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53165	15A0156CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Carry over from March 18, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0283CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over June 17, 2015 meeting. Also, see 15A0455. 1) Verify that ATS' in the service room are not for life safety. 2) Provide HP ratings for future fire pumps or remove them from drawings, can't approve drawing without them. 3) Equipment grounding conductors undersized for service entrance connectors cup-E. 4) Drawing AB20 3 of 3 4 pole ATS on non separately derived system, How will gen be shut down? 5) Provide site drawing and routing of feeders 225.32. 6) Verify that switchboard complies with 408.60(F). 7) Provide coordination study that can be read, not reviewed. 8) AB20 3 of 3 EGC off generator undersized. 9) AB20 3 of 3 provide fused disconnect on load side of F.A. ATS.				
	15A0344CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
Carry over from July 15, 2015 meeting. 1) Provide heat rise testing method. 2) Show 1000 KVA substations @ 480 volts. 3) Provide grounding scheme. 4) Show key interlocking scheme.				
	15A0386CO	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
Carry over from July 15, 2015 meeting. 1) Explain how reduced neutral were calculated from apartments. This item addressed by sending in section 220.61 of the NEC. No calculations on how calculations were done. 9/18/15 Rejected. 1) Items 1 and 2 not addressed.				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0415	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Short circuit study to be performed and stamped by a PE. 2) EGC to fire pump service switch undersized. 3) Verify that service bus complies with Section 368.119. 4) M52-load side bus of 1600 amp disconnect switch undersized. 5) Generator floor plan not submitted. 6) Verify electrical contractors office location with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/28/16 1) Item 1 not addressed. 2) 1600 amp emergency feeder to "EMSWB" not derated, conduit overfilled. 3) Item #4 not addressed. 4) More work added to original drawing requires a new filing and review. 5) Staple coordination study together in the future.</p>				
53265	15A0419	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show type of fuse for 4000A service switch. 2) Through bus undersized to 2000 amp disconnect switch, with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/6/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/25/18 - swap dwg A rev 4</p>				
53166	15A0422	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/23/17 - 1) Busbar feeds SS # 3 & FA switch is undersized. 2) Neutral of SS # 3 to be bonded and grounded. 3) 600A TR fuse doesn't coordinate with 1200A A4BY (SS#3) 4) Provide service rating for RP-C. RP-1 & TWC Panel. 5) Cond. Feeds ATS-3 Emergency side- is undersized. 6) Show bus size and breaker values in EMDP, RP-c, RP-1 and TWC Panel. 7) Provide panic bar to the door. 8) Label all S.Switches in floor plan. 9) Physical doesn't match one line DWG-2 of 2. 6/26/19 1) Confirm 5' clearance to ss#4-confirm that distribution of ss#3 doesn't obstruct clearance of ss#4. 2) Provide breakers value in "RP-C" panels. 3) Comply with 408.36-provide main OCPD to "RP.C" panels. 4) Provide series rating doc. 8/12/19 1) Provide series rated document. 9/6/19 Swap Dwg # 1 of 2 and 2 of 2 Rev-4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53350	15A0426	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump conductors and equipment grounding conductors undersized, fire pump emergency feeder fusing undersized. 2) Show SEC's to fire alarm S.S. 3) Show size of section bus feeding 2000 amp s.s. 4) Show vertical bus in DB-2. 5) Relocate jockey pump tap ahead of the F.P. controller(RSTS and Cont). 12/3/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/27/18 - 1) Cond in between section 'DB-1' panel is undersized 2) Provide coordination study signed & sealed by P.E. 3) Provide tap cond size & length for future retail. 4) 1600A A4B! & downstream 800A A4BY doesn't coordinate 'DB-3" panel. 5) Provide sectional bus size in "DB-2" section # 2 6) Physical doesn't match one line "DB-1". 5/15/19 Swap dwgs 1 and 2-Revision 4. 2/16/2024 Amended plan # 1 Rev 5 .Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
53192	15A0430	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that service switchboard complies with Section 408.60(F). 2) Add generator notes to drawing. 8/20./15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53167	15A0442	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/30/16 Swapped drawing 1-Revision 2 5/18/2017 - swap dwg # 1 of 1 rev 3</p>				
53394	15A0446	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Equipment cut sheets not provided, is equipment listed provide documentation. 2) Transformer tap lengths not shown. 10/6/15 Rejected. Listing information for SEL-751-Feeder protected relay not provided. 12/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/18/16 Swapped drawing A-Revision 1 and Drawing B-Revision 2. 2/31/17- swap dwg A - Rev 2</p>				
53263	15A0450	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1 Line does not match physical 400 and switch not shown. 10/5/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0455CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>Carry over from July 15, 2015 meeting. Also, See 15A0283. 1) Verify which # this building is. 2) Identify which switchboards are feeding the equipment on this drawing from E-J Electrical, 15A0283 SB-CUP-E 2500A s.s. 3) Provide mechanical ventilation in new electrical room. 4) Reidentify service room as electrical room. 5) Verify that all equipment in the service room is being fed from the 2500 A disconnect switch FA and FS. 6) Show drawing of routing and feeders 225.32. 7) Are 750 KVA transformers 3rd fusing. If not, show connection, verify from manufacturerer minimum clearance between transformers. 8) Service switch KRPC fuse doesn't coordinate with 1200 A A4BQ fuse in Drawing #2. 9) Verify that 60A F.A. switch is on the line side of transformer, FA not on 1 Line.</p>				
53250	15A0467CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from July 15, 2015 meeting. 1) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Room layout for 1040KW genset. 9/16/15 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/19/17 swap dwgs 1,2, & 3 Rev 6 3/22/18 - 1) Provide updated coordination between 1600A breaker and downstream fuse for standby generator 4/4/18 - swap dwgs 1,2 & 3 Rev 7 5/3/18 - swap dwg 1,2 & 3 Rev 8 - No More Swaps</p>				
54023	15A0470	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Transformer secondary taps exceed 25'. 2) Show lengths of transformer secondary taps. 3) Bus in 3000 amp switchboard to comply with 408.60(E)(2) and 408.60(E)(5). 4) Indicate rating of F.P. wiring. 5) Provide signed letter addressing how all the issues in the coordination study are being complied with. 7/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0475	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Identify which switchboard is the existing board on the room layout, switchboards not identified as ESW-CRC. 2 Coordination study from a P.E. not submitted. 3) 3 sets of 4/0 fused at 1200 amps and conduit size. 4) Transformer secondary circuit breaker set to high. 5) Verify that normal and emergency dist. are not in same room with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code</p>				
	15A0477	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
<p>1) Provide 2nd set of genset cut sheets. 2) Is emergency switchboard is feeding life safety. If yes, show the systems on 1 Line.with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/6/15 Rejected Generator main switch to be ground fault type. 3/23/16 Void in lieu of Cal. #53617, Submission #16A0138.</p>				
53271	15A0478	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify compliance with 408. 60(F), how will conduit enter the rear of medium voltage switches? 2) How long will temp service be in use? 3)Add general notes 10/6/15 Job finalized.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53267	15A0479	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) 1 Line does not match manufacturer's cut sheet of switchboard(bus sizes) . 2) Ground bus not shown on 1 Line. 3) Correct types to show 2-3" conduits on load side of 600 amp disconnect switch with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/6/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53802	15A0480	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Correct typo's for switch sizing and fuses in distribution panel. 2) Provide main in DP-B-(misidentified as service). 3) Where is DP-B?. 10/5/15 Rejected. DP-B does not comply with 240.21(B)(1). 2/18/16 Rejected. DP-B does not comply with 240.21(B)(1). 5/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53262	15A0482	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide short circuit curves between service switches and Q5H circuit breakers. 2) 3 service switches identified as #7's. 9/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53307	15A0485	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Transformer secondary taps undersized to 400A disc's. 2) identify switchboard MSB-A in service room. 3) Vita link cable cannot be installed in conduit. 4) How much meter banks taps be made? 5) Provide calculations for meter bank loads. 6) Verify 4 conductors feeding transformer. 7) Verify short circuit curve Fu ss #4A MCB DP-3.with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/21/17 - swap dwg A,B,C,D 7/25/17 - swap dwg A Rev 5</p>				
53184	15A0486	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/4/17 - swap dwg with rev 1</p>				
53185	15A0487	Requesting permission to utilize Article 690 of the 2014 NEC to allow the installation of listed 1000 volt solar photovoltaic equipment to be installed on a building.	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0488	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Verify size of SEC's to fire pump service switch. 2) Fire rate fire pump emergency feeders. 3) Generator neutral not to be bonded and grounded. 4) Tapped conductors feeding 400 amp disconnect switches undersized. 5) Panel DPA 1 Line does not match physical with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/6/15 Rejected. 1) Fire pum is 120/208 volt 230 volt FLA is incorrect, how will MI cables be terminated on emergency side, the normal feeder is undersized, if transition boxes are being used for MI cable show it on the 1 Line. 3/22/16 Denied MI cable not properly installed.</p>				
53177	15A0490	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/20/17 - swap dwg with rev 3</p>				
53164	15A0491	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/28/18 Swap dwg with Rev 1</p>				
53176	15A0492	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53509	15A0493	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify that VFD cables are listed, provide manufacturer's installation instruction that cable is listed to installed in conduit, how are 2 sets installed in 3-3" conduit. 2) Where will the VFD PVC jacketed cables be installed. 3) Provide copy of field evaluation by NRTL at time of inspection. 4) Show length of transformer secondary conductors. 5) EGC load side of transformer undersized. 2/11/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/24/16 Swapped drawing A071501- Revision 2. 5/17/2017 - ok swap dwg 1 rev 3, dwg 2 rev 2</p>				
53186	15A0496	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/6/18 1) Provide 5' clearance for F.A. service switch. 2) Service entrance cond is undersized. 9/5/18 Swap dwg #A-Revision 1 and dwg B-Revision 2.</p>				
53162	15A0497	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53150	15A0501	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53178	15A0503	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/10/2017 - ok- swap dwg # 2 of 4 Rev -1				
53553	15A0504	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Where is the SEB located, verify 12 sets of service entrance conductors and EGCs. 2) Verify sizes of EGC's. 3) Grounded conductor to be brought to fire pump service switch. 4) GEC undersized to service switch #5. 5) GEC undersized to MDP2-1 thru 3. 6) Verify by note under panel EMDB-1 whether 3 or 4 for ATS' will be used from panel EMDB-1.with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/6/15 Rejected. 1) Service entrance conductors to be concrete encased from end box to service room, provide length of secs. 2) Grounding electrode conductor undersized service switch #5. 3) Room layout drawing is revision 1 but does not indicate any changes. 12/24/15 Rejected. 1) Drawings 1 of 3 and 2 of 3 should be Revision 2s. 2) Layout drawings to be Revision 2, not 9. 2/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/25/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/13/2017 - 1) Service entrance conductor to SS# 5 undersized. 2) Cable from Generator to DS-2 and DS-2 to EMDB-1 panel undersized. 6/22/18 1) Fire alarm tap to be ahead of all building service disconnecting means-760.41(A)(1). 2) Tap cond of 400A disconnect switches and 200A disconnect switch are undersized. 8/13/16 - 1) EGC of 100A sws are undersized T-250.122 2) Service cond feeds SS# 4 & F.A. sw is undersized . 1) Service cond. feeds ss#4 and F.A. switch is undersized. 9/20/18 Swap dwg #1-Revision 6 and dwg #2-Revision 3.</p>				
53163	15A0506	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swapped Drawing B, Revision 1.6/16/2017 - ok, swao dwg B rev 2				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53442	15A0507	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire alarm system to be tapped ahead of main service switch. 2) Confirm with Con-Ed the C.T. arrangement in switchboard with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/30/15 Fire alarm service switch not metered with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/30/15 Fire alarm service switch not metered with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/20/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/20/16 Swapped Drawing A-Revision 3 and Drawing C-Revision 3. 5/18/2017 - ok swap dwg A rev 4, dwg C rev 4</p>				
53149	15A0510	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53315	15A0512	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Length of tap not shown. 11/4/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/10/16 " Rejected" 1) Tap length corrected. 2) Size of the disconnect switch still shows 1600 amp not 2000 amp. 7/19/16 Swapped Drawing 1-Revision 1				
53527	15A0513	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Provide coordination, size and type for meter bank O.C.P.D. 2/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53172	15A0514	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0515	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Veify FLA for fire pump, f.p. s.s undersized for 177 FLA, should be 169. 2) Coordination and short circuit not submitted. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.				
	15A0517	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Need old job with this one. 2) Applicant is required to come to explain the work.				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0518	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) 5' clearance required in front of service switches. 2) 3' clearance required in front of distribution board. 3) Show all tap lengths on existing, does 400 amp breaker have a main? 4) Service entrance conductors for new 1200 amp ss undersized, and feeder undersized. 5) Verify bus sizing for new 1200A ss.				
	15A0520	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/21/17 Provide barrier in the other side of service switchboard if distance from the wall is more than 12in-Section 230.64(B)(4)				
53151	15A0522	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53161	15A0523	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR This submittal voids out Cal. #52648. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/18/15 Swapped drawing 1 and 2-Revision 5s.				
53153	15A0524	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/17/16 Swapped drawing 1, Revision 1. 8/5/19 Swap Dwg-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
53159	15A0525	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR This submittal voids out Cal.#53034. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53154	15A0526	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53155	15A0527	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/28/15 Swapped drawing 1-Revision 1.				
53156	15A0528	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53174	15A0529	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53305	15A0530	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify 5' clearance in front of fire pump service switches, and service switch B-1. 2) Where are remote Con-Ed end boxes located in relation to service rooms. 3) Fire pump service switches 2 and 3 tapped from line side of fire pump service switch 1. 4) Emergency panel ESB-3-1 misidentified on 1 Line drawing with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/21/15 Rejected 1) Emergency switchboard ESB-3-1 not shown on 1 Line. 2) Emergency board does not show switch for EDP-1. 3) Indicate changes on all drawings. If no changes were made, indicate so, with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/13/2022 Amended Plan 1 and 2, Rev. 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
53157	15A0531	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53249	15A0532	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) 1200 amp A4BQ Doesn't coordinate with 800 amp 2nd fuse ODB Board. 2) Fire pump 1 line show neutral conductor feeding the fire pump. 9/15/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/24/17-swap dwg # 1,2, & 3 rev4 4/24/18 - swap dwg 1m & 3 Rev 5</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53158	15A0533	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53160	15A0534	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53256	15A0535	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Verify fusing of generator, may be oversized, with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/22/15 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53191	15A0537	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/24/16 Swapped Drawing D-Revision 1. 8/21/17 1) Cond feeds f.p. emergency side- is undersized. 2) F.P. OCPD is emergency side-is undersized. 3) Fix typo for F.P. & B.P. 4) Show bonding and grounding to ssw #4B and 5B or verify if it is part of the main switchboard. 3/16/18 - swap dwg ACS-D-12117				
53175	15A0539	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0543	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
1) Shw front clearances in front of switchboard DESS-PESS-SB-15-B1 and DES-PESS-SB-A1. 2) Verify 650 KCM conductors. 3) Feeders overfused. 4) Show feeder size to fire alarm switch and system. 5) F.P. feeder not fire rated outside service room. 6) Short circuit study SEC 3.5 recommendations must be addressed. 3/23/16 This job void in lieu of Cal. #53616, Submission #15A0685.				
	15A0545	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
1) Clarify site plan to show location of service equipment and clearances in front of equipment. 2) How will service be physically protected on job site? 2/24/16 Void submittal as per 15A0772, Cal. #53551.				
54954	15A0546	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Physical of equipment does not match room layout service switches mismarked and explain transition section without 3' clearance in front of it, not on physical and 1200 amp switch not shown on layout. 2) Clarify feeder from 1200A s.s. to distribution board and conductors between switchboard sections. 3) EGC's undersized on 800 amp feeders. 4) Fire pump information not provided. 5) Vertical section bus size is missing. 6) Correct door swing on E.S.R. 3/20/17 - 1) Section BUS undersize in service switchboard section 4. 2) FP & JP conductor undersize. Comply section 695.6 (1) for FP & JP conductor size. 8/2/17 - 1) Service bus in service switchboard section 4 & 5 is undersized. - sec 230.42(A)(2) 2) Item not 1 not addressed 3) Jockey pump to follow tap rules. 12/21/17 - Job Finalized *with stip: that service bus size for SS# 1,2, & 3 approved based on Demand submitted. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

August 12, 2015

Approval #	Submission #	Type of Request	Status	Fee
53168	15A0547	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53169	15A0548	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53170	15A0549	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/19/16 Swapped drawing 1 of 1-Revision 1.				
53187	15A0554	Requesting permission to leave as installed a vertical emergency fire pump feeder and conductor support box installed inside a concrete wall inside of a fire rated electrical closet located in the middle of the building where the conductor support box will have a metal cover.	Approved	\$0.00
<p>With the stipulation that a plaque with signage is provided on the 2 hour fire rated sheet rock wall indicating that there is an electrical pull box behind the enclosure. Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PW1 as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 				