

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50301CO	10A0331CO	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
Carry over from September 15, 2010 meeting. The submittal is not in Advisory Board format, and the manufacturer's physical drawings were not submitted				
50602CO	11A0106CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from April 13, 2011 meeting. 1) Verify 4 sets of MI cable feeding limited service fire pump. 2) F.A. system undersized EGC's. 3) Vertical bus in service switchboard undersized. Job finalized 11/10/11.				
50714CO	11A0207CO	Requested approval for the electric service equipment proposed to be installed	OK, but	\$0.00
Carry over from March 25, 2011 meeting. 1) TVSS not shown on 1-Line, where is TVSS located? 2) Fire pump feed cannot be tapped from cubicle that contains overcurrent protective devices.				
50746CO	11A0229CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from June 15, 2011 meeting.				
50749CO	11A0232CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from June 15, 2011 meeting. Length of transformer tap to new 400 amp panel not shown. Job finalized 9/1/11.				

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50804	11A0274	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Through bus undersized.v 9/13/13 job finalized..				
50805	11A0275	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50806	11A0276	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Neutral disconnect link installed on line side of bonding and grounding. No supplemental ground lug provided. 2) Is DBI new or existing, bus size not provided. 3) Show second fusing off of existing service switches. 4) Service switch 3A not identified on 1-Line, is it rear accessible? 5) Dimension clearance at corner of new SEB. 6) Submit manufacturer cuts.				
50807	11A0277	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that existing service room is mechanically ventilated. 2) Fire pump switch, and circuit undersized. 3) Provide signage in building 92 indicating where the service is located. Job finalized 9/22/11.				
50808	11A0278	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify that service room is mechanically ventilated. Job finalized 9/22/11.				

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50809	11A0279	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50810	11A0280	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50811	11A0281	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50812	11A0282	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50813	11A0283	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50814	11A0284	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1-Line does not match room layout. Job finalized 10/21/11.				
50815	11A0285	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50816	11A0286	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Equipment grounding conductors in MC cables are undersized. 2) More than 6 switches supplied from transformer, how long are transformer secondary conductors. 3) PVC jacketed MC cable to be behind 1 hour fire rated construction in the 2008 NEC. 3A) Provide secondary overcurrent protection on step-up 750 KVA transformer . 4) How long are transformer secondary conductors. 5) Show "DP-EM" on drawings. 6) Show F.A. switch on generator room floor plan. Job finalized 1/15/13. 4/7/15 Swapped Drawing 1,2,3, Revision 2s.				
50817	11A0287	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Service switch over fused. 2) Provide calculations for reduced neutral size. Job finalized 10/25/11.				
50818	11A0288	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50819	11A0289	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50820	11A0290	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50821	11A0291	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify that rear cover of service switch is not removable. Job finalized 9/19/11.				
50822	11A0292	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
The tap to feed the fire pump cannot be made in the same enclosure that contains overcurrent protective devices.				
50823	11A0293	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50824	11A0294	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50825	11A0295	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50826	11A0296	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
1) Generator distribution rooms to have 2 means of egress 110.26(c)(2). 2) Generator to have ground fault indication. 3) Fire pump circuit conductors normal and emergency to be fire rated. 4) Equipment grounding conductors undersized.				
50827	11A0297	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Service entrance conductors to 2000 amp C.T, not identified. 2) Are circuit breaker panels for future use? AIC not provided. Job finalized 1/14/13. 10/30/14 Swapped Revision 2. 5/4/15 Swapped Revision 3.				
50828	11A0298	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
5/11/19 Received letter stating change of contractor name from Polo to Pac Electric Corp. 7/12/19 Swap dwg #071101-Rev-3 8/8/19 1) Comply with 760.41(A)- Fire pump tap to be ahead of all service disconnect means. 2) Confirm supplemental grounding. 3) Confirm 5' clearance without obstacles in front of SS #4 & Fire Alarm s. sw. 4) Change Revision # from 3 to 4 - Revision #3 was changing contractor name on the Dwg. 1/3/20 Swap Dwg # 071101 Rev-5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50829	11A0299	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Equipment grounding conductor undersized. 2) Provide neutral link in service switch and supplemental ground. 3) Provide cut sheet of service entrance box from manufacturer. 4) Provide physical of new distribution panel. Job finalized 11/29/11.				
50830	11A0300	Requested Concept Approval:	Hold	\$0.00
Designer to appear to explain job.				
50831	11A0301	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) 5' clearance needed in front of new service equipment. 2) Is new equipment rear accessible? Can rear covers be removed? 3) Fire pump feed taken from cubicle that contains overcurrent protective devices. 4) Where is special service fire pump located? 5) 1200 amp through bus undersized. 6) Generator frame not grounded.				
50832	11A0302	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50833	11A0303	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) How long is the tap to panel HDP-CHP. 2) Transformer T-1 not grounded. 3) How long are transformer T-1 secondary conductors to new distribution board. 4) Provide signage on new distribution board warning of live blades. Job finalized 9/22/11.				

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50834	11A0304	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50835	11A0305	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Service switch #5 not bonded and grounded, no neutral link provided. Job finalized 9/22/11.				
50836	11A0306	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Fire pump conductors to be 2 hour fire rated. 2) Feeders overfused. 3) Where is FA emergency switch located. Job finalized 10/11/12. 12/10/13 Swapped Rev 2 address correction Brooklyn to Manhattan. 8/18/15 Swapped Drawing C, Revision 2. 4/18/16 Swapped drawing C-Revision 3.				
50837	11A0307	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
Provide fused disconnect switch for portable generator 700-5(G) and bond and ground it. 7/15/14 Rejected Provide fused disconnect switch for portable generator 700-5(G) and bond and ground it. 12/1/14 1) Provide fused disconnect switch for portable generator 700-5(G) and bond and ground it. 2) 4 sets of 4/0 fuse at 1600 amps. 3) 4 pole ATS feeder 3 pole ATS.				
50838	11A0308	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50839	11A0309	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50840	11A0310	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Show size of vertical bus in new board. Job finalized 10/24/11.				
50841	11A0311	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Jumpers in disconnect switch undersized. Job finalized 10/25/11.				
50842	11A0312	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Will grounding collector bus be accessible with barrier installed. Job finalized 10/24/11.				
50843	11A0313	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50844	11A0314	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50845	11A0315	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Fire pump tap cannot be taken from a cubicle that contains overcurrent protective devices.				
50846	11A0316	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50847	11A0317	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50848	11A0318	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50849	11A0319	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
50850	11A0320	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
Wrong calendar number for the above job address. The correct calendar # is 50856.				
50851		Requesting permission to replace a defective 400 amp service switch with new on a 1000KVA service	Approved	\$0.00
50852		Requesting permission due to lack of space inside of the existing service room to install a new service switch in a remote electrical distribution room where signage will be provided indicating where the other service is located	Approved	\$0.00
50853		Requesting permission to extend approximately 40 feet of service entrance conductors in fire rated MI cable in a ventilated trough where it is not feasible to trench the existing slab	Denied	\$0.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Type of Request	Status	Fee
50854		Requesting permission to replace an existing defective 800 amp service switch with new where the front clearance is 28 to 30 inches and there is no other location to install the new switch.	Hold	\$0.00
Pending field evaluation.				
50855		Requesting permission to install rigid non metallic conduit and PVC coated rigid metallic conduit exposed indoors in a corrosive area inside of the New York aquarium salt water holding tanks.	Approved	\$0.00
50856	11A0320	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Equipment grounding conductor undersized for 2000 amp fuse. Job finalized 9/19/11.				
50857	11A0321	Requested approval for equipment for use in New York City of your Fino Undercabinet Lights.	Approved	\$200.00

