

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54049	15A0710CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from November 18, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/28/16 Swapped drawings 1 and 2-Revision 3.				
54026	15A0837CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
OR This submittal voids out submittal number 13A0169, Approval #52948. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54062	16A0155	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 10/15/18</p> <p>1) Provide 3' clearance in front of ss-1 section #1. 10/25/18 Swap Dwg #A.1 Pg 1 of 2.</p>				
	16A0196CO2	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>Carry over from July 13, 2016 meeting. 1) Coordination study not provided. 2) How is the feeder between the generator and the 13KV secondary switchgear protected. 3) Is Co-gen listed or will it be field evaluated by a OSHA recognized testing laboratory with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0253	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Service C tap conductor to 400 amp switch undersized. 2) Provide manufacturer's cut sheets of switchboards with listings. Show how bus is formed and provide calculations for distribution boards, cut sheets of bus. 3) Service B 2 set of 500 KCM overfused. 4) Fire alarm system #10 conductors overfused. 5) Verify that park metal switchgear is listed. 6) Provide emergency room layout. 7) Show service switch for fire pump B. 8) Show ATS room. 9) Generator cut sheet not provided. 10) Provide wiring method from generator to switchboard with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
54417	16A0294CO	See comments for requests and status	Approved	\$0.00
<p>Requesting permission as per attached drawings to: 1) Approve the power source for fire command and all data gathering panels as shown. Status: Approved -A dedicated ATS connected to primary and secondary power to be provided in a separate 2 hr enclosure. 2) Advisory Board concurrence that the automatic transfer switches are not in the same room as the power sources. Status: Approved -A dedicated ATS connected to primary and secondary power to be provided in a separate 2 hr enclosure. 3) Advisory Board approval to utilize #12 copper equipment grounding conductors on 15 ampere circuits for pre-action detection, clean agent, and dry chemical panels as per Table 250.122. Status: Approved. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/15/17 -Re-submitted drawing E-353da is approved and to permission to leave the final alarm system as installed with #12 copper equipment grounding conductors with 20amp fusing is approved. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/8/17 Based on recent documentation, Items 1 and 2 have been changed from denied to approved status.</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54920	16A0348	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump 1, 2 emergency side underfused. 2) ATS-2 #7 overfused on emergency side. 3 EMR-DS-23-D1, EMR-DS-23-C1 show conductors in split panel. 4) Show transformer secondary tap length PNL-LS VP-23-D. 5) Panels 5D-2-D1 and SD-2-C1 not shown on 1 Line or physical. 6) Coordination study not provided. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/18/17 - 1) Correct neutral connection 'EM-DES-2A' & 'EM-DS-2-B' 2) Comply with section 408.60(E)(B) for paralleling switch board for bus bars connected to 4000A main breaker , & 2000A breaker in section no. 9 3) Item # 5 was partially addressed. 4) Provide full size one line of the coordination study 10/3/17 - 1) Verify you followed the recommended settings for each adjustable CB & fuse. & comments of the coordination of devices has been addressed. 2) Coordination study one line doesn't match submitted one line. 11/27/17 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/2021 Amended Plan # AB-40 -01 of 1 Rev- 9 and SB-40 -01 of 7 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54037	16A0366	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54051	16A0391	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/27/18 - swap dwg 1 Rev 1. 5/29/18 Swap dwg 1-Revision 2				
54136	16A0394	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
The contractor paid twice for the same submittal number but one receipt was for 16A0394. Who will be performing bus bar installation on 4000 amp service switch to connect PV system. 10/6/16 Job finalized. With the stipulation that 1000 volt SMA Sunny Tripower 3000 TL inverters, and SMA connection units 1000-US combiner boxes can be installed Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54047	16A0398	Requesting permission to replace existing Federal Pacific circuit breaker interiors with Cutler-Hammer retro-fit interiors and covers on feed through panels and leave at present height 7'2" off the floor due to rigid conduits in concrete walls making it a hardship to lower the panels to 6'7" to the top circuit breaker in 23 apartments.	Approved	\$0.00
With the stipulation that the fault current at the panels does not exceed 10,000 amp. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54398	16A0403	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Drawing AB-02 through bus on 1 Line has typo bus not complete. 2/9/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54133	16A0404	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Service bus between 1st and 2nd sections undersized with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/4/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/28/17 - swap dwgs AB20 1 of 1 Rev 2, PB60-02 of 8, FP51 1 of 1 Rev 1, SB20 1 of 1 Rev 5 2/1/19 Swap dwgs AB20 1 of 1 Rev 3, FB51 1 of 1 Rev 2, SB20 1 of 1 Rev 6, PB60 1 of 8 4/15/19 Swap Dwg AB20 1 of 1 rev 4.				
54035	16A0473	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54063	16A0480	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54064	16A0490	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
54134	16A0491CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from July 13, 2016 meeting. Fused switch, not circuit breaker shall be installed remote from the emergency switchboard with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/3/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/3/2020 Swap drawings # A REV 3, D REV 2, E REV 4, F REV 2, H REV 3 and I REV 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 10/2/2020 Swap Dwgs# A Rev 4, D Rev 3 and E Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 12/14/2020 Amended Plan # D Rev-4,& E Rev-6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54065	16A0492	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 2/26/18 - swap dwg A Rev 2, B Rev 1 3/1/2019 Swap Dwg #A Rev-2 #B Rev-2				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54773	16A0499	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Cut back concrete pad to clear egress path with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/3/16 1) Show bonding and grounding of existing service equipment. 2) Fire pump emergency breaker undersized. 3) Fire pump transition conductors undersized. 9/25/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/8/19 - 1. Provide coordination between existing 4000A A4BQ fuse & new downstream fuses.</p>				
54864	16A0501	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Drawing 2-show Time Warner and Verizon feeders and switches. 2) Drawing 2-Fire alarm disconnect switch fed from Building A to be unfused. 3) Drawing 3-Equipment grounding conductor feeding fire pump controller undersized. 4) Drawing 5-Room layout does not match physical MSC-C-N and MBDP-C-N1. 5) Drawing 2 and 3 verify that the 3000 any feeders are ground fault protected with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/2/17 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/27/2020 Amended Dwgs# 1 & 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/24/2020 Amended dwgs# 2 & 3 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54126	16A0515CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from July 13, 2016 meeting. Fire pump normal side equipment grounding conductor undersized with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/6/17 Rejected 1) Feeders and ECGs undersized. 2) SDS to be bonded in one location only. 3) Verify that neutral in Gen is bonded to the enclosure. 5/18/2017 - ok swap dwgs 1 & 2 rev 3. 10/15/2020 Amended Dwgs# 1 & 2 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 11/17/2020 Amended plan #2 of 2, Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 12/21/2020 Amended dwgs# 1 Rev 5, 2 Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54290	16A0516	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Wiring methods not shown on E.1.0AB. 2) Conductors feeding normal side of ATS' overfused. 12/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/6/19 Swap Dwg E-1.0AB-Revision 3, dwg E-6.0AB-Revision 2 and dwg E-6.1AB-Revision 3. 11/1/19 Swap Dwgs E-1.0AB rev 4, E-6.0AB rev 3, E-6.1AB rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
54066	16A0517	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
54033	16A0518	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0520	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Verify no emergency feeders are running through the service room. 2) Mechanical ventilation. 3) Emergency feeder switch on load side of ATS not permitted in service room as well as its feeders. 4) Emergency disconnect for 400A on load side of ATS not to be bonded or allowed in service room. 5) Emergency feeder for fire alarm to be taken from line side of generator switch. 6) Emergency switch for fire alarm can't be bonded with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
	16A0541	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Short circuit study to be performed, signed and sealed by a P.E. 2) Verify that service entrance conductors are concrete encased from underground to 4h floor service room. 3) Show cable support boxes for the service entrance conductors. 4) Show Con-ED box on drawing 3. 5) Service entrance conductors undersized. 6) Derating is 70% for service entrance conductors. 7) Was service installed on ground floor and then moved to 4th floor?</p>				
	16A0543CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>Carry over from July 13, 2016 meeting. 1) Provide sequence of operation. 2) Designer to appear at future meeting to explain installation, lack of information on submission.</p>				
54050	16A0544CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from July 13, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/20/17 - swap dwgs AB20-1of2 rev 1, AB20-2 of 2 rev 1 12/18/17 - swap dwg FP20-01 of 1 Rev 1 2/26/18 - swap dwg # FP20 1of 1 Rev 2 LAST SWAP. 3/3/2021 Amended dwgs# AB20-01 of 2 Rev 2, AB20-02 of 2 Rev 2, FP20-01 of 2 Rev 2 and AB151511 Rev A Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54182	16A0548	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Neutrals in Con-ED box to bonded to the enclosure. 2) Verify if generator is or not a separately derived system. 3) 3 or 4 pole ATS' being used. 4) Show short circuit current at fire pump controller, cut sheet not provided. 5) Is jockey pump controller service rated, show fault current at pump and provide cut sheet. 6) Fire pump CT to be 400A and 3 phase not single phase with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/1/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	16A0574	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Drawing 1-Fire pump emergency Board to be fed directly from line side of emergency switchboard. . 2) Drawing 1-show fuse size of normal supply to fire pumps. 3) Fire pump emergency feeders not fire rated. 4) Verify 120/208 volt fire pumps fed from 480V board. 5) Medium voltage feeders overfused. 6) Existing fusing for medium voltage feeders not shown on drawing. 7) Verify that there is a cutoff switch for the generator.</p>				
54067	16A0581	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
54185	16A0582	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination study. 2) Provide main fuse type. 3) Provide cut sheet and rating for new devices. 11/116 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/27/18 - swap dwg 1,2,3 Rev 2</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54173	16A0583	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Entrance to switchboard to comply with 110.26(c)(2) 24". 10/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54039	16A0587	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
OR Job addresses 76 Pinehurst Avenue, 177 Wadsworth Avenue and 611 West 180th Street-Manhattan. Also, 350 Richmond Terrace-Staten Island. With the stipulation that Solar Edge Inverters. Models: SE5000 KUS, SE10KUS, SE20KUS, SE33.3 KUS, Solar Bos combiner boxes and Solar Edge Power Optimizer 1000 volt equipment be installed. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54032	16A0588	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54184	16A0589	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Length of taps off of bus ducts not shown, 10'ok, 25' NG. 2) Equipment grounding conductors tapped from bus duct undersized 250.122(G). 3) 1 Line doesn't match physical 3000 amp service switch. 4) Fire pump service entrance conductors, feeders, and equipment grounding conductors to 125 HP fire pump undersized (Reversed). 5) Fire pump feeders not fire rated. 6) Separately derived generator to be bonded and grounded at generator, one location 250.30(A)(1). 7) Fire alarm service entrance equipment grounding conductor undersized. 8) Verify 16 sets of SEC's and EGC on each service. 9) Verify bus size feeding 1500 KVA transformer. 10) Bus off 1500 KVA transformer undersized. 11) 1500 KVA transformer secondary not bonded and grounded. 12) DPA-2-1 verify EGC between sections. 13) Feeder to panel DPA-1-1 overused with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 08/30/2016 1. Separately derived generator neutral to be bonded in location only</p> <p>2. Items 5, 6, & 13 not addressed with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/1/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/20/2020 1) Jockey pump tap to follow tap rules-Dwg 1 of 4. 2) Confirm #of sets feeding new fire alarm dwg # 2 of 4. 3) EGC to tap conductors are undersized -T250.122 dwg #2 of 4. 4/23/2020 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/23/2021 Amended plan# 1 of 4 Rev 6 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54036	16A0595	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0596	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Generator overfused. 2) Which transformer from 16A0522 is feeding this switchboard? 3) Provide short circuit study performed, signed sealed and stamped by a P.E. 4) Typo on feeders supplying switchboard.				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0597	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Which transformer from 16A0522 is feeding switchboard. 2) Provide coordination study performed, signed and sealed by a P.E. 3) Tapped conductor to 400 amp device undersized with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/7/19 - Swap dwg #A061603 Rev-4.</p>				
	16A0598	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Electrical room door to open outwards. 2) Which transformer on 16A0522 is feeding this switchboard? 3) coordination study performed, signed and sealed by a P.E. not provided. 4) There are only 2 transformers on 16A0522 that feed 3 switchboard, How? 5) Verify 130,000 short circuit current for switchboard.</p>				
54068	16A0600	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
	16A0601	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Show coordination emergency side. 2) Provide full size plan of generator and enclosure can't locate Gen PNL, transformers not show on 1 Line with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0602	Requesting permission to leave as installed a 10 H.P. sprinkler booster pump installed in the basement without the feeder being fire rated.	Denied	\$350.00
54053	16A0603	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
SANDY Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/29/16 Swapped drawings A and B-Revision 3.				
54083	16A0604	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify size of through bus in HCP distribution (X). 2) Show circuit breaker size and type feeding ATS. 3) Show coordination on emergency side from main breaker and panelboard with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/1/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/30/19 Swap dwg #ME52-Sheet 1 of 1-Revision 2</p>				
54038	16A0606	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54069	16A0608	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
54034	16A0609	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54070	16A0612	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 3/27/19 Swap dwg G rev 4				
54071	16A0615	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 6/1/18 - swap dwg 16324-1 Rev 2				
54313	16A0616	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Equipment grounding conductor off 2500 fusing undersized. 2) Coordination study performed signed and sealed by a P.E. not provided with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/12/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/29/2020 Amended Dwgs# 1,2,3 & 4 Rev2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/15/2021 Amended plans# 1, 2, 3 & 4 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/20/2021 Amended plans# 1, 2, 3 & 4 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0617	Requesting permission to leave as installed 2 hour Vitalink cable as a wiring method for fire pump wiring system.	Administrative Closure	\$0.00
4/6/17 This item void as per swapped drawing 1 , Revision 1 for Cal. #51079 showing fire rated vitalink MC cable.				
	16A0618	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
Submitted drawings are not in Advisory Board format, 2 sets of drawings are required.				
	16A0620	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Switchboards misidentified on room layout. 2) 1 Line does not match physical MSA. 3) Fire pump panels not labeled on room layout. 4) Substations don't match physicals. 5) 36th floor substation door to open outwards. 6) Substation panels not identified as per physicals. 7) Fuse types not shown on 1 Line WT-1, WT-2. 8) C-3 bus on load side of transformer undersized. 9) Feeder to 36-2 substation overfused. 10) Fire alarm service equipment neutral to be bonded and grounded. 11) Note types of ATS being installed after 2nd fuses. 12) Feeder to 36-5 substation overfused. 13) Bus in 36-5 and C-4 substations undersized. 14) Is generator separately derived? Stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Review Stopped.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54309	16A0621	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that service switches 1,2 and3 comply with 408.60(F). 2) Provide series rating chart 2000, 600 amp service switches to 2nd fusing. 3) Provide short circuit study and coordination. 1/10/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54040	16A0622	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54041	16A0623	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54072	16A0624	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 11/22/17 - swap dwg 1,2,3 rev 4				
54042	16A0625	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54073	16A0626	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 8/30/17 - swap dwg 1 & 2 rev 3 8/29/18 Swap dwg 1&2 rev 3				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54044	16A0629	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54043	16A0630	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/11/2017 - swap revision 1 dwg				
54045	16A0631	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/29/16 Swapped drawing 1-Revision 1.				
54074	16A0632	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
With the stipulation that signage is provided on the rear of the switchboards "Do not remove covers" Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 6/23/17 - comply with 110.26(A)(1) - or verify if 45KVA Xfmr is ceiling mounted, provide the height if so - dwg-12539-1 7/13/17 - swap dwg ACS-D=12539-1,2,&3 rev 4, dwg# ACS-D-12542-1,2,3 & 4 Rev 4				
54129	16A0633	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Block rear of switchboards. 2) MDB-RES Section 3 does not match room layout and 1Line. 3) MDB1 switchboard overfused. 4) Remove 2nd switch feeding fire alarm transformer. 5) Fire pump emergency feeder not fire rated. 6) Verify amount of sets of conductors feeling C-M1-M. 7) Roll up generator to comply with 700.6(G). 8) Feeders to distribution 1-DB overfused. 9/20/16 This submittal had incorrect submittal number 16A0663 which belongs to another submitter. 9/30/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 4/8/19 - 1. Confirm 5' clearance to SS#4. 5/6/2021 Amended Plans# A Rev.7, B Rev.7, C Rev.3, D Rev.8 and E Rev.7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/1/2021 Amended Plans# A Rev 7, B Rev 8, C Rev 3, D Rev 8 and E Rev 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/18/2021 Amended plans# A Rev 8, B Rev 9, C Rev 3, D Rev 8 and E Rev 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54132	16A0634	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service switch #A3, line and load side bus reversed. 2) Verify neutral conductors for fire pump emergency feeders. 3) Feeders to PNL EMDB1 not shown and size of PNL not shown with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an ALT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 10/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/11/2017 - swap dwgs 1,2,3,& 4 rev 2 7/20/17 - SWAP dwg # ACS-D-12536-1,2,3 &4 Rev 3(note-Dwg # 3 is the only dwg that had changes, the rest of the dwgs just changed the revision #)</p>				
54075	16A0635	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 4/26/18 - swap dwg 1 rev 1, dwg 2 rev 1</p>				
54076	16A0636	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0637	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) 1 set of 350 KCM copper overfused. 2) Genset cut sheets showing listing not provided with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 				
54228	16A0638	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Room need to be mechanically ventilated. 2) Verify 225 KVA transformer secondary feeder size with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/29/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/5/2017 - swap dwg A rev 4</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54077	16A0640	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/16/18 1) Con feeds "ATS-Elev"-emergency side-is undersized. 2) F.A. tap to be ahead of NDL 1/3/19 - Swag drawings 1&2 revision 2.. 7/14/2021 Amended plan# 1 & 2 Rev 4 . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
54078	16A0643	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 2/23/2017- swap dwg # 3 of 3 Rev - 1. With stipulation 480V service board has tamper resistance screws, with signage do not open</p>				
54046	16A0644	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
54127	16A0645	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Section bus for S.S. 1,2 and 3 undersized. 2) Section bus for S.S. 4,5 and 6 undersized. 3) Vertical bus for S.S. 5 and 6 undersized. 9/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/27/18 1) 300KVA transformer secondary OCPD is overfused. Table 450.3(B) and note (L). 10/29/18 Swap Dwg #1-Revision 4.</p>				

ADVISORY BOARD CALENDAR

August 17, 2016

Approval #	Submission #	Type of Request	Status	Fee
54130	16A0646	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Bus on load side of 1500 KVA transformers undersized. 10/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
54048	16A0647	Requesting permission to utilize Vitalink 2 hour fire rated cable for fire alarm wiring due to structural, mechanical plumbing and electrical systems making it almost impossible to run conduit for the fire alarm system. The Vitalink will be installed in several location SC1, SC2, SC3, 1 mezzanine and 9th floor.	Approved	\$0.00
With the stipulation that fire conductor to be installed as per manufacturers installation instruction. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0648	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Section bus in TSQ-DP-1 undersized. 2) Verify that fire rated RHW-2 can be run in conduit instead of EMT for 40 HP fire pump. 3) Ground generator frame, is generator a separately derived system. 4) Add note under generator whether 3 or 4 pole ATS' will be installed. 5) Provide full size generator floor plan, plan submitted is confusing. 6) Verify address of job, doesn't match key plan. 7) Coordination study performed, signed and sealed by a P.E. not provided. 8) 1 Line drawing should have been made into 2 sheets confusing to read with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				