

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48418CO	08A0016CO	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	FedEX Distribution Center 670 East 132nd Street Bronx NY	Approved	\$0.00
Carry over from January 16, 2008 meeting. 1) Provide secondary protection for 1500 KVA step-down transformer. 2) Submit manufacturer's cuts (SQD) for switchboard. 3) Verify grounding for transformer and switchboard MSB. Job finalized 11/10/09.						
49351CO	09A0138CO	Litespeed Electric, Inc. 135 West 29th Street, Suite 301 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Bloomberg Data Center 340 West Street New York NY	Hold	\$0.00
Carry over from March 18, 2009 meeting. 1) Remove generator neutral bonds and bond and ground neutral in switchboard. 2) Does EPS supply power to emergency loads, If yes #1 doesn't apply. 3) Ground fault protection required in switchboard breakers for non life safety. 4) Special permission need for lack of selectivity for UPS only.						
49449CO2	09A0193CO2	Belmont Electrical Inc. 244 Fifth Avenue, Suite 2352 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1150 Park Avenue New York NY	Approved	\$0.00
Carry from July 15, 2009 meeting.						
49460CO	09a0204CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	NYCollege of Technology 300 Jay Street Brooklyn NY	Approved	\$0.00
Carry over from May 20, 2009 meeting.						
49578CO	09A0293CO	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	6 Harrison Street New York NY	Hold	\$0.00
Carry over from July 15, 2009 meeting. 1) Relocate equipment in service room to comply with Advisory Board rules or add additional door on the other side of the room. 2) Service entrance conductors from end box to CT cabinet to total frame ratings of all service switches where 500 MCM conductors will be allowed to be rated at 400 amps. 3) Fuses in MDP #2 do not coordinate with fuses in new service switch. 4) Show which way the front of service switch #6 and MDP #2 are facing. See special permission Cal. #49670.						

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49623	09A0326	A.C.Morgan Electric 3601 Riverdale Avenue Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	355 West 52nd Street New York NY	Hold	\$650.00
Inadequate access to service equipment. No 2nd means of egress. Provide alt. Layout.						
49624	09A0327	Striano Electric Co., Inc. 246 Park Avenue Garden City Park NY 11040	Requested approval for the electric service equipment proposed to be installed	515 Madison Avenue New York NY	Approved	\$650.00
49625	09A0328	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	26 Broadway New York NY	Approved	\$650.00
Service entrance conductors feeding 1200 amp switch are undersized. Job finalized 8/19/09.						
49626	09A0329	Reliable Electrical Contractors 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	1595 Lexington Avenue New York NY	Approved	\$650.00
Provide code clearance in front of ss#6 (relocate). Job finalized 10/14/09.						
49627	09A0330	Jacoby Electric Corp. 10-40 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	RCN Communications 111 8th Avenue New York NY	Approved	\$650.00
1) Submit request for special permission for lack of coordination 1600A A4BQ & 800AF/800AT GE breaker. 2) Indicate available short circuit current at "MDS-B". Job finalized 9/16/09.						

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49628	09A0331	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	PS 276 55 Battery Place New York NY	Ok, but	\$650.00
1) Fire pump service switch undersized. 2) Fire pump service entrance conductors not shown. 3) Feeder to panel "EDBR" is overfused.						
49629	09A0332	Smith Electrical Contracting Inc. 224-17 Merrick Blvd. Queens NY 11413	Requested approval for the electric service equipment proposed to be installed	1177 Flushing Avenue Brooklyn NY	Approved	\$650.00
49630	09A0333	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 89K 265 Warick Street Brooklyn NY	Approved	\$650.00
49631	09A0334	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	540 West 28th Street New York NY	Approved	\$650.00
1) Service entrance Conductors to 1200 amp "HDP" are undersized. 2) Service entrance bus undersized. 3) Provide end lugs, strap, neutral disconnect link in 'HDP'. 4) Maximize front clearance ss#3. Job finalized 2/16/10.						
49632	09A0335	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1 Pierrepont Plaza Brooklyn NY	Ok, but	\$650.00
1) Confirm Con Ed available short circuit current (90KA?) 2) Indicate available short circuit current at new UPS switchboard. 3) Bus sizes in new UPS switchboard? 4) Indicate available short circuit on 5th floor at new bus plug. Provide plug in breaker with appropriate rating. 5) Indicate on drawing special permission for lack of coordination between 4000A fuse and new UPS switchboard. Note that no building loads are served by 4000A service switch.						

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49633	09A0336	Rigid Electric Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	New York University 12-14-16 Waverly Place New York NY	Hold	\$650.00
1) Show where feeders originate from(4160). 2) Provide supplemental ground. 3) Feeder sizes on load side of 3000A ATS not shown. 4) Provide tap length of feeder to 300 amp breaker. 5) Service bus undersized. 6) Verify that MI cable is 1800 series and is sized at 600 MCM. 7) Verify that cable FA is MI. 8) FACO not bonded and grounded. 9) Short circuit calculations not provided. 10) On coordination curves show actual breaker settings . 11) Provide 5ft front clearance for f.p. switch. 12) Show doors on closet for life safety ATS's. 13) Provide proper side clearance for 3000A ATS.						
49634	09A0337	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Beth Israel Medical Center 1st Avenue at 16th Street New York NY	Approved	\$650.00
Correct bus size on drawing ATL-D-905132-A, "EMD-5" 4000A CB cubicle. Job finalized 9/18/09.						
49635	09A0338	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1460 Broadway New York NY	Approved	\$650.00
Verify if tap originates from 1200 or 1600 amp service switch. Job finalized 8/28/09.						
49636	09A0339	Jeco Electrical Service Corp. 1162 Intervale Avenue Bronx NY 10459	Requested approval for the electric service equipment proposed to be installed	440 Watkins Street Brooklyn NY	Approved	\$650.00
1) Service entrance conductors undersized feeding 1200, 2000 and 1600 amp service switches. 2) Neutrals in disconnect switches bonded after service switch. Job finalized 9/18/09.						
49637	09A0340	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	241 Keap Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49638	09A0341	Jeco Electrical Service Corp. 1162 Intervale Avenue Bronx NY 10459	Requested approval for the electric service equipment proposed to be installed	345 Thatford Avenue Brooklyn NY	Approved	\$650.00
1) Service entrance conductors feeding 1200, 1600 and 2000 amp service switches and undersized. 2) Tap conductors to 3 new 100 amp disconnect switches are undersized. 3) Neutrals bonded after service switch in 800 and 1200 amp disconnect switches. 4) 1500 amp fuse is to large feeding 1000 and 600 amp disconnect switch. Job finalized 9/18/09.						
49639	09A0342	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	453 West 37th Street New York NY	Approved	\$650.00
49640	09A0343	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Monroe High School 1300 Boyton Avenue Bronx NY	Approved	\$650.00
49641	09A0344	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NYU School of Law 133 MacDougal Street New York NY	Approved	\$650.00
1) Service entrance conductors undersized. 2) Clarify service end box location. Job finalized 11/9/09.						
49642	09A0345	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	50 Broad Street (Basement) New York NY	Approved	\$650.00
1) Service switch identified as safety switch. 2) Show that service entrance conductors are not routed with fused feeders. 3) Service switch not bonded and grounded. 4) Verify that booster pump is not located below street level, legend does not match drawing. 5) If motor is for fire pump, the service switch is undersized and the service entrance conductors shall originate from Con-ED box. Job finalized 11/9/09.						

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49644	09A0347	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bronx Science High School 75 West 205th Street Bronx NY	Approved	\$650.00
49645	09A0348	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	MILCO 5202 Third Avenue Brooklyn NY	Approved	\$650.00
49646	09A0349	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	1 West 125th Street New York NY	Approved	\$650.00
Remove neutral bonds after service switch. Job finalized 9/18/09.						
49647	09A0350	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	1 Union Square South New York NY	Approved	\$650.00
1) Show neutral disconnect link in existing board. 2) Equipment grounding conductors in 4000 amp feeders are undersized. 3) Bus to 2000 amp disconnect switch is undersized. Job finalized 9/22/09.						
49648	09A0351	Ideal Electric & HVAC Co., Inc. 235 India Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	1060 5th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49649	09A0352	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Ryan Center 801 Amsterdam Avenue New York NY	Approved	\$650.00
49650	09A0353	Stanco Systems Electrical Contracting Inc. 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	HS for Arts & Design 105-25 Horace Harding Expressway Queens NY	Approved	\$650.00
49651	09A0354	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Century 21 Rego Park Rego Park NY	Approved	\$650.00
49652	09A0355	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 971K Early Childhood Ctr 6214 Fourth Avenue Brooklyn NY	Approved	\$650.00
49653	09A0356	Accu-Glo Electric of New York, Inc. 38-26 30th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	16 West 22nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49654	09A0357	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	1185 Avenue of the Americas New York NY	Approved	\$650.00
49655	09A0358	A. Giovannetti Electric 110 Wall Street, #0108, 11th Floor New York NY 10005	Requested approval for the electric service equipment proposed to be installed	Metropolitan Opera House 80 Columbus Avenue New York NY	Approved	\$650.00
49656	09A0359	Laredo Electric, Inc. 2477 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	270 Park Avenue South New York NY	Approved	\$650.00
49657	09A0360	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	132 Nassau Street New York NY	Approved	\$650.00
49658	09A0361	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	440 West 42nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49659	09A0362	OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	390 Wythe Avenue Brooklyn NY	Approved	\$650.00
49660	09A0363	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1140 Broadway New York NY	Approved	\$650.00
49661	09A0364	Centrum Electric Corporation 12 Lombardy Street New York NY 11222	Requested approval for the electric service equipment proposed to be installed	402 Avenue U. Brooklyn NY	Hold	\$650.00
1) FACO not bonded. 2) Fire pump branch circuit undersized. 3) Show selectivity between 1000 amp main circuit breaker and branch circuit. 4) Supplemental ground not shown. 5) Show grounding in 1000 amp combo panel. 6) Show that combo panel is suitable for use as service switch. 7) Show selectivity at meter bank breakers, calculations.						
49662	09A0365	Jolt Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	Oscar Blandi Salon 545 Madison Avenue, 2nd Floor New York NY	Approved	\$650.00
49663	09A0366	Associated Electrical Contractors of NY Cor 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	370 Lexington Avenue New York NY	Approved	\$650.00
1) Fire pump service switch undersized. 2) Fire pump branch circuit not fire rated. Job finalized 9/2/09.						

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49664		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to temporarily disconnect ground fault protection for six months in a 5000 amp service switch until the second level switchboard is replaced that will contain ground fault protection on each switch over 1000 amps.	1285 Avenue of the Americas New York NY	Approved	\$0.00
With the stipulation that upon completion and inspection of the replacement of switchboard #2 the ground fault protection in the 500 amp service switch shall be in operation and the disconnection of the ground fault protection shall not last longer than six months.						
49665		Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requesting permission to leave one door for the service room due to a Con ED steam room on the other side of the wall.	444 Madison Avenue New Yor	Approved	\$0.00
With the stipulation that a double door is installed.						
49666		Atlas Electric Contractos, Inc. 87-12 113th Street Richmond Hill NY 11418	Requesting permission to leave as installed on a commercial building service equipment mounted on the outside of the building.	183 Tagee Street Staten Island NY	Approved	\$350.00
49667		Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requesting permission to leave as installed 1-5, 10-3 and 1-2 family buildings built without separate PLP services and panels due to the architect not requiring them for a project funded by HPD.	rion Street, Sumpter Street, Bradford Brooklyn NY	Denied	\$350.00
49668		Foster Electrical Service Inc. 1325 Foster Avenue Brooklyn NY 11230	Requesting permission to leave as installed due to a hardship to replace, AC cable that does not contain an equipment grounding conductor as a wiring method in a place of assembly.	602 Leonard Street Brooklyn NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49669		Reliant Electrical Contracting Inc. 628 Classon Avenue Brooklyn NY 11238	Requesting permission to leave as installed 22 three family buildings built without separate PLP services and panels where the buildings were designed by HPD for low income housing where having a commercial meter will cause the owner undue financial burden of paying higher electrical bills.	Pacific and Dean Streets Brooklyn NY	Denied	\$350.00
49670		Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requesting permission to utilize the old NYC Electrical Code for fusing conductors on 1000 KVA work that was originally filed by another contractor in 2002 and violated in 2003 and to leave clearances and one door as installed.	6 Harrison Street New York NY	Approved	\$0.00
With the stipulation that 500 MCM service entrance conductors will be allowed to be rated at 400 amps for a 1000 KVA service and must be equal to the total of all the frame ratings of the service switches, and clearances of equipment must be as Advisory Board rules. See notes on drawing Cal. #49578						
49671		Richard DeCastro & Sons Electl Corporatio 43-01 162nd Street Flushing NY 11358	Requesting permission not to submit full Advisory Board drawings for the addition of a 400 amp disconnect switch fused at 250 amps fed from an existing 5000 amp service switch fused at 2000 amps that will power a rectifier as part of Con Edison DC elimination program	589 8th Avenue New York NY	Approved	\$0.00
49672		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requesting permission due to a hardship of running a long distance of raceway, to tap emergency power for a FACO from an existing automatic transfer switch instead of the unfused bus of the generator switchgear	Columbia University 3010 Broadway New York NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

August 19, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49673		Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requesting permission to install a 2000 amp service switch for a fire pump that has 343 full load amps, see drawing Cal. #49576.	30 Rockefeller Plaza, 55th Fl. New York NY	Approved	\$0.00
49674		Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requesting permission to waive coordination between 2000 and A4BQ fuses and 2000 amp GE SH power break II circuit breakers.	Beth Israel Petrie Emerg. Dept. New York NY	Approved	\$0.00
49675	09A0367	Teknion, LLC 350 Fellowship Road Mount Laurel NY 08054	Requested approval for use in New York City of your Teknion Architectural Office Furniture System.		Approved	\$200.00
With the stipulations						
49676	09A0368	Extron Electronics 1230 S. Lewis Street Anaheim CA 92805	Requested approval for use in New York City of your Power Module for use in office furniture. Model/Series: OEM PRO INTERSECTION 200 & 400 PWR and <input type="checkbox"/> 200 & 400 FLX		Approved	\$200.00
With the stipulation that flexible metal conduit is used as a wiring method instead of liquidtight flexible metal conduit.						