

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46352CO	05A0235CO	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Walton High School 2780 Reservoir Avenue Bronx NY	Approved	\$0.00
Carry over from May 25, 2005 meeting.						
46359CO	05A0177CO	Stat Electric Inc. 118-24 Queens Blvd., Suite311 Forest Hills NY 11375	Requested approval for the electric service equipment proposed to be installed	Dunkin Donuts Store 476 Second Avenue New York NY	Hold	\$0.00
Carry over from May 25, 2005 meeting. 1) Provide Con-Ed short circuit. 2) Provide series ratings of circuit breakers on calculations to meet Con-Ed AIC.						
46430CO	05A0290CO	Up Town Electric, Inc. 5-28 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2900 Verterans Parkway West Staten Island NY	Approved	\$0.00
Carry over from June 15, 2005 meeting.						
46482CO2	05A0314CO2	JB Electric Corp. 3702 Rombouts Avenue Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Verizon 1095 Sixth Avenue New York NY	Approved	\$0.00
Carry over July 20, 2005 meeting. Run service conduits through slab. Provide revised drawings. Job finalized 10/18/05.						
46549CO	05A0364CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Newtown Creek W.P.C.P. 315 Greenpoint Avenue Brooklyn NY	Ok, but	\$0.00
Carry over from August 17, 2005 meeting. Provide SC and coordination study.						

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46573CO	05A0424CO	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Restaurant Depot 4340 57th Avenue Maspeth NY	Approved	\$0.00
Carry over from August 17, 2005 meeting.						
46602CO	05A0402CO	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	30 Rockefeller Plaza New York NY	Approved	\$0.00
Carry over from August 17, 2005 meeting. Verify grounded at generator. Job finalized on 10/17/05						
46611CO	05A0422CO	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	155 Canal Street New York NY	Approved	\$0.00
Carry over from August 17, 2005 meeting.						
46625	05A0468	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	100 Jay Street Brooklyn NY	Approved	\$650.00
Time Warner panel to be fed from non-servie switch comply with 230.82. Job finalized 10/18/05.						
46626	05A0430	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Lehman Brothers Chiller 85 10th Avenue-7th Floor & Roof New York NY	Hold	\$650.00
1) Provide Advisory Board format drawings from Asco. 2) Provide floor plan with dimensioned code clearances shown.						

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46627	05A0437	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	New York Stock Exchange 11 Wall Street New York NY	Approved	\$650.00
46628	05A0438	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Goldman Sachs 77 Water Street New York NY	Approved	\$650.00
46629	05A0439	Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Cornell University 515 East 71st Street New York NY	Approved	\$650.00
46630	05A0440	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Brooklyn Museum of Art 200 Eastern Parkway Brooklyn NY	Approved	\$650.00
46631	05A0441	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Metropolitan Museum of Art 799 Fort Washington Avenue New York NY	Approved	\$650.00
Provide signage indicating multiple service rooms. Job finalized 10/24/05.						

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46632	05A0442	Platinum Electrical Service, Inc. 588 Broadway, Suite 203 New York NY 10012	Requested approval for the electric service equipment proposed to be installed	Morton Square 600 Washington Street New York NY	Approved	\$650.00
46633	05A0435	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	120 West 44th Street New York NY	Approved	\$650.00
Justify short circuit rating of circuit breakers panels. Provide series rating. Job finalized 7/19/07.						
46634	05A0433	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	2 Gold Street New York NY	Hold	\$650.00
1) Provide fuse types. 2) Provide details of retail trough. 3) Provide bus sizing per Article 408 for service switchboard.						
46635	05A0432	GMA Electrical Corp. 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Excellence Charter School 225 Patchen Avenue Brooklyn NY	Approved	\$650.00
46636	05A0467	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	CBS, Inc. t.-A Level Room A-306, Lower & M New York NY	Approved	\$650.00
1) Indicate 2000A tap is 25 ft maximum. 2) Show coordination of 3000/2000A fuse or reduce 2000A to 1600A. Job finalized 10/24/05.						

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46637	05A0464	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Nextel NY-2473 79-11 41st Avenue Elmhurst NY	Approved	\$650.00
46638	05A0466	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	NYU Medical Center, Chiller 550 1st Avenue New York NY	Approved	\$650.00
46639	05A0465	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	715 Lexington Avenue New York NY	Approved	\$650.00
46640	05A0463	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Nextel NY-2347 55-30 46th Street Maspeth NY	Approved	\$650.00
46641	05A0462	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Nextel NY-3809 100 West Kingsbridge Road Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46642	05A0460	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	225 Fifth Avenue New York NY	Approved	\$650.00
1) Increase bus size for 3000A and 4000A switch connections comply with Article 408. 2) In main service switchboard 'B' change 3000A fuse to 2500A for coordination. 3) On service 'C' wire trough not acceptable for penetrating fire rated wall. Provide concrete enclosed conduit. Jpb finalized 10/18/05.						
46643	05A0461	AMC Electrical Services, Inc. 3819 Fort Hamilton Parkway Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	9 East 40th Street New York NY	Approved	\$650.00
46644	05A0481	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	25 West 51st Street New York NY	Approved	\$650.00
46645	05A0478	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Greenbriar Apartments 85-15 Main Street Queens NY	Approved	\$650.00
46646	05A0479	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Mersereau Pumping Station Mersereau Avenue Staten Island NY	Hold	\$650.00
Provide siemens drawings "as built" for equipment.						

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46647	05A0480	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	155 West 21st Street New York NY	Approved	\$650.00
1) Provide details of "comm. trough". 2) SS #5 feeder undersized. 3) Comply with fuse coordination on SS#5 and "TDP". 4) Show proper connection of jockey pump. 5) Line side tap for fire pump does not require concrete encasement. Job finalized 11/28/05.						
46648	05A0476	Mari Electric Contractors Inc. 635 Richmond Road Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	557 Atlantic Avenue Brooklyn NY	Approved	\$650.00
46649	05A0475	A.I. Klein Electric, Inc. 511 West Twentieth St., Suite 2N New York NY 10011	Requested approval for the electric service equipment proposed to be installed	270 Lafayette Street New York NY	Approved	\$650.00
46650	05A0473	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Jacobi Med. Ctr. Nurses Resid. 1400 Pelham Parkway South Bronx NY	Approved	\$650.00
1) New taps to be within 10ft. 2) New service switches require neutral bond. Job finalized 10/25/05.						
46651	05A0469	Zwicker Electric Co., Inc. 380 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Time Warner 10 Columbus Circle New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46652	05A0470	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	1 New York Plaza New York NY	Approved	\$650.00
46653	05A0459	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Peter Cooper Village/Stuyvesant 400 East 20th Street New York NY	Approved	\$650.00
1) Increase through bus 2nd & 3rd section building A. 2) Indicate bus size building B. Job finalized 10/18/05.						
46654	05A0458	ECS Electrical Contracting Services, Inc. 351 Kent Avenue Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	The Savoy 200 East 61st Street New York NY	Approved	\$650.00
46655	05A0457	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Sprint 016 507 Osborn Street Brooklyn NY	Denied	\$650.00
The 1-4"x1/4" service bus is undersized.						
46656	05A0456	Solar Electric System, Inc. 452 West 55th Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Ethical Culture Fieldston School 3901 Fieldston Road Bronx NY	Approved	\$650.00
1) Provide barriers. 2) Change 100A service switches to 30 amps for correct fusing. Job finalized 10/18/05.						

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46657	05A0471	Robert Garcia Electrical Contracting Corp. 500 Trinity Avenue, Suite 1-B Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	15 West 45th Street New York NY	Approved	\$650.00
46658	05A0472	Big Shot Electric Corp. 710 East 135th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Apartment Building 20 East 68th Street New York NY	Hold	\$650.00
Service is not adequate to support load of entire building.						
46659	05A0474	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	Woodhull Med and Mental Ctr. 760 Broadway Brooklyn NY	Approved	\$650.00
46660	05A0477	JMJ Electric Corp. 46-33 5th Street Long Island City NY 10001	Requested approval for the electric service equipment proposed to be installed	1920 Amsterdam Avenue New York NY	Approved	\$650.00
46661	05A0482	SDM Metro 220 Maple Avenue, Suite 203 Rockville Centre NY 11570	Requested approval for the electric service equipment proposed to be installed	60 East 55th Street New York NY	Approved	#Error

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46662	05A0436	Judd Electric Inc. 327 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	584 Broadway New York NY	Approved	\$650.00
46663	05A0484	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	975 Park Avenue New York NY	Approved	\$650.00
46664	05A0443	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	125 West 31st Street New York NY	Approved	\$650.00
46665	05A0444	Associated Electrical Contrs of NY, Inc. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	184-10 Jamaica Avenue West Hollis NY	Hold	\$650.00
Tap conductors too small.						
46666	05A0447	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	Montefiore Med. Ctr.-Parking 111 East 210th Street Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46667	05A0448	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weill Cornell Med. College 1305 York Avenue New York NY	Approved	\$650.00
Provide statement that short circuit between generator and distribution equipment. Job finalized 10/24/05.						
46668	05A0446	Angel Electrical Construction Inc. 101 Luquer Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	225 Park Avenue South New York NY	Approved	\$650.00
New trough cannot run through elevator room. Job finalized 10/18/05.						
46669	05A0445	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	80 Broad Street New York NY	Hold	\$650.00
Change one time fuses.						
46670	05A0450	Concord Electrical Contractors Inc. 107 Luquer Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	1775 Broadway New York NY	Approved	\$650.00
46671	05A0451	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	345 Hudson Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46672	05A0452	Queensboro Electrical Contracting Corp. 217-22 Northern Blvd. Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	Morimoto Restaurant 88 Tenth Avenue New York NY	Approved	\$650.00
46673	05A0453	Venus Electrical Contractors, Inc. 34-14 Crescent Street Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	P.S. 226M 345 East 15th Street New York NY	Approved	\$650.00
Show selectivity or provide letter. Job finalized 1/7/08.						
46674	05A0454	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	230 West 38th Street New York NY	Approved	\$650.00
46675	05A0455	Queens Electrical Contractors, Inc. 32-17 Broadway Astoria NY	Requested approval for the electric service equipment proposed to be installed) Bergen St., aka 475 St. Marks Ave Brooklyn NY	Approved	\$650.00
46676	05A0449	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Rockefeller Center 620 5th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46677	05A0434	United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	217 Grand Street New York NY	Approved	\$650.00
46678	05A0431	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	16 West 46th Street New York NY	Hold	\$650.00
Show the 100 amp service switch on 1 Line						
46679	-	A to Z Electrical Maint. & Service Corp. 307 Seventh Avenue, Suite 403 New York NY	Requesting permission to utilize an existing conduit inside of a elevator shaft that will provide power to a new elevator motor.	Commerce Bank 2 Wall Street New York NY	Approved	\$0.00
46680	---	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 non metallic conduit standpipe on a building located in Far Rockaway, Queens	nd 561 Bch 43rd St. and 338 Bch 69t Queens NY	Approved	\$0.00
46681	----	Quantum Electric Corporation 38-24 34th Street Long Island City NY 11106	Requesting permission not to file Advisory Board drawings on a job where a existing 5 KV feeder will be relocated.	Tropicana 7-02 154th Street Whitestone NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46682	-----	New Energy Options, Inc. 410 Great Road, B-6 Littleton MA 01460	Requesting permission not to apply Section 690.64(B) (2) to the existing 400 amp panel that houses the two 200 amp fused disconnect switches where one of the switches will backfeed the service from a new photovoltaic system.		Approved	\$0.00
with the stipulation that is provided as per Article 690.17.						
46683	-----	Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to tap power for a fire alarm control panel on the line side of the tenants distribution panel, the FACP will be provided with battery back up or not to connect the FACP to the building fire alarm system and use a control station monitoring company.	JP Morgan Chase 145th Street and Edgecombe Avenue New York NY	Approved	\$0.00
with the stipulation that this installation is subject to Fire Department approval.						
46684	-----	JB Electric Corp. 3702 Rombouts Avenue Bronx NY 10466	Requesting permission not to provide concrete encasement for service entrance conductors that will run from the Con-Ed box in a service room to another service room directly above, both rooms are 2 hour fire rated.	Verizon Building 1095 Avenue of the Americas New York NY	Approved	\$0.00
46685	-----	DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to run two existing sets of #6 wire in parallel due to the hardship of running a new conduits.	Sheepshead Bay H.S. 3000 Avenue X Brooklyn NY	Denied	\$0.00
The smallest conductor that can be run in parallel is 1/0 AWG.						
46686	-----	Krypton Electric 32 E. 31st Street, Suite 810 New York NY 10016	Requesting permission to install 1/2" EMT that will contain Class 2 low voltage wiring for a thermostat inside of active dumbwaiter shaft, in a landmark building.	34-13 80th Street Queens NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

September 14, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46687	05A0483	Danfoss Inc. 7880 Tranmere Drive Toronto ON L5S1L	Requested approval for use in New York City of your Danfoss LX Electrical Radiant Floor Heating Mats complete with Controller (thermostat). Model/Series Number: LX Series 0881.		Hold	\$200.00
<p>1) Provide correlation between the certification file and the catalog numbers as submitted. 2) The thermostat package indicates a UL listing but there is no marking on the product and the listing file did not accompany the submittal.</p>						