

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 101-92-E Vol. 9

Manufacturer:	Globe Fire Sprinkler Corp. 4077 Airpark Drive Standish, MI 48658	
Trade Name(s):	The Inch	
Product:	Model GL5606 and GL5653 Adjustable Concealed Pendent Sprinkler	
Pertinent Code Section(s):	Subchapter 17 and Reference Standard RS17	
Prescribed Test(s):	UL 199	
Laboratory:	Underwriters Laboratories Inc.	
Test Report(s):	File EX1085 Projects 98NR11745, 03NJ15943, 05NJ10800 & 07CA09747 issued April 7, 2000 and revised August 29, 2007	

Description: These sprinklers are intended for installation in fire sprinkler systems where a decorative finish is desired. Once the sprinkler is installed the coverplate of the sprinkler is the only visible part exposed. The sprinkler consists of a frame, a deflector assembly and a glass bulb. In addition, a support shell is attached to the frame and a soldered coverplate assembly is attached to the support shell. When a fire occurs, heat builds up causing the solder joints to melt and the cover falls allowing the deflector to drop into position. As heat continues to build, the glass bulb operates allowing water to flow and be distributed on the fire.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections (letter dated December 17, 2007, F.P. Index #0710005A).

Terms and Conditions: The above units are accepted on condition that:

- 1. All uses and installation comply with the applicable New York City codes, rules, regulations and testing requirements in particular with the requirements of Subchapter 17 and RS 17-2, RS 17-2A and RS 17-2B of the Administrative Code, and the NFPA Code 13, 13R and 13D.
- 2. Underwriter Laboratories Inc.'s listing requirements and limitations shall be adhered to.
- 3. Manufacturer's installation, maintenance procedures and limitations shall be complied with.

Final Acceptance	February	21,0	ZOOP.
Examined by	Amald	A	H
Ĺ		$^{\prime}$) .