

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45792CO	04A0319CO	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	820 West End Avenue New York NY	Approved	\$0.00
Carry over from July 21, 2004 meeting.						
45840CO	04A0347CO	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	100-17 23rd Avenue Queens NY	Approved	\$0.00
Carry over from August 18, 2004 meeting.						
45895CO	04A0395CO	Sage Electrical Contracting, Inc. 651 Willowbrook Rd., Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Hippodrome 1120 6th Avenue New York NY	Approved	\$0.00
Carry over from September 15, 2004 meeting.						
45896CO	04A0394CO	Dal Electrical Corp. 5910 11th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	580 5th Avenue New York NY	Approved	\$0.00
Carry over from September 15, 2004 meeting.						
45904CO	04A0414CO	Pabst Electric Company Inc. 45-48 51st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	City Center HVAC Upgrade 130 West 56th Street New York NY	Approved	\$0.00
Carry over from September 15, 2004 meeting						

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45932	04A0424	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Times 1 New York Times Plaza Flushing NY	Approved	\$650.00
1) Submit short circuit and coordination study. 2) Bus size too small on paralleling switchgear 1200A should be 1-1/4x5". 3) Bus sizing on Cutler-Hammer modifications? Item finalized November 17, 2004.						
45933	04A0425	M.A.M. Electric Corp. 7025 Third Avenue Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Red Hook Green LLC 269 Conover Street Brooklyn NY	Approved	\$650.00
1) Bus size on load side of 3000A ATS. 2) Generator connecting for stand-by only. No emergency loads. 3) Drawing shows 75KA available. Con Ed letter states 37 KA. Correct drawing.						
45934	04A0426	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 680 Fairview Avenue Brooklyn NY	Denied	\$650.00
1) Life safety ATS not permitted in service room (rule12:01) . 2) Utility and emergency feeds must be direct from F.C.O. 3) Emergency connection must be made ahead of main.						
45935	04A0427	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 355 Forest Avenue Staten Island NY	Denied	\$650.00
1) Life safety ATS not permitted in service room (Rule 12:01). 2) Utility and emergency feed must be direct from F.C.O. 3) Emergency connection must be made ahead of main.						
45936	04A0428	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	900 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45937	04A0429	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	38 East 37th Street New York NY	Approved	\$650.00
45938	04A0430	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens Center Mall 91-23 Queens Blvd. Elmhurst NY	Approved	\$650.00
45939	04A0431	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JP Morgan Chase 4 Metrotech Center Brooklyn NY	Approved	\$650.00
45940	04A0432	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	501 Seventh Avenue New York ny	Approved	\$650.00
45941	04A0433	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Pk Med Eastern Women's Ctr 800 Second Avenue New York NY	Approved	\$650.00
1) 600 amp disconnect switch upside down. 2) Provide supplementary ground.						

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45942	04A0434	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Helena 601 West 57th Street New York NY	Approved	\$650.00
45943	04A0435	Barth-Gross Electric Co., Inc. 110 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
45944	04A0436	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	East 83rd Street - 83rd & York Ave New York NY	Approved	\$650.00
1) Bond neutral on secondary of 500 KVA XFMR only once. 2) Drawing note #7 indicate 1999 code? 11/30/04-Item Finalized.						
45945	04A0437	Axcel Electric Company 636 11th Avenue, 10th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	387-397 Greenwich Street New York NY	Approved	\$650.00
45946	04A0438	MetroYork Electrical, Inc. 23-86 BQE Long Island City NY 11103	Requested approval for the electric service equipment proposed to be installed	2720 Broadway New York NY	Ok, but	\$650.00
Provide contractors name on drawing in title block						

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45947	04A0439	Trince Electric Inc. 330 East 35th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	32 East 76th Street New York NY	Approved	\$650.00
45948	04A0440	Jeminis Electrical Contractors, Inc. 122-11 18th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Waterview Plaza 14-34 110th Street College Point NY	Approved	\$650.00
45949	04A0441	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	29 West 57th Street New York NY	Approved	\$650.00
45950	04A0442	Elmac Electric, Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	3718 Henry Hudson Parkway Bronx NY	Approved	\$650.00
45951	04A0443	Elmac Electric, Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	22-30 Mott Avenue Far Rockway NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45952	04A0444	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	4 Union Square South New York NY	Approved	\$650.00
45953	04A0445	Tectonic Engs & Surveying Consul P.C. 955 Little Britain Road New Windsor NY 12553	Requested approval for the electric service equipment proposed to be installed	Alwyn Court 180 West 58th Street New York NY	Approved	\$650.00
45954	04A0446	Dudley & Assoc. Lic. Electrical Contrs 6 East Clark Place Bronx NY 10456	Requested approval for the electric service equipment proposed to be installed	2116 Adam Clayton Boulevard New York NY	Approved	\$650.00
45955	04A0447	Urban Power and Lighting, Inc. 24-42 49th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	204 West 55th Street New York NY	Approved	\$650.00
45956	04A0448	Manuel Sertzen Inc. 1545 White Plains Road Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	Wingate Inn 35-15 Farrington Street Flushing NY	Approved	#Error

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45957	04A0449	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	240 West 35th Street New York NY	Ok, but	\$650.00
What does rectifier feed?						
45958	04A0450	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	100 West 58th Street New York NY	Approved	\$650.00
45959	04A0451	NJS Electrical Service Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	303 East 60th Street New York NY	Approved	\$650.00
45960	04A0452	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	33-00 Northern Boulevard Queens NY	Approved	\$650.00
45961	--	Fervent Electrical Corp. 111 Third Street Brooklyn NY 11231	Requesting permission to leave as installed service entrance conduits that are bonded with a #1 conductor that loops through all the bonding bushings and is attached to the enclosure in 3 buildings.	301, 315 and 335 Sutter Avenue Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45962	---	PL Engineering Consulting Services 381 Sunrise Highway Lynbrook NY 11563	Requesting permission to use the electrical service room as a plenum to exhaust air from the lobby area.	Long Island University 23 Lafayette Street Brooklyn NY	Denied	\$0.00
Section 300.22B of the National Electrical Code prohibits the service room to be utilized as a duct or plenum for environmental air.						
45963	-----	I.M. Robbins P.C. 15 West 44th Street New York NY 10036	Requesting permission to install the electrical wiring under the "old New York City Electrical Code" in a building where the electrical permit was issued on 6/12/03 and the job was delayed due to 9/11/01.	River Place 2 600 West 42nd Street New York NY	Approved	\$0.00
45964	-----	Sure Electrical Contracting Corp. 3836 Richmond Avenue Staten Island NY 10312	Requesting permission due to no common area to leave as installed service equipment on the outside of a combination commercial, residential building.	7378 Amboy Road Staten NY	Approved	\$0.00
45965	-----	Sage Electrical Contracting 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requesting permission to extend the service bus more than 10 feet to supply new service equipment.	Hippodrome 1120 6th Avenue New York NY	Approved	\$0.00
45966	-----	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission not to group together service equipment installed on a 2 family building due to the building having no common areas.	3555 Richmond Avenue Staten Island NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45967	-----	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requesting permission to install high voltage feeders in PVC conduits underground encased in concrete.	New York Times 1 New York Times Plaza New York NY	Approved	\$0.00
45968	-----	Kiss + Zwigard Architects 120 Duane Street, Suite 402 New York NY 10007	Requesting permission to install a Schaffner FN 6030 three phase de-coupling filter for power line communication that is not listed and approved by OSHA nationally recognized testing laboratory.	Samsung Time Warner Center, 3rd Floor New York NY	Denied	\$0.00
The equipment must be approved by one of OSHA's Nationally Recognized Testing Laboratories.						
45969	----- ---	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to leave as installed wiremold containing receptacles mounted on the gym floor in a face up position.	875 Third Avenue, 29th Floor New York NY	Denied	\$0.00
Provide documentation from the manufacturer that their surface raceway is approved to be installed on the floor with the receptacles in a face up position.						
45970	-----	Transel Elevator Inc. 127 West 24th Street New York NY 10011	Request permission to re-use existing conduits inside a elevator shaftway to supply power to the new elevators.	423 West 55th Street New York NY	Approved	\$0.00
45971	-----	Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 10019	Requesting permission to re-use and extend 60 to 80 year old box cable for power and lighting branch circuits inside a landmark building.	Pierpont Morgan Library 29 East 36th Street New York NY	Denied	\$0.00
With the exception that it is permitted to cutback the existing BX cables that enter the splice boxes or circuit breaker panels if the conductors are not defective. The existing circuits shall not be extended in any manner.						

ADVISORY BOARD CALENDAR

October 13, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45972	-----	Carrier Corporation 516 West 34th Street, 3rd Floor New York NY 10001	Requesting permission to install a Carrier 226 KW microsteam turbine generator that is made up of all UL listed components and not listed as a complete assembly.	7 World Trade Center New York NY	Approved	\$0.00
45973	-----	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requesting permission to tap a bus instead of the end line box to provide power to a new 400 amp service switch.	50 Sutton Place South New York NY	Denied	\$0.00
The service bus is undersized, and the tap is too long.						
45974	04A0453	NESCO/Lighting 40 Hudson Rd. Canton MA 02021	Requested approval for use in New York City of your Lithonia Reloc System. Model/Series Numbers: #CSU-120-F-U-M40 and #CE-120-D-U-05-M10		Approved	\$200.00
45975	04A0454	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Ceiling Level Lighting and Power Distribution System. Model/Series Numbers: USL-E230973.		Approved	\$200.00