

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55889	18A0098CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1) Fix typo for MC cable on dwg #2 of 11. 2) Coordination study one line doesn't match EAB one line and doesn't include the complete new scope of work. 3) Provide sequence of operation for running generator. 4/9/19 1) Updated coordination study to be signed and sealed by P.E. and include short circuit study and recommended settings. 5/6/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/25/2021 1,2,3,4,5,6,7,8,9,10,11 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56159	18A0201	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide 2 hr fire rated cond to F.P.-Sec 695.6(A). 2) Provide available s.c. current at FP controller. 3) Comply with 760.41(A)-F.A. tap to be ahead of N.D.L. 4) Provide conds size feed F.A. system and FP from FP controller. 5) Sectional bus in "MSB-B" Section #1 is undersized. 6) Cut sheet of 'DPL-PG3' doesn't match one line. 7) Verify # of incoming service sets. 1/27/20 Item # 5 not addressed "DPL-PG3" sectional & vertical bus are undersized. 2/3/2020 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/5/2020 Amended Drawings 23663AB20-01-Revision 3, 23663AB20-02-Revision 4, 23663SB40-03-Revision 4, 23663SB60-01-Revision 3, 23663SB60-02-Revision 4, 23663SB60-03-Revision 4, and 23663SB60-04 -Revision 4, Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/9/2020 Amended Plan # AB20-01 Rev- 4, AB20-02 Rev- 5, FP91-01 Rev- 2, SB40-01 Rev- 2, SB40-02 Rev- 4, SB40-03 Rev- 5, SB60-01 Rev- 3, SB60-02 Rev- 4, SB60-03 Rev- 4, SB60-04 Rev- 4, and SB60-05 Rev- 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56140	18A0262	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Tap conds feed Time Warner disconnect switch and 800A switch are undersized-240.21(B). 2) EGC of 'FP-1' and 'FP-2' are undersized-T250.122. 3) Show Time Warner disconnect switch in service room. 4) Provide coordination and short circuit study signed and sealed by P.E. and provide available short circuit current at P.O.E. in one line dwg. 5) Verify if service incoming cable 750 MCM (AL) are Con-ED cables. 6) Service cond for F.A.. Shall not be MC Cables-330.12(3) and 230.43. 12/20/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/23/2021 CD# 10/23/18 Amended plans# AB40-01 Rev 2, FP20-01 Rev 2, SB40-01 Rev 4, SB40-02 Rev 2,PB90-05 Rev 2 and PB90-06 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/8/2022 Amended plans # AB40-01 Rev 2, FP20 -01 Rev 3, SB40-01 Rev 4, SB40-02 Rev 2, PB90-05 of 19, PB90-06 of 19. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/12/2022 Amended plans# AB40-01 Rev 2, ,FP20-01 Rev 2, SB40-01 Rev 4, SB40-02 Rev 2, PB90-05 Rev 2, PB90-06 Rev 1.Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
56160	18A0263	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) FP conductor undersized. 2) Available short circuit current at FP controller. 3) Conductor for feeding TDB-C distribution panel undersized. 4) Conductor for feeding HDB-C distribution panel undersized. 5) Provide panic hardware doors. 6) Verify RDB-C distribution panel indicated in service room. 7) Verify HDB-R distribution panel indirected in service room or roof. 8) Provide sc and coordination study signed and sealed by P.E. 1/2/2020 1) Coordination study doesn't match EAB one line - verify 1200A s.sw & downstream OCPDs. 2) Verify HDB-R in roof and confirm if Nema 3R enclosure is required. 2/13/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work 9/16/2020 Amended Dwgs # AB40-01 of 2 Rev2, AB40-02 of 2 Rev 0, FP20-01 of 1 Rev 1, SB40-01 of 2 Rev 2, SB40-02 of 2 Rev 4, SPB01-01 of 13 Rev 6, SPB01-02 of 13 Rev 4 *new drawing* SPB01-03 of 13 Rev 4 *new drawing*, SPB01-04 of 13 Rev5, SPB01-05 of 13 Rev 5, SPB01-06 of 13 Rev 4, SPB60-01 of 1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 3/24/2021 Amended dwgs# AB40-01 Rev 4, AB40-02 Rev 2, FP20-01 Rev 2, SB40-01 Rev 5, SB40-02 Rev 1, PB01-01 Rev 6, PB01-02 Rev 4, PB01-03 Rev 5, PB01-04 Rev 6, PB01-05 Rev 5 and PB60-01 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0314CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>1) Dwg A: Physicals are changed without being marked. 2) Dwg B: Provide FA and FP ATS ratings on one line diagram. 3) Dwg B: Provide FA transformer rating. 4) Dwg B: Verify conductor between FP transformer and FP controller comply with 695.6(B)(1) and sprinkler pump. 5) Submit electrical service room floor plan and show existing sprinkler pump ss on floor plan and transformer .6)Show available shortest current as fire pump controller. 7) Verify location of transformer for FP and sprinkler. 8) One line and physical does not match. 9) Request coordination study. 10) Request scope of work for plan plans submittal need to know if it is for generator only or if panels are included.</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55913	18A0314CO2	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from 4/18/18 meeting. 1) Dwg A physicals are changed without being marked.. 2) Dwg B Provide FA and FP ATS ratings on one line diagram. 3) Dwg B Provide FA transformer rating. 4) Dwg B Verify conductor between FP transformer and FP controller comply A695.6(B)(1) and sprinkler pump. 5) Submit electrical service room floor plan and show existing sprinkler pump ss on floor plan and transformer. 6) Show available short circuit current at fire pump controller. 7) Verify location of transformer for FP and sprinkler. 8) One line and physical does not match. 9) Request coordination study. 10) Request scope of work for plans submitted need to know if it is for generator only or if panel are included. 2/19/19 1) Remove 2nd bonding in new 400A fire pump and sprinkler pump switches and 100A fire alarm switch-emergency side. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Provide bonding and grounding to FP and sprinkler pump transformers secondary. 3) F.A. transformer primary and secondary OCPDS re overfused-450.3(B). 4) Fire alarm ATS shall be 4 pole. 5) Confirm the appropriate clearance to 100A disconnect switch for fire alarm, 400A disconnect switch for fire pump and sprinkler pump as per Table 110.26(A)(1). 4/2/19 1) Item #2, 3, 4 & 5 from last revision are not addressed. 5/17/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/2/2020 Swap #B-Revision 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/9/2020 Amended dwgs # A Rev 2, B Rev 8 and C Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/30/2020 Amended Plan #B , Rev 9. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55562	18A0370CO2	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over September 26, 2018. 1) Provide cut sheet to "Gen-3" switchboard. 11/15/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/1/19 Swap Dwg #AB-18296-A.5, Dwg #AB-18296-C.5, Dwg #AB-18296-D.4, Dwg #AB-18296-H.4, Dwg #AB-18296-I.5, Dwg #AB-18296-J.4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/20/19 Swap Dwg # AB-18296-A.6, Dwg # AB-18296-C.6, Dwg # AB-18296-I.6 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55882	18A0488CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>10/10/18 1) Provide bonding to F.A. service switch and school switchboard. 2) Provide GFP to SS1A. 3) EGC of "SS2B" still undersized -250.122. 4) Physical doesn't match one line-school switchboard bus bar size. Dwg 8 of 8. 5) Show F.P. trough and F.P. switches in generator. 5/2/19 Job finalized This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/6/2023 Approved plans#1 - 5 & 8 Rev 3, 6 Rev 2, 7 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55595	18A0570	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination. 2) Verify no DL in park custom switchboard. 3) Provide available s.c. current at F.P. controller. 4) Provide GEC to "PVC" fire pump cond. 5) Provide bonding and grounding to service switch #1 and 2.. 12/7/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/15/2021 Amended dwg# 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/13/2021 Amended dwg# A Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55601	18A0571CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from August 15, 2018 1) Provide voltage of 60A fm. Sw in floor plan and verify if it is 3rd level of OCPD-Item #8 previous revision not addressed. 12/5/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55713	18A0603	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show generator grounding. 2) DLO cables are undersized and provide details of DLO cable connections. 3) Main breaker of emergency generator is overfused. 4) Provide coordination between 3000A KRPC fuse and generator MCB with downstream 1600A breaker signed and sealed by P.E. 5) Show ground bus in new transfer feeder switchgear with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/11/19 1) Provided coordination study to be signed and sealed by P.E. 10/29/19 1) Provide signed and sealed short circuit and coordination study. 12/5/19 Swap Dwg # 23960FP20-01 of 1 Rev 1, AB20-01 of 2 Rev 2, AB20-02 of 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55807	18A0624	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide short circuit study calculations and curves, performed, signed and sealed by P.E. 2) Provide Asbestos Abatement document. 3) Verify type and sizes of devices in meterbank A and B and C. 3/7/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/8/2022 Amended plans# A Rev 4, B Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/8/2022 Amended plans# A Rev 6 B Rev 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/10/2023 Amended Plan # A Rev- 8. 2/10/2023 Amended Plan # A Rev- 8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55770	18A0632	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide selective coordination study. 2) Verify location of N.D.L 1A 4000A main service switchboard. 3) Fix typo on size of conductor 600 switch. 4) Fix typo on one line diagram DPH to HDP. 5) Verify type of 600A fuse (TRR or FRN?) 6) One line and phys does not match for fuse type TRR or FRN. 1/28/19 - 1. Provide cond. Size feeds SS#4. 2. Bus bar of HDP panel is undersized. 3. Confirm bus bar size in main switchboard -- section #3 of 6. 4. All tap conds. feed 200A switcher are undersized. 3/14/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/27/2020 Amended dwgs # B Rev 6 and C Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55535	18A0642	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/22/19 Swap dwg AB20-01 of 1-Revision 1.				
	18A0672	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Provide coordination between new 1200A C.B. and upstream fuse signed and sealed by P.E.				
	18A0673	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Provide selective coordination study, signed , sealed and performed by P.E.				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55902	18A0676	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Short circuit study protective device coordination study need to be stamped, signed and performed by P.E. 2) Provide physicals for missing switchboards(DPH-R-1, DP-3-1, DPH-R-2 , MSB-3-1. 3) Show generator room layout plan. 4) Show DP-3-1 located in electric room 305 in room layout. 5) Request cut and support of cable bus and cable bus. 6) Provide cutsheet of DLO ampacity. 7) Provide cutsheets of junction boxes/support. 8) 208VY primary shoves second ground on one neutral. 9) Transformer primary switches must be rated for in rush current. 10) Upgrade all over dutied equipment and for devices for short circuit study. 2/4/19 Provide bonding to fire pump and fire alarm service switches (ss F.P-2"SW, "FP-1 SW", and FA-sw-1)-Dwg 1 of 8. 2) Fire pump cond of "FP-1" is undersized. 3) Comply with 760.41(A)-F.A. tap to be ahead of N.D.L-Dwg 1 of 8. 4) EGC of ss#3, 2 and ss#4 are undersized-T250.122-dwg 1 of 8. 5) Cond feeds future load bank is undersized-dwg 2. 6) Remove bonding from "EMDP-3-1) section #2 and in"EMDP-3-1" and "DP-3-1"-Dwg #2 of 8. 7) Provide sectional bus size in (DP-3-1) Section 2 and in"EMDP-3-1" Section #2, Also bus bar feed 1000A, 1200A, and 800A switches in "EMDOP-3-1" Section #2 is undersized. 8) Confirm compliance with 230.6 for service incoming conds. Fro S.E.B to service room. 9) Verify access Section #4A in main switchboard "MSB-3-1". 3/8/19 1) Provide bonding and grounding to "SSFP-1" service switch. 2) GEC of "SSFP-1", and "SSFP-2" switches are undersized-T250.66. 3) Update EGC of SS#2 that feeds "DP-3-1" in dwg #(2 of 8). 5/10/19 - This drawing is approved.</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/17/2020 Amended Dwgs # 1,2,3,4,5,6,7 & 8 rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/21/2022 Amended Dwgs # 1,2,3,4,5,6,7 & 8 rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/21/2023 Amended plans # 1-8 Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/20/2023 Amended plans # 1-8 Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/27/2023 Amended plans # 1-8 Rev 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 7/25/2023 Amended Plan # 1of 8 Rev-8. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55530	18A0678	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/24/19 - Swap Dwg C Revision 1.</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55583	18A0682	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Verify replacement of service switches are the same amperage rating of existing switches. 11/27/18 Job finalized . Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/1/19 Swap Dwg # 24005AB20-01 of 1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55547	18A0684	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) OCPDs are not coordinating.. 10/31/18 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55589	18A0685	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Special permission shall be requested for Part II of Article 225, and shall address all sections. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55594	18A0688	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provided selective coordination curves do not match one line fuses and not signed and sealed by P.E. 2) One line diagram not matching physical in MSB-T-C. 3) Fix typo in MSB-TA for distribution (MSB-T.B). 4) Physical does not match room layout for MSB-TA. 5) Physical does not match room layout for MSB-TB. 11/27/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0689	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Provide coordination and short circuit study signed and sealed by P.E. - Third means of egress not an exit.				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
	18A0690	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Service conds and tap conds are undersized using free air not a code compliance in this job. 2) Provide coordination between 4000A A4BQ and 2500A A4BQ signed and sealed by P.E. 3) Fire pump tap to be ahead of all service disconnect means-695.4. 1/29/19 1) Item #1 is not addressed.				
55600	18A0693	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Comply with 408.60(E)(3)-Existing busbar connected to ss#1 is undersized. 2) Provide Asbestos Abatement compliance document.. 12/7/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/2/19 Swap dwg 1 rev 2.				
55869	18A0696	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement document. 2) Provide selective coordination . 3) Provide cutsheets. 4) Verify ground fault protection . 12/27/18 1) Comply with 408.36 Provide main OCPD to new 'EDP-PH-2'. 2/13/19 1) Item #1 from revision 12/27/18 not addressed. 4/25/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55815	18A0697	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Selective coordination TCC need to be signed, sealed and performed by P.E. 2) Feeder neutral to second building shall not be bonded as per Article 225. 12/31/2018- 1) Provide bonding & grounding to FP S.S.W. 3/25/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/8/2022 Amended Plan # 1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/16/2022 Amended Plan # 1 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55529	18A0700	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/7/19 1) Service incoming cond are undersized-comply with 230.42(A)(2). 2) Provide location of S.E.B in relation to service rom and comply with 230.6. 3) Fire pump conductor is undersized-FLA of Table 430.250 is used not FIA of name plate. 4) Fire pump EGC is undersized-T250.122. 4/12/19 Swap dwg 2 of 2-Revision 2. 12/7/2021 Amended plan# 1 Rev 1 .Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55826	18A0701	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Tap conds feed 60A disconnect switches are undersized-240.21(B). 2) Fix typo of ATSS terminals. 3) Provide OCPS and conds sizes normal size feeds "EMR", "EMLPC5" and "EMLPR" panels. 4) Provide coordination and short circuit study signed and sealed by P.E. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 12/27/18 1) Item #2 is not addressed. 2) Item #3 is partially addressed-provided OCPD valve fees "EMR", "EMLPCS" and "EMLPR" panels normal size. 3) Provide adequate AIC rating to "DP7" panel 4) Coordination doesn't make EAB one line 5) Comply with 696.4(B)(3)(4)-Provide 12" separation. 2/6/19 - 1. Confirm that 800A SS#3 & down stream breaker 300A JXD2 all not overlapped above 0.1 sec. 4/9/19 Job finalized. With the stipulation that coordination study recommended settings to be followed Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/20/2020 Amended Dwgs # 1 & 2 Rev 4 . Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55626	18A0702	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide available short circuit current at meter bank. 12/20/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/1/19 Swap 1&2 rev 2. 3/10/2020 Swap dwg #16358--2-Revision 3 .Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55527	18A0705	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55536	18A0707	Special Permission	Approved	\$350.00
<p>With the stipulation that the installation and inspection shall be in accordance with 2014 NEC. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55591	18A0708	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Short circuit study and protective device coordination study need to be stamped, signed and performed by P,E. 2) Physical doesn't match one line diagram for MSB-2-in Section #1. 12/10/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/10/19 1) Provide new contractor license #. 2) Add triangle to contractor name as a new change. 3) Show neutral bonding of "FP-SW", "FA-SW" & "ARCS-SW". 4) Confirm 5' clearance in front of "FP-SW". 5) Update Dwg # 3 of 3 with new contractor name. 10/02/19 Swap Dwg # LNY0020492-S1-OL (1,3) Rev 3, (2,3) Rev 3, (3,3) Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55537	18A0709	Special permission material for retrofit	Approved	\$350.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
55533	18A0710	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/24/2021 Amended Plan # 1,2, 3, & 4 Rev- 2.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/3/2021 Amended dwgs# 1, 2, 3 & 4 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55528	18A0711	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/24/2020 Swap Dwg # 24150FP20-01 of 1 Rev 2 and 24150AB20-01 of 1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55872	18A0712	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Asbestos Abatement document. 2) Comply with 230.54 B(1)-Verify if there is existing service switch in front of new 800A service switch. 3) Confirm if doors open outwards or inwards. 4/25/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/21/19 Swap Dwg # Rev.2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/18/19 Swap Dwg # rev.3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55694	18A0713	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Provide Asbestos Abatement compliance document. 2/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55534	18A0714	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55584	18A0715	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide EGC size to MC cables with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/27/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/28/2020 Amended Plan # 1 Rev- 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
56119	18A0716	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement. 11/14/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/10/2020 Swap dwg #ACS-D-13372-1-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55532	18A0717	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55805	18A0718	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance form. 2) Meterbanks are not on physical. 3/26/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.. 4/19/19 Swap Dwgs 1 and 2-Revision 2. 9/15/2020 Amended Plan #1 & 2 Rev- 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55585	18A0719	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Provide Asbestos Abatement compliance document. 11/27/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55987	18A0720	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement document.. 6/3/19 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/7/19 Provide location of the fire alarm, provide short circuit calculation of fire alarm. 9/19/19 Swap Dwg 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/27/19 Swap Dwg 1 rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55760	18A0721	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance document. 3/6/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/20/19 Swap Dwg #1-Revision 1 and dwg 2-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
56143	18A0722	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide selective coordination study. 2) Provide available short circuit current at fire pump controller verify 2 F.P. service switch . What is the AC at the fire pump of what is the short circuit rating at the F.P. controller. 3) F.P. verify tr sec is grounded 12/26/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/21/20 Amended Plan ACS-D-13298-3, Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55586	18A0723	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Asbestos Abatement compliance doc is required. 11/27/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55602	18A0724	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement document.. 11/30/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/14/19 1) Provide fire pump and feeder permit and submittal. 9/19/19 Swap Dwg 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55587	18A0725	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) F.P. conds-emergency side and normal side before service switch are undersized. 11/29/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/12/19 Swap Dwg #1,2 & 3 Rev-2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/17/2020 Amended Plans # 1, 2, & 3 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/10/2021 Amended Plan # 1,2 & 3 Rev-4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0726	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>OR 1) Provide Asbestos Abatement compliance document. 2) Provide coordination between new 600A FRN fuse and upstream fuse signed and sealed by P.E. 3) Provide existing sectional bus size in Section #3</p>				
55611	18A0729	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55671	18A0730	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Provide coordination between new 1200A KRPC fuse and down stream fuses signed and sealed by P.E. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55531	18A0731	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

October 23, 2018

Approval #	Submission #	Type of Request	Status	Fee
55571	18A0733	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Asbestos Abatement compliance document or ACP-5 control #. 2) Verify that "PLP panel is suitable for the use as service equipment. 3) Confirm that 800A (ssw#2) and 400A TCC are not overlapping. 4) Indicate the location of S.E.B. in relation to service room.11/16/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/24/2020 Amended dwg # 1 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	18A0735	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Conds feed transformers T1 & T2 are undersized. 2) Firest part of incoming service busbar are undersized in "SWGR1". 3) Provide clearance in front of SWGR1 and verify 2HR fire rated room construction and ventilation to all electric rooms. 4) Physical doesn't match one line of "SWGR2"-switchgear amperage rating is different. 5) Provide OCPD values of stand by generators. 6) Correct voltage rating of generators in coordination study one line. 7) Explain 3.3.2 (transformers) in short circuit coordination study confirm that transformer differential relay being provided</p>				