

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
BK00085A1	BK00085	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/9/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <p>1) Contact Con-Edison regarding Blue Book requirements.</p> <p>2) It is applicant responsibility to Maintain Listing for all new, and modified existing equipment.</p> <p>3) It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. 8/5/2020 Job finalized.</p> <p>Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK00120A1	BK00120	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/6/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> · Contact Con-Edison regarding Blue Book requirements. · It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. · It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. · It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 11/18/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
	BK00121	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>11/4/19 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf The §4000-01 Rule includes but not limited to the following:</p> <p>a. Bus bar sizes within an NRTL listed switchboards/panels shall not be shown, only the rating of the equipment and not the rating of bus bars. A note of compliance with 2011 NYCEC can be added on the plans.</p> <p>b. The new or existing service/system (generator) grounding and bonding as per NEC Article 250 shall be noted on the plans.</p> <p>c. Provide equipment rating and available Short circuit current (on the plans) to all new equipment.</p> <p>d. Confirm NRTL listing to all new equipment.</p> <p>e. Only one line drawing up to the second level of OCPDs, and room lay out shall be submitted. The room lay out shall clearly shows all new equipment (clearly labeled) and the appropriate clearance as per 110.26. Discard all other unnecessary drawings and do not show demolition plans.</p> <p>f. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing.</p> <p>2. Briefly provide the sequence of operation.</p>				
BK00124A2	BK00124	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/10/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. 10/15/2020 Job finalized. <p>Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/15/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/10/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 8/17/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
BK00129A	BK00129	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/4/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 				
BK00135A1	BK00135	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/5/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> · Contact Con-Edison regarding Blue Book requirements. · It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. · It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. · It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 6/4 /2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/6/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/14/2022 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/19/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				
BK00162A	BK00162	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>3/4/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
	bk00162	Requested approval for the electric service equipment proposed to be installed		\$650.00

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
BX00045A1	BX00045	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/16/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 1/20/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BX00068A2	BX00068	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>2/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 5/20/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
MN00021A	MN00021	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>2/7/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00022A2	MN00022	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/19/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 2/2/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 4/12/2023 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				
MN00033A	MN00033	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/28/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00059A2	MN00059	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/30/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 11/5/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/29/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				
MN00061A	MN00061	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/3/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 11/3/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00069A1	MN00069	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/2/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 11/3/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 				
	MN00077	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>10/22/19 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf:</p> <p>The §4000-01 Rule includes but not limited to the following:</p> <ul style="list-style-type: none"> a. All drawings must include PE/RA Seal and sign. b. Bus bar sizes within an NRTL listed switchboards/panels shall not be shown, only the rating of the equipment and not the rating of bus bars. A note of compliance with 2011 NYCEC can be added on the plans. c. The new or existing service/system grounding and bonding as per NEC Article 250 shall be noted on the plans. d. Provide equipment rating and available Short circuit current (on the plans) to all new equipment and at the POE based on NYC 4000-01 Rule. e. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing. f. Confirm NRTL listing to all new equipment. g. Provide Plan view / service equipment room layout h. All voltages must be clearly shown on the drawings, which must include voltages pertaining to all of the equipment overcurrent protection up to and including the second level protection. i. If the existing service equipment and/or point of service entrance is to be discontinued, the drawings must so state. 				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00079A1	MN00079	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>2/7/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/16/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/29/2022 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/23/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN00080A	MN00080	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/3/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department.</p>				
MN00082A1	MN00082	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>5/27/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN00083A1	MN00083	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/30/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: · Contact Con-Edison regarding Blue Book requirements. · It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. · It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. · It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 9/3/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/9/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00107A1	MN00107	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/17/19</p> <ol style="list-style-type: none"> 1. All drawings must include PE/RA Seal and sign. 2. Bus bar sizes within an NRTL listed switchboards/panels shall not be shown, only the rating of the equipment and not the rating of bus bars. A note of compliance with 2011 NYCEC can be added on the plans. 3. Neutral bus bar/conductor shall not be shown. 4. The new or existing service/system grounding and bonding as per NEC Article 250 shall be noted on the plans. 5. Provide equipment rating and available Short circuit current (on the plans) to all new equipment and at the POE based on NYC 4000-01 Rule. 6. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing. 7. Confirm NRTL listing to all new equipment. 1/27/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 				
MN00119A2	MN00119	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/26/19</p> <ol style="list-style-type: none"> 1) Contact Con-Edison regarding Blue Book requirements. 2) It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. 3) It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. 4) It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 5) Where installation of equipment differs from the 11/28/2023 New cover letter with new P.E. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/4/2023 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 2/2/2024 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00125A1	MN00125	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/7/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> · Contact Con-Edison regarding Blue Book requirements. · It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. · It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. · It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 6/29/2023 New cover sheet submitted with new P.E. name. Job finalized. <p>Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN00128A	MN00128	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/5/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 				
MN00133A2	MN00133	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/22/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/23/2020 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
MN00137A1	MN00137	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>3/4/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
MN00153A	MN00153	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/24/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00154A1	MN00154	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
12/20/19 Disclaimer: Please note that Electrical Plan Review (EPR) final approval does not eradicate the applicants' liability to all submitted work including submitted coordination study. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Following the recommended settings within the provided coordination study and matching the approved plans are the applicant's responsibilities. - Where installation of equipment differs from the approved original drawings, amended drawings/Coordination must be filed with the department.				
MN00164A	MN00164	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
11/21/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. Additional Comments: - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department.				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
QN00012A1	QN00012	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/23/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 1/12/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/25/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 				
QN00015A2	QN00015	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>12/19/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 2/23/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
QN00018A3	QN00018	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/15/20 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Where installation of equipment differs from the approved original drawings, amended drawings must be filed with the department. 3/16/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/16/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/2/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/30/2022 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				
QN00131A	QN00131	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/22/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. 				

ADVISORY BOARD CALENDAR

October 31, 2019

Approval #	Submission #	Type of Request	Status	Fee
QN00140A3	QN00140	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/4/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement.. 7/14/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/4/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/21/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 				
SI00106A	SI00106	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1/24/20 Disclaimer: Please note that Electrical Plan Review (EPR) final approval does not eradicate the applicants' liability to all submitted work including submitted coordination study.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. - It is applicant responsibility to ensure proper bonding and grounding to existing service switches with fuse replacement. - Following the recommended settings within the provided coordination study and matching the approved plans are the applicant's responsibilities. - Where installation of equipment differs from the approved original drawings, amended drawings/Coordination must be filed with the department. 				
SI00132A	SI00132	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/22/19 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> - Contact Con-Edison regarding Blue Book requirements. - It is applicant responsibility to Maintain Listing for all new, and modified existing equipment. - It is applicant responsibility to comply with Building code for emergency and standby power system generators BC 1704.31 and all other Building code requirement. 				