

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49107CO2	08A0562CO2	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Red Hook Water Pollution Plant 63 Flushing Avenue Brooklyn NY	Hold	\$0.00
Carry over from July 15, 2009 meeting. 1) Underrated equipment must be corrected (see also special permission 49844). 2) Verify coordination is maximized.						
49424CO3	09A0183CO3	CMS Electrical Services Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Equity Office Properties 717 Fifth Avenue New York NY	Hold	\$0.00
Carry over from June 17, 2009 meeting. Show actual drawing of the bus and switch details fed off of the generator, or provide the test report form the NRTL that listed the product.						
49584CO2	09A0299CO2	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Elmhurst Hospital Center 79-01 Broadway Elmhurst NY	Hold	\$0.00
Carry over from October 14, 2009 meeting. Have applicant appear at December 16, 2009 meeting						
49611CO2		K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10145	Requesting permission due to water damage to: 1) Replace a defective feeder and 400 amp disconnect switch. 2) Replace 2 sets of 500 MCM feeders fed from a 3000 amp service switch fused at 800 amps. 3) Replace 8 sets of 500 MCM fed off of another 3000 amp service switch fused at 3000 amps on a 1000 KVA service without filing full Advisory Board drawings.	244 Madison Avenue New York NY	Approved	\$0.00
Carry over from September 16, 2009 meeting. With the stipulation that permanent signage is posted indicating that 4000 amp fuses cannot be changed without an outage, and the 3000 amp switch has signage indicating maximum fuse size 800 amps. Cleaning and testing of equipment shall be performed by a certified testing company and the documents shall be available at inspection.						
49749CO	09A0422CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Con Edison Fire Water Supply 4 Irving Place New York NY	Approved	\$0.00
Carry over from October 14, 2009 meeting.						

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49763CO	09A0436CO	Arcadia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	Curtis High School 105 Hamilton Avenue Staten Island NY	Approved	\$0.00
Carry over from October 14, 2009 meeting.						
49786	09A0444	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Javits Convention Center 655 West 34th Street New York NY	Approved	\$650.00
49787	09A0445	Bronxdale Electric, Inc. 1718 White Plains Road Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	148 East 24th Street New York NY	Approved	\$650.00
1) Fire pump circuit conductors not fire rated. 2) Service entrance conductors feeding service switch #1 not shown. 3) New opening Ok. 4) 7' clearance needed between service switches 5 & 6. 5) Provide GE equipment submittal. Job finalized 2/27/12.						
49788	09A0446	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	40 Worth Street New York NY	Approved	\$650.00
1) Add 1 additional doors on each side of service room. 2) Doors in service rooms to open outwards. 3) Verify sets of conductors on line and load sides of transformers. Job finalized 12/28/09.						
49789	09A0447	Total Electrical Construction Co. Inc. 230 Green Street Brooklyn NY 1122	Requested approval for the electric service equipment proposed to be installed	LIRR East Side Access 41st Avenue and Northern Blvd. Long Island City NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49790	09A0448	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Taconic Mgmt Co., LLC 111 Eighth Avenue New York NY	Approved	\$650.00
49791	09A0449	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	100 Imlay Street Brooklyn NY	Approved	\$650.00
<p>1) Transformer secondaries not grounded. Provide Delta-WYE. 2) Verify that service room is mechanically ventilated. 3) Verify that no emergency feeders are ran through the service room. 4) Fire pump to be connected to generator. 5) Verify if 3 or 4 pole ATS' will be installed. 6) GF trip not permitted on devices feeding life safety loads. 7) Verify barriers between switchboard sections. Job finalized 6/4/10.</p>						
49792	09A0450	A Tech Electric Enterprises, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Voorhees Building 186 Jay Street Brooklyn NY	Approved	\$650.00
<p>Bond neutral to enclosure on normal side FCO. Job finalized 12/29/09.</p>						
49793	09A0451	Knight Electrical Services Corp. 111 Eighth Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Approved	\$650.00
<p>1) Verify that service room is mechanically ventilated. 2) 500KVA transformer neutral should be grounded. N-G bond exists at PP-4. Job finalized 2/17/10.</p>						
49794	09A0452	Atlas--Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	#2 World Financial Center New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49795	09A0453	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 Eighth Avenue New York NY	Approved	\$650.00
Indicate cable size feeding existing distribution bus trough. Job finalized 1/19/2010.						
49796	09A0454	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Capital One 17 University Place New York NY	Approved	\$650.00
49797	09A0455	Maximum Electric Corp. 34-17 Broadway Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	360 East 88th Street New York NY	Approved	\$650.00
49798	09A0456	United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	370 Canal Street New York NY	Approved	\$650.00
49799	09A0457	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Royal Plaza 132-35 41st Road Flushing NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49800	09A0458	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Rentar Metro Mall 66-26 Metropolitan Avenue Middle Village NY	Approved	\$650.00
49801	09A0459	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	401 Park Avenue South New York NY	Ok, but	\$650.00
1) Bus undersized in distribution switchboard. 2) Provide 2nd gate in fence.						
49802	09A0460	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	40 West 77th Street New York NY	Approved	\$650.00
49803	09A0461	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1201 Broadway New York NY	Approved	\$650.00
49804	09A0462	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS 149 360 East 145th Street Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49805	09A0463	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Target Store 517 East 117th Street New York NY	Approved	\$650.00
Provide full size service room layout w/ dimensions. Job finalized 10/19/10.						
49806	09A0464	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Target Store 40-20 College Point Blvd. Flushing NY	Approved	\$650.00
Provide full size service room layout w/ dimensions. Job finalized 10/19/10.						
49807	09A0465	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	123 3rd Avenue New York NY	Ok, but	\$650.00
1) Fire pump service entrance and branch circuit conductors is undersized. 2) Barrier rear of new service switchboard.						
49808	09A0466	GTS Electrical 218-14 Northern Blvd. Bayside NY 1136	Requested approval for the electric service equipment proposed to be installed	7 Bushwick Place Brooklyn NY	Hold	\$650.00
1) Explain use of Y-Y transformer and code grounding. 2) Submit manufacturer's drawings. Design drawings submitted. 3) Submit floor plan in appropriate scale to read. 4) Have engineer/contractor appear at next meeting.						
49809	09A0467	Robert Director Assoc. Consulting Engineer 19 West 44th Street New York NY 10036	Requested concept approval:	Milford Hotel 700 Eighth Avenue New York NY	Approved	\$0.00
1) Prove that neutral service bus is adequate for the load and some spare capacity. 2) Fire pump service switch not to be installed in switchboard. 3) Special permission letter to accompany future Advisory Board drawing requesting permission to leave service neutral bus as existing. 4) The new drawings shall show that the existing service bus complies withstand ratings.						

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49810	09A0468	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	One World Trade Center New York NY	Hold	\$650.00
1) Mark up drawings drawing show what connectors are needed. 2) Fuel cell drawings to come.						
49811	09A0469	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	50 Rockefeller Plaza New York NY	Approved	\$650.00
49812	09A0470	CSA Engineering Services 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	2000 East Tremont Avenue Bronx NY	Ok, but	\$650.00
1) Show detail of service room, doors and walls. 2) Electrician not shown in title block.						
49813	09A0471	Double K Electric Corporation 24703 Jamaica Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	Garden of ONO Restaurant 18 9th Avenue New York NY	Approved	\$650.00
49814	09A0472	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS 8 37 Hicks Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49815	09A0473	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital 177 Fort Washington Avenue New York NY	Approved	\$650.00
1) Transformer ground to be connected to grounding electrode system not rod. 2) Ground fault not provided for transformer. 3) Show grounding bus in switchboard. Job finalized 12/29/09.						
49816	09A0474	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	210 East 68th Street New York NY	Approved	\$650.00
49817	09A0475	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	11 West 51st Street New York NY	Approved	\$650.00
49818	09A0476	Dooley Electric Company, Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Lasdon House 404-420 East 70th Street New York NY	Approved	\$650.00
1) Fire pump feed to be tapped from end box. 2) Fire pump service switch neutral to be bonded to enclosure. Job finalized 2/2/10.						
49819	09A0477	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Long Island Jewish Hospital 270-27 76th Avenue Queens NY	Hold	\$650.00
1) Fire pump branch circuits are undersized. 2) Fire pump branch circuits to be fire rated. 3) Reverse 5 KV switch for emergency board. 4) Emergency board change main 3000 amp switches and 3000 amp tie, switch to 4 pole and install kirk key interlock system. 5) Provide bus sizes in panelboards. 6) Install 100 amp fuses in fire pump service switches. 7) Show barrier separating emergency feeders from normal bus in switchgear.						

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49820	09A0478	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Boricua Village, Bldg. "D" 507 East 161st Street Bronx NY	Approved	\$650.00
49821	09A0479	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	The Peninsula Hotel 700 Fifth Avenue New York NY	Approved	\$650.00
49822	09A0480	United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	40-17 Main Street Flushing NY	Approved	\$650.00
Limit the new service switch fuses to 80% with signage. Job finalized 1/10/11.						
49823	09A0481	Bayside Electrical Contractors Corp. 40-18 31st Avenue Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	301 West 57th Street New York NY	Approved	\$650.00
Limit the new service switch fuses to 80% with signage.						
49824	09A0482	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	63 East 9th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49825	09A0483	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1510 Lexington Avenue New York NY	Approved	\$650.00
49826	09A0484	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Battery Park Site #23 300 North End Avenue New York NY	Approved	\$650.00
Provide reduced neutral calculations. Job finalized 4/5/10.						
49827	09A0485	Sajun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	30 Irving Place New York NY	Approved	\$650.00
49828	09A0486	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	53-01 32nd Avenue Woodside NY	Approved	\$650.00
49829	09A0487	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Center 1400 Pelham Parkway South Bronx NY	Hold	\$650.00
1) Drawings not submitted in Advisory Board format. 2) Designer to appear at meeting to explain job.						

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49830	09A0488	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS 430 29 Fort Greene Place Brooklyn NY	Approved	\$650.00
1) Equipment grounding conductor to be sized at per table 250.122. 2) Feeder to comply with tap rules. Job finalized 6/2/10.						
49831	09A0489	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Lowe's Kings Plaza 5100 Kings Plaza Brooklyn NY	Hold	\$650.00
1) ATS for life safety cannot be located in the service room. 2) Verify that emergency feeders are not running through the service room. 3) Fire pump feeders not fire rated. 4) Secondary of step down transformer not grounded. 5) Generator neutral to be bonded and grounded to grounding electrode. 6) FCO cutout to be tapped on line side of 2000 amp switch. 7) 2 switches installed ahead of FACO. 8) 2 sets of 350 fused at 800 amps. 9) Verify if transformer is Con Eds or buildings. 10) Short circuit study not complete details not included. 11) Designer to appear at next meeting to explain job.						
49832		Department of Environmental Protection 59-17 Junction Boulevard Flushing NY 11373	Requesting permission to replace underground defective 5KV feeders that failed between manholes with new.	Bowery Bay Sewage Plant Astoria NY	Approved	\$0.00
49833		Daniel s Electric Inc. 1465A Flatbush Avenue Brooklyn NY 11210	Requesting permission to install underground service entrance conductors in Schedule 80 non metallic conduit.	737 Elvira Avenue Far Rockaway NY	Approved	\$0.00
49834		Daniel s Electric Inc. 1465A Flatbush Avenue Brooklyn NY 11210	Requesting permission due to not damaging an historical building, to install an upgraded feeder to an apartment inside of an operational dumbwaiter shaftway for a fifth floor apartment.	35-36 80th Street Jackson Heights NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49835		New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission on upgrading 26 elevator locations to: 1) Utilize existing conduits originally installed in shaftways and allow the installation of new unspliced feeders. 2) To allow the installation of new conduit containing unspliced feeders inside of the shaftway.	Brevoort Houses e, 1871,1865,1853,1839 and 1831 F Brooklyn NY	Approved	\$0.00
49836		Control Spec Electrical Systems, Inc. 30-60 Review Avenue Long Island City NY 11101	Requesting permission to leave as installed in a place of assembly AC cable that does not contain an equipment grounding conductor.	31 Division Avenue Brooklyn NY	Approved	\$350.00
49837		ACP Electrical Contracting, Inc. 412 West 48th Street New York NY 10036	Requesting permission to utilize Section 408.54 of the 2008 NEC and allow the installation of a 84 pole circuit breaker panel	349 Broadway, 3rd Fl. New York NY	Approved	\$0.00
49838		M & M Electric Inc. 1076 Castleton Avenue Staten Island NY 10310	Requesting permission to install a replacement electrical service on the outside of a salt shed building where there is no room inside due to the shed being filled with salt.	Dept. of Sanitation Tompkins Avenue Staten Island NY	Approved	\$0.00
49839		MSR Electrical Construction Co. 31 Bay Street Brooklyn NY 11231	Requesting permission due to no indoor common space in a residential building, to install the service equipment on the outside of the building.	100 Beach 131st Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49840		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to leave as installed due to a hardship to replace fire pump branch circuits with equipment grounding conductors sized as per table 250.66 instead of table 250.122.	Rego Park Mall 61-01 Junction Blvd. Rego Park NY	Denied	\$0.00
49841		Fas Electrical Contractors, inc. 90-61 Pitkin Avenue Ozone park NY 11417	Requesting permission to install overhead service entrance conductors in rigid non metallic conduit that will be exposed to corrosive salt air.	355-355A Beach 44th Street Edgemere NY	Approved	\$0.00
49842		Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street New York NY 10001	Requesting permission to replace one 4000 and one 1600 amp service switches without filing Advisory Board drawings.	Brookfield Properties 1 Liberty Plaza New York NY	Approved	\$0.00
With the stipulation that the first and second fuses are coordinated.						
49843		AK Electrical Group Inc. 6815 8th Avenue Brooklyn NY 10220	Requesting permission to leave one mean of egress for a service room due to a pump room and an oil tank room surrounding the service room, and to leave in place the existing oil tank room door swinging into the service room which is not a means of egress from the service room but from the oil tank room.	98 Riverside Drive New York NY	Approved	\$0.00
49844		Dept. of Environmental Protection 59-17 Junction Boulevard Flushing NY 11373	Requesting permission to waive coordination issues for this portion of a project that will be addressed and corrected in the future when the existing equipment is replaced.	Red Hook Water Pollution Brooklyn NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49845		Maximum Electric Corp. 34-17 Broadway Astoria NY 11106	Requesting permission to install a seventh service switch where 3 service switches power fire pumps.	360 East 88th Street New York NY	Approved	\$0.00
49846		Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requesting permission to allow a non selective system to be installed where the load is feeding computer equipment.	#2 World Financial Center New NY	Approved	\$0.00
49847		Bayside Electrical Contractors Corp. 40-18 31st Avenue Astoria NY 11103	Requesting permission to install a seventh service switch where two of the existing service switches power fire pumps.	301 West 57th Street New York NY	Approved	\$0.00
49848		United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requesting permission to tap power for a 1600 amp service switch from a service bus sized at 4-1/4x5 copper bars that also feeds 1200 and 800 amp service switches.	40-17 Main Street Flushing NY	Approved	\$0.00
With the stipulation that the total sum of the fuse sizes shall not exceed 4000 amps based on 800 amps per square inch requirements and signage is provided on each switch indicating the maximum fuse size.						
49849	09A0490	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your High Bay Fluorescent Lighting Fixture. Model/Series Numbers: HBT5-446, 646, 346, 846, 546 - HBT8-448, 648, 348, 548 and 848.		Hold	\$200.00
Provide Test Report						

ADVISORY BOARD CALENDAR

November 18, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49850	09A0491	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Surface/Pendent Mounted Fluorescent Wrap Fixtures. Model Series/Numbers: 300-220, 300-220TAN, 300-230, 300-240, 300-240TAN, 300-420, 300-440, 300-272, and 300-296		Hold	\$200.00
Provide Test Report						
49851	09A0492	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Fluorescent Surface/Pendent Mount Wrap Fixtures. Model/Series Numbers: 390-220 and 390-240.		Hold	\$200.00
Provide Test Report						
49852	09A0493	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Fluorescent Surface/Pendent Mount Wrap Fixtures. Model/Series Numbers: RDIALP-2X2, 2X4 T5/T8 LAMPS.		Hold	\$200.00
Provide Test Report						
49853	09A0494	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Recessed Fluorescent Troffer Lighting Fixture. Model/Series Numbers: EL-1x2, EL-1x4, EL-2x2, EL-2x4.		Hold	\$0.00
Provide Test Report						