



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 115-08-E

Manufacturer: Kingsman Fireplaces
2340 Logan Avenue
Winnipeg, MB R2R 2V3
CANADA

Trade Name(s): Solace – Marquis Collection by Kingsman

Product: Zero clearance direct vent gas fireplace
MEA Index #300-20 – Gas-fired Fire Place

Pertinent Code Section(s): Subchapters 14 and 15

Prescribed Test(s): RS 14-6 (ANSI Z21.50a).

Laboratory: Intertek Testing Services NA, Inc.

Test Report(s): No. 3101993COQ-001a issued January 15, 2007.

Description: Gas-fired, decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room. Units are equipped with electric ignition.

Model No.	Description	Rating (Btu/hr)
HBZDV3628	Direct vent, zero clearance fireplaces, control box and battery spark ignition	28,000
HBZDV3632	Direct vent, zero clearance fireplace, control box and battery spark ignition	30,500
MQHBZDV3636	Direct vent, zero clearance fireplace, control box and battery spark ignition	30,500

Terms and Conditions: The above-described gas-fired, vented appliances are accepted for decorative heating under the following conditions:

1. Units shall be installed indoors only.
2. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
3. Units shall use natural gas only.
4. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
5. Venting of units is subject to Section 27-879 of the New York City Building Code.
6. Approval of all electric equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
8. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance May 14, 2008
Examined By Donald [Signature]