



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 117-07-M

Manufacturer: Ferrari, 38352 La Tour Du Pin Cedex, France
38352

Trade Name(s): Precontraint® 932

Product: PVC-coated fabric for covering metal frame
buildings

Pertinent Code Section(s): 27-514, 27-499, 27-501, 27-506, 27-507

Prescribed Test(s): RS 7-3 (NFPA 701)

Laboratory: Intertek Testing Laboratories, Inc.

Test Report(s): Report 3093761SAT-001, dated March 17, 2006.

Description: Precontraint® 932 is a composite textile made of a high-tenacity polyester base cloth, coated with plasticized PVC with an acrylic varnish top coat. The material is suitable for use as a membrane to cover metal frame buildings and textile architecture projects. The total weight is 28 oz. per sq. yard.

Terms and Conditions: The above material can be accepted with the following conditions:

1. Fabric must meet the flame resistance requirements of Section 27-515 of the New York City Building Code, for use in covering metal frame buildings to enclose spaces classified in occupancy groups C, E, F, G, H, or J.

2. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions.
3. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance June 28, 2007

Examined By Simon Derkshidan