

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, A.I.A., Commissioner
MEA 119-02-E**

Report of Material and Equipment Acceptance Division

Manufacturer – Wolf Range Company, 19600 South Alameda Street, Compton, CA 90221.

Trade Name(s) – Wolf Newport Ranges.

Product – Gas fired commercial ranges.

Pertinent Code Section(s) -27-800, 27-826, RS 13-2, 13-3.

Prescribed Test(s) - RS 14-6 (ANSI Z83.11).

Laboratory – CSA International.

Test Report(s) – No. 1306855, dated May 1, 2002.

Description – Commercial gas cooking appliances. Combination of open tops and standard oven. Unit comprises main burners, pilot lighters with manual gas burner valves for the top burners and solid automatic thermostat for oven main burner with standard pilot burner with manual piezo spark ignitor and gas pressure regulator.

Model Number	Oven BTUH	Top BTUH
NP36N	32,000	6 @ 26,000

Notes: 1. Unit may be installed on combustible flooring

2. Unit shall be installed with the following minimum clearances to combustible combustion: sides- 10 inches; rear- 6 inches.

Recommendation – That the above commercial kitchen equipment, be accepted, when fired by natural gas only, under the following conditions:

- 1. Unit shall be installed in accordance with manufacturer's instructions and National Fuel Gas Code and New York City Building Code requirements.**

2. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS-13 requirements of the New York City Building Code and have a fire suppression system complying with Reference Standard RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The Fire Suppression system exclusively used for cooking equipment shall be filed with the Building Department and examined and approved by the Fire Department
3. The installation shall not interfere with combustion air, accessibility for operation and servicing.
4. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
5. Special precautions regarding exhaust fans in the vicinity of the equipment may be required to prevent interference with operation of the equipment.
6. For grease removal, suitable baffle type grease filters, MEA accepted, shall be installed.
7. Gas line tubing and fitting connectors shall permit flexibility for operation, cleaning and servicing, and shall be MEA accepted for such use.
8. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing unit
9. All work provided by the installer from the point of gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector
10. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in section 27-131 of the Building Code.
11. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance _____

Examined by _____