



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 12-08-E

Manufacturer: Wolf Steel Ltd., 24 Napoleon Road,
Barrie, Ontario L4M 4Y8 CANADA

Trade Name(s): Napoleon & Continental Fireplaces

Product: Gas-fired vented decorative fireplace heaters/appliances
MEA Index #300-20 – Gas-fired Fire Place

Pertinent Code Section(s): Subchapters 14 and 15

Prescribed Test(s): RS 14-6 (ANSI Z21.88, ANSI Z83.11 and
ANSI Z21.50)

Laboratory: Intertek Testing Services NA, Inc.

Test Report(s): Report No. 3082516 issued May 31, 2006.
“ “ 3107080 issued November 1, 2007.
“ “ 3093208TOR-004a issued August 20, 2007.
“ “ 3037698 issued July 2003.
“ “ 3085395 issued May 31, 2006.
“ “ 3093208TOR-004 issued August 14, 2007.
“ “ 277-0388-00 issued June 2003.

Description: Direct-vented gas fireplace heaters and direct-vented gas fireplaces. Units, with model numbers, input and output heating ratings, are listed on the following page.

Model No.	Type	Input (Btu/hr)	Output (Btu/hr)
GD82NT	Vented Gas Fireplace Heater	26,000	16,150
GD82TTN	Vented Gas Fireplace Heater	26,000	16,150
BGD36CFN	Vented Gas Fireplace Heater	17,000	10,900
BCDV36CFN	Vented Gas Fireplace Heater	17,000	10,900
BGD42CFN	Vented Gas Fireplace Heater	24,000	16,000
BCDV42CFN	Vented Gas Fireplace Heater	24,000	16,000
GT8N	Vented Gas Fireplace Heater	6,000	4,680
GDS25N	Vented Gas Fireplace Heater	24,500	18,400
GDI-44	Vented Gas Fireplace Heater	40,000	27,600

Terms and Conditions: The above-described gas-fired vented appliances are accepted for decorative heating operation under the following conditions:

1. Natural gas to be used only.
2. For indoor installation only with combustion air and required ventilation air provided. Venting of fireplace is subject to Section 27-879 of the New York City Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and delivery of such equipment shall be accompanied by a metal tag, permanently affixed to the units and suitably placed, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 30, 2008
 Examined By 