



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 12-91-E Vol. 4

Manufacturer: First Operations, 8273 Moberly Lane, Dallas, TX 75227

Trade Name(s): First Co. or U.S. A/C Products

Product: Air-cooled condensing units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-8 (UL 1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA11605 dated April 28, 2006 and October 20, 2006

Description: Self-contained, air-cooled packaged units, model WCX for thru-the-wall installation. R-22 is the refrigerant used within the system. Unit is comprised of hermetically sealed compressor, air-cooled condenser with indoor fan and safety controls. Unit is suitable for outdoor use. Units, with model numbers and nominal cooling capacities, are listed below:

Model No.	Nominal Cooling Capacity (Tons)
18WCX(#)-(AB*, BB*)	1.5
24WCX(#)-(AB*, BB*)	2.0
30WCX(#)-(AB*, BB*)	2.5

- reserved for future use

* - may have suffix letter

Terms and Conditions: The above-described thru-the-wall air-cooled, condensing units are accepted with the following conditions:

1. Units shall use only Refrigerant R-22.
2. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 22, 2007

Examined By Simon Deshpande