

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

**MEA 120-03-E  
Report of Material and Equipment Acceptance Division**

Manufacturer – Hussong Manufacturing Co., Inc, 204 Industrial Park Drive, Lakefield MN 56150.

Trade Name – Kozy Heat.

Product -Factory built direct vent gas fired heaters and decorative appliances.

Pertinent Code Section(s)- 27-800, RS 14-2 (ANSI Z223).

Prescribed Tests - RS 14-6 (ANSI Z21.50 - 1992, ANSI Z21.44, Z21.88).

Laboratory – Intertek Testing Services.

Test Reports - Report No. J97021289.1-231 dated September 25, 1997, J98009339, dated May 1, 1998, J98016162-231 dated June 24, 1998, J990003958-231 dated June 16, 1999, J20010055-231 dated April 24, 2000, J20009952-231 dated June 20, 2000, J20042308-231, dated April 26, 2001, 3025702 dated June 20, 2002, #3018076 dated May 22, 2002.

Description - Factory built direct vent gas fireplace heater (fireplace) designed to provide supplemental heating and to enhance the aesthetics of a room.

Model No.	Description	Input BTUH	
		Max	Min
56101	Direct vent fireplace heater. Standing pilot/piezo ignition system.	21,000	14,000
56150	Direct vent fireplace heater. Standing pilot/piezo ignition system.	22,000	20,900
56161	Direct vent fireplace heater. Standing pilot/piezo ignition system.	19,000	13,000
811	Gravity direct vent wall furnaces used in factory built solid fuel fireplaces, piezo/standing pilot ignition system.	40,000	27,500
911 XL	Solid fuel burning fireplaces, piezo/standing pilot ignition system.	36,000	21,400
932	Gravity direct vent furnace/fireplaces, piezo/standing pilot ignition system.	26,000	17,500

936	Gravity direct vent furnace/fireplaces, piezo/standing pilot ignition system.	32,000	21,000
SP-36	Direct vent fireplace, piezo/standing pilot ignition system	32,000	21,000
942-DV	Direct vent fireplace, piezo/standing pilot ignition system	32,000	21,000
944	Direct vent fireplace, piezo/standing pilot ignition system	28,300	25,000
961	Direct vent fireplace, piezo/standing pilot ignition system	38,000	23,800

Recommendation - That the above described factory-built fireplaces be accepted for use as supplemental heating and decorative purposes. The installation of the above described units shall be in accordance with manufacturer supplied instructions and all installations, uses and locations shall comply with Article 19 Solid Fuel Fireplace Stoves, and Room heater and Article 2 chimneys of the New York City Building Code and the U.L. Listing. Furthermore the unit shall be vented in accordance with Section 27-856 of the Building Code. All shipments and deliveries of such equipment shall be accompanied by a metal tag, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 7/21/03

Examined by Shyam or Bened