



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 120-08-E

**Manufacturer:** Denso Sales California, Inc.  
3900 Via Oro Avenue  
Long Beach, CA 90810

**Trade Name(s):** MovinCool Office Pro

**Product:** Single-packaged portable air conditioning units  
MEA Index #20-120 – Air Conditioning Equipment

**Pertinent Code Section(s):** 27-777, 27-770

**Prescribed Test(s):** RS 13-11B (ANSI B9.1), RS 13-12 (UL 484)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File SA10472, Vol. 1, Sections 2, 4 and 5.

**Description:** Single-packaged portable air-conditioning units for cord connection to the source of supply. R-410A is the refrigerant used for the system. Unit is comprised of compressor, evaporator, refrigerator coils, fans and controls. Units, with model numbers and cooling capacities, are listed below:

MODEL	Cooling Capacity (Btu/hr)
Office Pro 12	12,000
Office Pro 18	16,800
Office Pro 24	24,000
Office Pro 36	36,000
Office Pro 60	60,000
Office Pro 63	60,000

**Terms and Conditions:** The above-described air-conditioning units are accepted under the following conditions:

- 1) Units shall utilize Refrigerant R-410A only.
- 2) Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 3) Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
- 4) All equipment and deliveries of such equipment shall be suitably labeled certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 15, 2008

Examined By Simon Derflicker